

VENTILATION AUDIT REPORT

SCHOOL:	Lismore South Public School (2409)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Lismore

2409 - Lismore South Public School
Site Plan (11777)










1:653

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Communal Space - (155.02 SQM)	● Student Space (71)	
B00A - R0003 - Movement - (17.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (18.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Raised Platform - (51.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Movement - (20.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (17.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Reading Area - (194.23 SQM)	● Student Space (90)	
B00A - R1003 - Seminar/Study - (9.4 SQM)	● Office (2)	
B00A - R1004 - Seminar/Study - (9.75 SQM)	● Office (2)	
B00A - R1011 - Movement - (40.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Staff Room - (47.74 SQM)	● Office (11)	
B00B - R0002 - Movement - (14.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Movement - (120.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Movement - (42.39 SQM)	Not Applicable	Circulation or storage space.
B00B - R1006 - Sick Bay - (8.03 SQM)	● Student Space (3)	
B00B - R1007 - Duplicating Workroom - (12.03 SQM)	● Office (3)	
B00B - R1008 - Clerical Office - (11.74 SQM)	● Office (2)	
B00B - R1009 - Deputy Principal - (16.03 SQM)	● Office (4)	
B00B - R1011 - Principal - (21.01 SQM)	● Office (5)	
B00B - R1012 - Deputy Principal - (12.85 SQM)	● Office (3)	
B00B - R1013 - Interview - (12.35 SQM)	● Office (3)	
B00C - R1002 - Home Base - (71.21 SQM) - Teaching Space: 1	● Student Space (33)	
B00C - R1003 - Practical Activities - 1hb - (12.66 SQM)	● Student Space (5)	
B00C - R1007 - Movement - (12.56 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (280.35 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Movement - (66.77 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Practical Activities - 1hb - (17.84 SQM)	● Student Space (8)	
B00D - R1004 - Home Base - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1005 - Home Base - (50.94 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1006 - Practical Activities - 1hb - (18.96 SQM)	● Student Space (8)	
B00D - R1007 - Practical Activities - 1hb - (18.96 SQM)	● Student Space (8)	
B00D - R1008 - Home Base - (50.39 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0001 - Movement - (142.16 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (30.18 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (42.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - Home Base - (50.78 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1003 - Practical Activities - 1hb - (18.96 SQM)	● Student Space (8)	
B00E - R1004 - Practical Activities - 1hb - (19.03 SQM)	● Student Space (8)	
B00E - R1005 - Home Base - (50.7 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0002 - Movement - (512.78 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Movement - (125.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R1002 - Home Base - (51.24 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R1003 - Practical Activities - 1hb - (18.98 SQM)	● Student Space (8)	
B00F - R1004 - Home Base - (50.39 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R1005 - Practical Activities - 1hb - (18.96 SQM)	● Student Space (8)	
B00F - R1006 - Practical Activities - 1hb - (19.06 SQM)	● Student Space (8)	
B00F - R1007 - Home Base - (52.1 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R1008 - Home Base - (49.3 SQM) - Teaching Space: 1	● Student Space (22)	
B00F - R1009 - Practical Activities - 1hb - (19.11 SQM)	● Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R1012 - Home Base - (50.3 SQM) - Teaching Space: 1	 Student Space (23)	
B00F - R1013 - Practical Activities - 1hb - (19.06 SQM)	 Student Space (8)	
B00H - R0001 - Movement - (113.95 SQM)	Not Applicable	Circulation or storage space.
B00H - R1003 - Home Base - (66.37 SQM) - Teaching Space: 1	 Student Space (30)	
B00H - R1004 - Practical Activities - 1hb - (15.06 SQM)	 Student Space (6)	
B00H - R1005 - Withdrawal Space - 1hb - (11.11 SQM)	 Student Space (5)	
B00I - R0001 - Movement - (8.24 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Movement - (7.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Entry Vestibule - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Home Base - Pre - (68.95 SQM) - Teaching Space: 1	 Student Space (31)	
B00J - R0006 - Practical Activities - Pre - (46.29 SQM)	 Student Space (21)	