

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lithgow Public School (2410)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Bathurst</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lithgow</b>

2410 - Lithgow Public School  
Site Plan (12099)



1:946

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (19.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Home Base - (47.8 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0007 - Home Base - (47.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0009 - Seminar/Study - (12.46 SQM)	● Office (3)	
B00A - R0010 - Seminar/Study - (12.46 SQM)	● Office (3)	
B00A - R0012 - Reading Area - (147.96 SQM)	● Student Space (68)	
B00A - R0015 - Movement - (21.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (12.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Entry Vestibule - (18.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Deputy Principal - (18.73 SQM)	● Office (4)	
B00A - R0023 - Duplicating Workroom - (12.24 SQM)	● Office (3)	
B00A - R0024 - Movement - (51.36 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Movement - (8.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Principal - (26.91 SQM)	● Office (6)	
B00A - R0033 - Sick Bay - (7.09 SQM)	● Student Space (3)	
B00A - R0034 - Movement - (12.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0035 - Clerical Office - (16.82 SQM)	● Office (4)	
B00A - R1003 - Movement - (21.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Home Base - (49.49 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1005 - Home Base - (49.5 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1006 - Home Base - (49.5 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1007 - Home Base - (49.56 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1008 - Home Base - (49.43 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1009 - Movement - (21.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R1012 - Movement - (6.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Communal Space - (140.76 SQM)	● Student Space (65)	
B00A - R1016 - Raised Platform - (16.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Staff Room Annexe - (19.19 SQM)	● Office (4)	
B00A - R1018 - Movement - (8.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (11.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Withdrawal Space - 1hb - (16.54 SQM)	● Student Space (7)	
B00B - R0003 - Home Base - E - (20.84 SQM) - Teaching Space: 1	● Student Space (9)	
B00B - R0004 - Practical Activities - E - (9.82 SQM)	● Student Space (4)	
B00B - R0012 - Practical Activities - P - 1hb - (17.13 SQM)	● Student Space (7)	
B00B - R0013 - Home Base - P - (28.77 SQM) - Teaching Space: 1	● Student Space (13)	
B00B - R0014 - Staff Room Annexe - (14.07 SQM)	● Office (3)	
B00B - R0017 - Movement - (20.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (20.97 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Home Base - (49.14 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0005 - Home Base - (50.07 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0006 - Home Base - (50.16 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0007 - Home Base - M - (49.26 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0012 - Staff Room Annexe - (18.19 SQM)	● Office (4)	
B00D - R0014 - Movement - (96.31 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Practical Activities - S - 1hb - (6.71 SQM)	● Student Space (3)	
B00D - R0019 - Home Base - S - (42.42 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R1001 - Movement - (9.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Staff Room Annexe - (13.27 SQM)	● Office (3)	
B00D - R1003 - Home Base - (52.9 SQM) - Teaching Space: 1	● Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1004 - Home Base - (52.7 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1005 - Home Base - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1006 - Home Base - (52.76 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1008 - Home Base - (54.43 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R1010 - Movement - (9.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R1011 - Staff Room Annexe - (8.79 SQM)	Office (2)	
B00D - R1012 - Staff Room Annexe - (20.1 SQM)	Office (5)	
B00D - R1013 - Movement - (59.49 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (41.21 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Canteen - (47.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Movement - (51.58 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Special Programs Room - (47.09 SQM)	Student Space (21)	
B00F - R0009 - Special Programs Room - (32.77 SQM)	Student Space (15)	
B00F - R0011 - Practical Activities - 1hb - (46.94 SQM)	Student Space (21)	
B00F - R0012 - Movement - (13.53 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Communal Space - (68.49 SQM)	Student Space (31)	
B00F - R0016 - Movement - (18.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R1003 - Movement - (68.82 SQM)	Not Applicable	Circulation or storage space.
B00F - R1006 - Staff Room - (57.28 SQM)	Office (14)	
B00F - R1009 - Home Base/Practical Activities - (46.75 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R1010 - Home Base/Practical Activities - (48.44 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R1011 - Home Base/Practical Activities - (48.95 SQM) - Teaching Space: 1	Student Space (22)	
B00I - R0001 - Movement - (10.13 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Sick Bay - (11.37 SQM)	Student Space (5)	
B00I - R0009 - Clerical Office/Workroom - (13.23 SQM)	Office (3)	
B00I - R0010 - Home Base - (45.2 SQM) - Teaching Space: 1	Student Space (20)	
B00I - R0011 - Staff Room Annexe - (15.86 SQM)	Office (3)	
B00I - R0012 - Home Base - (62.18 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R0015 - Movement - (18.15 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Home Base - (45.01 SQM) - Teaching Space: 1	Student Space (20)	
B00I - R0018 - Home Base - (44.92 SQM) - Teaching Space: 1	Student Space (20)	
B00I - R0019 - Movement - (67.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R1001 - Movement - (17.25 SQM)	Not Applicable	Circulation or storage space.
B00I - R1002 - Home Base - (46.42 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R1003 - Home Base - (46.71 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R1004 - Staff Room - (16.19 SQM)	Office (4)	
B00I - R1005 - Home Base - (60.84 SQM) - Teaching Space: 1	Student Space (28)	
B00I - R1007 - Withdrawal Space - 1hb - (6.74 SQM)	Student Space (3)	
B00I - R1008 - Home Base - (46.28 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R1009 - Home Base - (46.39 SQM) - Teaching Space: 1	Student Space (21)	
B00I - R1010 - Movement - (77.78 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (41.08 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Communal Space - (214.78 SQM)	Student Space (99)	
B00K - R0002 - Raised Platform - (46.7 SQM)	Not Applicable	Circulation or storage space.
B00K - R0003 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Movement - (11.95 SQM)	Not Applicable	Circulation or storage space.