


VENTILATION AUDIT REPORT

SCHOOL:	Liverpool Boys High School (8186)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool

8186 - Liverpool Boys High School
Site Plan (11177)



1:1,640

Printed: 30-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Study - (26.54 SQM)	Office (6)	
B00A - R0005 - General Learning Space - (49.85 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0006 - General Learning Space - (49.88 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0007 - General Learning Space - (49.85 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0008 - General Learning Space - (49.92 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0009 - General Learning Space - (49.79 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0010 - General Learning Space - (49.71 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0012 - Movement - (157.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Leading Teacher - (13.28 SQM)	Office (3)	
B00A - R0022 - Isolation Space - (12.17 SQM)	Office (3)	
B00A - R0025 - Movement - (18.31 SQM)	Not Applicable	Circulation or storage space.
B00A - R0027 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (49.25 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Student Waiting - (19.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Deputy Principal Office - (15.46 SQM)	Office (3)	
B00A - R0041 - Deputy Principal Office - (15.94 SQM)	Office (3)	
B00A - R0043 - Movement - (7.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0046 - Staff Kitchen - (9.87 SQM)	Office (2)	
B00A - R0047 - Commonroom - (84.75 SQM)	Office (21)	
B00A - R0051 - Movement - (7.91 SQM)	Not Applicable	Circulation or storage space.
B00A - R0052 - Interview/Meeting - (9.94 SQM)	Office (2)	
B00A - R0053 - Public Reception - (21.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Administration - Clerical - (47.34 SQM)	Office (11)	
B00A - R0056 - Student Waiting - (46.65 SQM)	Not Applicable	Circulation or storage space.
B00A - R0057 - Principal Office - (19.34 SQM)	Office (4)	
B00A - R1002 - Leading Teacher - (26.56 SQM)	Office (6)	
B00A - R1005 - Staff Study - (52.27 SQM)	Office (13)	
B00A - R1006 - General Learning Space - (52.19 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1007 - General Learning Space - (52.18 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1008 - General Learning Space - (52.13 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1009 - General Learning Space - (52.27 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - General Learning Space - (52.26 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1012 - Interview/Office - Type 1 - (13.86 SQM)	Office (3)	
B00A - R1013 - Laboratory L.S. - (103.16 SQM) - Teaching Space: 1	Student Space (47)	
B00A - R1014 - Preparation - Science - (33.16 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Laboratory L.S. - (101.87 SQM) - Teaching Space: 1	Student Space (47)	
B00A - R1019 - Computer Learning Space - (66.77 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1024 - Movement - (163.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - Movement - (26.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R1026 - Movement - (79.78 SQM)	Not Applicable	Circulation or storage space.
B00A - R1027 - Staff Study - (32.09 SQM)	Office (8)	
B00A - R1029 - Movement - (16.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R9003 - Art Learning Space - (106.42 SQM) - Teaching Space: 1	Student Space (49)	
B00A - R9004 - Art Learning Space - (107.36 SQM) - Teaching Space: 1	Student Space (49)	
B00A - R9010 - Interview/Office - Type 1 - (21.46 SQM)	Office (5)	
B00B - R0003 - Laboratory L.S. - (92.87 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0004 - Preparation - Science - (28.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (7.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0017 - Laboratory L.S. - (92.85 SQM) - Teaching Space: 1	Student Space (43)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R0020 - Laboratory L.S. - (92.98 SQM) - Teaching Space: 1	● Student Space (43)	
B00B - R0027 - Movement - (11.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Movement - (11.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Movement - (11.57 SQM)	Not Applicable	Circulation or storage space.
B00B - R0033 - Preparation - Science - (39.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0034 - Staff Study - (12.96 SQM)	○ Office (3)	
B00B - R0035 - Tea Room - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Movement - (22.45 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1003 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1006 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1007 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1008 - General Learning Space - (52.25 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1015 - Computer Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1016 - Staff Study - (26.18 SQM)	○ Office (6)	
B00B - R1018 - Staff Study - (26.07 SQM)	○ Office (6)	
B00B - R1020 - Interview/Office - Type 1 - (12.78 SQM)	○ Office (3)	
B00B - R1022 - Clinic - Boys - (5.88 SQM)	○ Office (1)	
B00B - R1023 - Administration - Clerical - (16.82 SQM)	○ Office (4)	
B00B - R1024 - Leading Teacher - (8.56 SQM)	○ Office (2)	
B00B - R1030 - Staff Study - (62.54 SQM)	○ Office (15)	
B00B - R1033 - Student Waiting - (14.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Staff Study - (38.61 SQM)	○ Office (9)	
B00C - R0025 - General Assistants - (64.97 SQM)	○ Office (16)	
B00C - R0027 - Staff Study - (19.27 SQM)	○ Office (4)	
B00C - R0030 - Staff Study - (35.16 SQM)	○ Office (8)	
B00C - R0034 - Fitness Laboratory - (83.87 SQM)	● Student Space (38)	
B00C - R0035 - Dark Room - (7.82 SQM)	○ Office (1)	
B00C - R0038 - Movement - (199.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0040 - Food Technology L.S. - (105.54 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R0044 - Art Learning Space - (48.83 SQM) - Teaching Space: 1	● Student Space (22)	
B00C - R0046 - Dark Room - (8.84 SQM)	○ Office (2)	
B00C - R0050 - Student Canteen - (96.71 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Computer Room - (10.38 SQM)	● Student Space (4)	
B00C - R1006 - Design L.S. - (82 SQM) - Teaching Space: 1	● Student Space (38)	
B00C - R1009 - Wood Technology L.S. - (110.66 SQM) - Teaching Space: 1	● Student Space (51)	
B00C - R1012 - Design L.S. - (53.58 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R1013 - Computer Learning Space - (57.18 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1023 - Tiered Learning Area - (60.64 SQM)	● Student Space (28)	
B00C - R1029 - Wood Technology L.S. - (104.8 SQM) - Teaching Space: 1	● Student Space (48)	
B00C - R1031 - Staff Study - (11.59 SQM)	○ Office (2)	
B00C - R1032 - Staff Study - (29.06 SQM)	○ Office (7)	
B00C - R1034 - Movement - (71.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R1035 - Metal Technology L.S. - (119.94 SQM) - Teaching Space: 1	● Student Space (55)	
B00C - R1036 - Welding Area - (19.16 SQM)	Not Applicable	Circulation or storage space.
B00C - R1038 - Movement - (82.89 SQM)	Not Applicable	Circulation or storage space.
B00C - R1040 - Wood Technology L.S. - (110 SQM) - Teaching Space: 1	● Student Space (51)	
B00D - R1001 - Movement - (135.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R1002 - Movement - (65.14 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0003 - Practice/Seminar - (11.83 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Practice/Seminar - (11.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Music Learning Space - (59.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0007 - Practice/Seminar - (26.25 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Music Learning Space - (77.08 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0006 - General Learning Space - (52.79 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0007 - General Learning Space - (159.52 SQM) - Teaching Space: 1	● Student Space (74)	
B00G - R0001 - General Learning Space - (63.54 SQM) - Teaching Space: 1	● Student Space (29)	
B00G - R0003 - General Learning Space - (52.07 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0009 - General Learning Space - (52.72 SQM) - Teaching Space: 1	● Student Space (24)	
B00I - R0001 - Movement - (131.21 SQM)	Not Applicable	Circulation or storage space.
B00I - R0017 - Study Space - (12.1 SQM)	Not Applicable	Circulation or storage space.
B00I - R0018 - Study Space - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00I - R0022 - Study Space - (10.61 SQM)	Not Applicable	Circulation or storage space.
B00I - R0023 - Main Area - (465.06 SQM)	Not Applicable	Circulation or storage space.
B00I - R0030 - Audio Visual Workroom - (37.83 SQM)	● Student Space (17)	
B00I - R0032 - Senior Study - (26.12 SQM)	● Office (6)	
B00I - R1001 - Staff Kitchen - (6.57 SQM)	● Office (1)	
B00I - R1002 - Movement - (39.65 SQM)	Not Applicable	Circulation or storage space.
B00I - R1003 - Multi-Purpose Space - (293.29 SQM)	● Student Space (136)	
B00I - R1004 - Stage - (78.36 SQM)	Not Applicable	Circulation or storage space.
B00I - R1005 - Movement - (19.61 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Computer Learning Space - (91.81 SQM) - Teaching Space: 1	● Student Space (42)	
B00K - R0002 - Seminar - Type 2 - (18.78 SQM)	● Office (4)	
B00L - R0001 - Performance Workspace - (122.47 SQM) - Teaching Space: 1	● Student Space (56)	
B00M - R0001 - Workshop - (264.81 SQM)	● Student Space (122)	
OS 710 13388 - OS 710 13388 - Home Science/Pantry/Laundry - (95 SQM)	● Office (23)	