

VENTILATION AUDIT REPORT

SCHOOL:	Liverpool Girls High School (8176)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Liverpool
LOCAL GOVERNMENT AREA:	Liverpool

8176 - Liverpool Girls High School
Site Plan (11177)






















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0002 - Materials Learning Space - Type 1 - (72.6 SQM) - Teaching Space: 1	● Student Space (33)	
B00J - R0010 - Computer Learning Space - (49.78 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R0011 - General Learning Space - (49.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R0012 - General Learning Space - (49.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R0013 - General Learning Space - (49.85 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R0014 - General Learning Space - (50.03 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R0015 - General Learning Space - (50.23 SQM) - Teaching Space: 1	● Student Space (23)	
B00J - R0021 - General Assistants - (25.21 SQM)	● Office (6)	
B00J - R0033 - Student Canteen - (60.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0042 - Movement - (29.34 SQM)	Not Applicable	Circulation or storage space.
B00J - R0044 - Movement - (123.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0050 - Wood Technology L.S. - (58.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0051 - Wood Technology Bay - (43.3 SQM)	Not Applicable	Circulation or storage space.
B00J - R0055 - Movement - (76.81 SQM)	Not Applicable	Circulation or storage space.
B00J - R0057 - Fitness Laboratory - (116.49 SQM)	● Student Space (54)	
B00J - R0069 - Staff Study - (23.47 SQM)	● Office (5)	
B00J - R0072 - Movement - (158.09 SQM)	Not Applicable	Circulation or storage space.
B00J - R0073 - Movement - (21.29 SQM)	Not Applicable	Circulation or storage space.
B00J - R0076 - Movement - (29.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R1002 - Principal Office - (21.32 SQM)	● Office (5)	
B00J - R1003 - Administration - Clerical - (12.81 SQM)	● Office (3)	
B00J - R1004 - Deputy Principal Office - (13.74 SQM)	● Office (3)	
B00J - R1005 - Ancillary Staff - (9.79 SQM)	● Office (2)	
B00J - R1007 - Deputy Principal Office - (18.4 SQM)	● Office (4)	
B00J - R1008 - Computer Learning Space - (42.35 SQM) - Teaching Space: 1	● Student Space (19)	
B00J - R1011 - Leading Teacher - (17.64 SQM)	● Office (4)	
B00J - R1013 - Seminar - (107.02 SQM)	● Office (26)	
B00J - R1014 - Movement - (219.5 SQM)	Not Applicable	Circulation or storage space.
B00J - R1015 - Staff Study - (20.23 SQM)	● Office (5)	
B00J - R1018 - Interview/Meeting - (21.02 SQM)	● Office (5)	
B00J - R1019 - Staff Study - (36.7 SQM)	● Office (9)	
B00J - R1022 - Preparation - Materials - (12.05 SQM)	Not Applicable	Circulation or storage space.
B00J - R1025 - Food Technology L.S. - (71.15 SQM) - Teaching Space: 1	● Student Space (33)	
B00J - R1026 - Food Technology L.S. - (73.19 SQM) - Teaching Space: 1	● Student Space (33)	
B00J - R1030 - General Learning Space - (52.56 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1031 - General Learning Space - (52.17 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1032 - General Learning Space - (52.32 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1033 - General Learning Space - (52.1 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1034 - General Learning Space - (52.69 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1035 - General Learning Space - (52.59 SQM) - Teaching Space: 1	● Student Space (24)	
B00J - R1039 - Administration - Clerical - (26.76 SQM)	● Office (6)	
B00J - R1047 - Administration - Clerical - (7.84 SQM)	● Office (1)	
B00J - R1049 - Clinic - Girls - (18.92 SQM)	● Office (4)	
B00J - R1050 - Movement - (9.17 SQM)	Not Applicable	Circulation or storage space.
B00J - R1051 - Food Technology L.S. - (74.64 SQM) - Teaching Space: 1	● Student Space (34)	
B00J - R1060 - Movement - (144.45 SQM)	Not Applicable	Circulation or storage space.
B00J - R1061 - Movement - (21.08 SQM)	Not Applicable	Circulation or storage space.
B00J - R1064 - Public Reception - (14.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R1065 - Administration - Clerical - (6.65 SQM)	● Office (1)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R1066 - Student Waiting - (62.69 SQM)	Not Applicable	Circulation or storage space.
B00J - R2004 - Textiles Technology L.S. - (72.44 SQM) - Teaching Space: 1	● Student Space (33)	
B00J - R2007 - Computer Learning Space - (54.84 SQM) - Teaching Space: 1	● Student Space (25)	
B00J - R2021 - Staff Study - (31.76 SQM)	○ Office (7)	
B00J - R2022 - Preparation - Science - (35.31 SQM)	Not Applicable	Circulation or storage space.
B00J - R2023 - Preparation - Science - (33.37 SQM)	Not Applicable	Circulation or storage space.
B00J - R2024 - Study Space - (11.62 SQM)	Not Applicable	Circulation or storage space.
B00J - R2025 - Study Space - (13.52 SQM)	Not Applicable	Circulation or storage space.
B00J - R2029 - Staff Study - (40.35 SQM)	○ Office (10)	
B00J - R2030 - Seminar - Type 1 - (14.08 SQM)	○ Office (3)	
B00J - R2031 - Staff Kitchen - (12.46 SQM)	○ Office (3)	
B00J - R2036 - Movement - (199.28 SQM)	Not Applicable	Circulation or storage space.
B00J - R2037 - Laboratory L.S. - (104.88 SQM) - Teaching Space: 1	● Student Space (48)	
B00J - R2038 - Laboratory L.S. - (100.89 SQM) - Teaching Space: 1	● Student Space (46)	
B00J - R2039 - Commonroom - (63.92 SQM)	○ Office (15)	
B00J - R2041 - Movement - (10.66 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Movement - (25.33 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Multi-Purpose Space - (285.99 SQM)	● Student Space (132)	
B00L - R0002 - Staff Study - (5.79 SQM)	○ Office (1)	
B00L - R0004 - General Learning Space - (53.31 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0007 - General Learning Space - (40.02 SQM) - Teaching Space: 1	● Student Space (18)	
B00L - R0008 - General Learning Space - (53.24 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R0009 - Student Waiting - (6.14 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Interview/Office - Type 1 - (11.06 SQM)	○ Office (2)	
B00L - R0012 - General Learning Space - (39.51 SQM) - Teaching Space: 1	● Student Space (18)	
B00L - R0013 - Staff Study - (40.09 SQM)	○ Office (10)	
B00L - R0018 - Movement - (78.86 SQM)	Not Applicable	Circulation or storage space.
B00L - R1004 - Staff Study - (32.93 SQM)	○ Office (8)	
B00L - R1006 - Art Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R1007 - Art Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R1008 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R1010 - General Learning Space - (51.92 SQM) - Teaching Space: 1	● Student Space (24)	
B00L - R1012 - Art Learning Space - (14.4 SQM) - Teaching Space: 1	● Student Space (6)	
B00L - R1016 - Movement - (59.14 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Laboratory L.S. - (92.93 SQM) - Teaching Space: 1	● Student Space (43)	
B00M - R0006 - Laboratory L.S. - (93.25 SQM) - Teaching Space: 1	● Student Space (43)	
B00M - R0008 - Staff Study - (39.3 SQM)	○ Office (9)	
B00M - R0014 - Laboratory L.S. - (93 SQM) - Teaching Space: 1	● Student Space (43)	
B00M - R0015 - Preparation - Science - (29.22 SQM)	Not Applicable	Circulation or storage space.
B00M - R0026 - Preparation - Science - (39.63 SQM)	Not Applicable	Circulation or storage space.
B00M - R0027 - Laboratory L.S. - (65.98 SQM) - Teaching Space: 1	● Student Space (30)	
B00M - R0028 - Art Learning Space - (59.83 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0030 - Dark Room - (19.7 SQM)	○ Office (4)	
B00M - R0031 - Movement - (11.78 SQM)	Not Applicable	Circulation or storage space.
B00M - R0033 - Movement - (11.56 SQM)	Not Applicable	Circulation or storage space.
B00M - R0036 - Movement - (11.46 SQM)	Not Applicable	Circulation or storage space.
B00M - R1004 - Music Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00M - R1007 - Performance Workshop - (52.44 SQM)	● Student Space (24)	
B00M - R1010 - Staff Lounge - (14.51 SQM)	○ Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R1012 - Staff Study - (16.86 SQM)	 Office (4)	
B00M - R1015 - Staff Study - (26.87 SQM)	 Office (6)	
B00M - R1019 - Computer Learning Space - (65.94 SQM) - Teaching Space: 1	 Student Space (30)	
B00M - R1020 - Staff Study - (26.07 SQM)	 Office (6)	
B00M - R1021 - General Learning Space - (52.51 SQM) - Teaching Space: 1	 Student Space (24)	
B00M - R1024 - General Learning Space - (66.2 SQM) - Teaching Space: 1	 Student Space (30)	
B00M - R1027 - Music Learning Space - (52.58 SQM) - Teaching Space: 1	 Student Space (24)	
B00M - R1035 - Movement Studio - (106.33 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Gymnasium - (621.02 SQM)	 Student Space (288)	
B00N - R0007 - Staff Study - (24.64 SQM)	 Office (6)	
B00O - R0001 - Computer Learning Space - (91.92 SQM) - Teaching Space: 1	 Student Space (42)	
B00O - R0002 - Seminar - Type 2 - (18.76 SQM)	 Office (4)	
OS 600 11768 - OS 600 11768 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 13824 - OS 600 13824 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 601 10085 - OS 601 10085 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11590 - OS 601 11590 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11720 - OS 601 11720 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 11767 - OS 601 11767 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12344 - OS 601 12344 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 750 17706 - OS 750 17706 - Learning Unit - ESL - (38 SQM)	 Student Space (17)	