

VENTILATION AUDIT REPORT

SCHOOL:	Llandilo Public School (2413)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Londonderry
LOCAL GOVERNMENT AREA:	Penrith

2413 - Llandilo Public School
Site Plan (10466)


















1:967

Printed: 24-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Withdrawal Space - 1hb - (7.16 SQM)	● Student Space (3)	
B00A - R0004 - Practical Activities - 1hb - (21.06 SQM)	● Student Space (9)	
B00A - R0005 - Home Base - (60.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0006 - Home Base - (60.36 SQM) - Teaching Space: 1	● Student Space (28)	
B00A - R0007 - Practical Activities - 1hb - (21.13 SQM)	● Student Space (9)	
B00A - R0010 - Withdrawal Space - 1hb - (10.5 SQM)	● Student Space (4)	
B00A - R0011 - Home Base - (60.14 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0012 - Practical Activities - 1hb - (21.08 SQM)	● Student Space (9)	
B00A - R0013 - Practical Activities - 1hb - (21.11 SQM)	● Student Space (9)	
B00A - R0014 - Home Base - (60.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0015 - Withdrawal Space - 1hb - (7.31 SQM)	● Student Space (3)	
B00A - R0021 - Movement - (89.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (20.8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (21.02 SQM)	● Student Space (9)	
B00B - R0002 - Home Base - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0003 - Withdrawal Space - 1hb - (9.91 SQM)	● Student Space (4)	
B00B - R0006 - Practical Activities - 1hb - (21 SQM)	● Student Space (9)	
B00B - R0007 - Home Base - (60.35 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0010 - Reading Area - (162.04 SQM)	● Student Space (75)	
B00B - R0013 - Special Programs Room - (32.77 SQM)	● Student Space (15)	
B00B - R0016 - Movement - (148.36 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Canteen - (38.34 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Movement - (26.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (55.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Staff Room Annexe - (22.17 SQM)	● Office (5)	
B00D - R0002 - Staff Room - (42.78 SQM)	● Office (10)	
B00D - R0004 - Movement - (27.09 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Principal - (18.53 SQM)	● Office (4)	
B00D - R0007 - Clerical Office - (17.07 SQM)	● Office (4)	
B00D - R0008 - Entry Vestibule - (16.85 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Interview - (12.73 SQM)	● Office (3)	
B00D - R0010 - Duplicating Workroom - (20.83 SQM)	● Office (5)	
B00D - R0011 - Deputy Principal - (12.39 SQM)	● Office (3)	
B00D - R0012 - Sick Bay - (9.16 SQM)	● Student Space (4)	
B00D - R0014 - Deputy Principal - (13 SQM)	● Office (3)	
B00D - R0018 - Movement - (68.06 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Movement - (8.15 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (6.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Communal Space - (144.14 SQM)	● Student Space (66)	
B00E - R0014 - Staff Room Annexe - (10.4 SQM)	● Office (2)	
B00E - R0016 - Movement - (22.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (10.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0020 - Movement - (6.92 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Raised Platform - (45.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Movement - (40.63 SQM)	Not Applicable	Circulation or storage space.
B00E - R0029 - Movement - (25.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0030 - Movement - (46.83 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Home Base - (53.66 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0004 - Staff Room Annexe - (11.06 SQM)	● Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0001 - Practical Activities - 1hb - (9.28 SQM)	 Student Space (4)	
B00H - R0002 - Home Base - (62.85 SQM) - Teaching Space: 1	 Student Space (29)	
B00H - R0007 - Movement - (21.32 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Movement - (74.39 SQM)	Not Applicable	Circulation or storage space.
B00J - R0012 - Practical Activities - 1hb - (16.13 SQM)	 Student Space (7)	
B00J - R0014 - Home Base - (83.21 SQM) - Teaching Space: 1	 Student Space (38)	
B00J - R0015 - Home Base - (52.89 SQM) - Teaching Space: 1	 Student Space (24)	
B00J - R0016 - Practical Activities - 1hb - (20.99 SQM)	 Student Space (9)	
B00J - R0017 - Movement - (40.2 SQM)	Not Applicable	Circulation or storage space.
B00J - R0018 - Movement - (53.42 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (18.73 SQM)	 Student Space (8)	
B00K - R0004 - Home Base - (59.82 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0005 - Withdrawal Space - 2hb - (11.34 SQM)	 Student Space (5)	
B00K - R0006 - Home Base - (59.82 SQM) - Teaching Space: 1	 Student Space (27)	
B00K - R0008 - Practical Activities - 1hb - (18.73 SQM)	 Student Space (8)	
B00K - R0009 - Special Programs Room - (33.33 SQM)	 Student Space (15)	
OS 602 10202 - OS 602 10202 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13118 - OS 602 13118 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 19203 - OS 606 19203 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	