


VENTILATION AUDIT REPORT

| | |
|-------------------------------|-------------------------------|
| SCHOOL: | Lomandra School (5753) |
| AMU REGION: | South Western Sydney |
| STATE ELECTORATE: | Campbelltown |
| LOCAL GOVERNMENT AREA: | Campbelltown |

5753 - Lomandra School
Site Plan (10218)



1:720

Printed: 07-Aug-2021

Ventilation Audit Key

| Category | Description |
|---|--|
|  | Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings. |
|  | Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces. |

| Entity Location | Audit Condition Classification (Capacity) | Comment |
|---|---|-------------------------------|
| B00A - R0001 - Special Programs Room - (28.66 SQM) | ● Student Space (13) | |
| B00A - R0002 - Home Base - (49.35 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00A - R0003 - Home Base - (48.11 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00A - R0004 - Home Base - (48.83 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00A - R0006 - Movement - (126.59 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0010 - Movement - (13.46 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0016 - Staff Study - (49.35 SQM) | ● Office (12) | |
| B00A - R0018 - Interview - (16.7 SQM) | ● Office (4) | |
| B00A - R0032 - Movement - (8.18 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0033 - Entry Vestibule - (21 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0034 - Interview - (15.42 SQM) | ● Office (3) | |
| B00A - R0035 - Clerical Office - (36.33 SQM) | ● Office (9) | |
| B00A - R0036 - Principal - (22.3 SQM) | ● Office (5) | |
| B00A - R0037 - Deputy Principal - (22.91 SQM) | ● Office (5) | |
| B00A - R0038 - Sick Bay - (12.21 SQM) | ● Student Space (5) | |
| B00A - R0041 - Staff Room - (47.01 SQM) | ● Office (11) | |
| B00A - R0042 - Staff Kitchen - (6.02 SQM) | ● Office (1) | |
| B00A - R0043 - Movement - (23.72 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0044 - Movement - (19.84 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R0046 - Practical Activities - (21.71 SQM) | ● Student Space (10) | |
| B00A - R0047 - Practical Activities - (25.64 SQM) | ● Student Space (11) | |
| B00A - R1006 - Visual Arts Workshop - (37.55 SQM) | ● Student Space (17) | |
| B00A - R1009 - Movement - (5.36 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1013 - Staff Study - (10.14 SQM) | ● Office (2) | |
| B00A - R1014 - Main Area - (35.29 SQM) | Not Applicable | Circulation or storage space. |
| B00A - R1015 - Home Base - (48.18 SQM) - Teaching Space: 1 | ● Student Space (22) | |
| B00A - R1021 - Movement - (34.05 SQM) | Not Applicable | Circulation or storage space. |
| NS 111 16254 - NS 111 16254 - Learning Unit - Double Secondary/Secure - (114 SQM) | ● Student Space (52) | |
| OS 601 14377 - OS 601 14377 - Learning Unit - Standard/Withdrawal - (76 SQM) | ● Student Space (35) | |