


VENTILATION AUDIT REPORT

SCHOOL:	Lowesdale Public School (2429)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Albury
LOCAL GOVERNMENT AREA:	Federation

2429 - Lowesdale Public School
Site Plan (12772)



1:997

Printed: 24-Dec-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (31.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Reading Area - (20.47 SQM)	● Student Space (9)	
B00A - R0005 - Movement - (10.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (6.79 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Kitchen - (12.9 SQM)	○ Office (3)	
B00A - R0008 - Movement - (7.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Withdrawal Space - 1hb - (15.36 SQM)	● Student Space (7)	
B00A - R0010 - Principal - (15.62 SQM)	○ Office (3)	
B00A - R0012 - Reading Area - (15.62 SQM)	● Student Space (7)	
B00D - R0001 - Withdrawal Space - 1hb - (11.45 SQM)	● Student Space (5)	
B00D - R0004 - Practical Activities - 1hb - (9.98 SQM)	● Student Space (4)	
B00D - R0005 - Staff Kitchen - (11.23 SQM)	○ Office (2)	
B00D - R0008 - Home Base - (93.34 SQM) - Teaching Space: 1	● Student Space (43)	
B00F - R0001 - Reading Area - (59.86 SQM)	● Student Space (27)	