


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Luddenham Public School (2431)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Camden</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Liverpool</b>

2431 - Luddenham Public School  
Site Plan (12773)



1:775

Printed: 12-Oct-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (16.17 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Home Base - (83.78 SQM) - Teaching Space: 1	● Student Space (38)	
B00A - R0013 - Staff Room Annexe - (11.04 SQM)	● Office (2)	
B00A - R0016 - Home Base - (51.35 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0017 - Practical Activities - 1hb - (20.15 SQM)	● Student Space (9)	
B00A - R0018 - Movement - (40.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Canteen - (20.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Reading Area - (55.7 SQM)	● Student Space (25)	
B00C - R0002 - Movement - (5.37 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Principal - (15.08 SQM)	● Office (3)	
B00H - R0005 - Staff Room - (25.39 SQM)	● Office (6)	
B00H - R0006 - Movement - (18.96 SQM)	Not Applicable	Circulation or storage space.
B00H - R0009 - Sick Bay - (7.22 SQM)	● Student Space (3)	
B00H - R0011 - Clerical Office - (17.19 SQM)	● Office (4)	
OS 601 14305 - OS 601 14305 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 10704 - OS 602 10704 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	