


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	Lurnea High School (8401)
<b>AMU REGION:</b>	South Western Sydney
<b>STATE ELECTORATE:</b>	Holsworthy
<b>LOCAL GOVERNMENT AREA:</b>	Liverpool

8401 - Lurnea High School  
Site Plan (11183)



1:1,586

Printed: 30-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Movement - (28.23 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Clinic - (8.35 SQM)	Office (2)	
B00A - R0007 - Staff Kitchen - (8.35 SQM)	Office (2)	
B00A - R0008 - Deputy Principal Office - (8.35 SQM)	Office (2)	
B00A - R0011 - Administration - Clerical - (10.83 SQM)	Office (2)	
B00A - R0013 - Principal Office - (19.93 SQM)	Office (4)	
B00A - R0019 - Art Learning Space - (91.09 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0023 - Public Reception - (58.46 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Deputy Principal Office - (13.18 SQM)	Office (3)	
B00A - R0025 - Deputy Principal Office - (12.96 SQM)	Office (3)	
B00A - R0028 - Tea Room - (9.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Staff Study - (16.34 SQM)	Office (4)	
B00A - R0031 - Dark Room - (30.27 SQM)	Office (7)	
B00A - R0032 - Art Learning Space - (56.91 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R1001 - General Learning Space - (53.53 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1002 - Commonroom - (72.91 SQM)	Office (18)	
B00A - R1003 - Staff Study - (12.68 SQM)	Office (3)	
B00A - R1004 - Staff Study - (13.03 SQM)	Office (3)	
B00A - R1005 - Staff Kitchen - (9.45 SQM)	Office (2)	
B00A - R1009 - Special Learning Space - (39.45 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1010 - Craft Room - (72.18 SQM)	Office (18)	
B00A - R1011 - Special Learning Space - (39.23 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1012 - Special Learning Space - (40.05 SQM) - Teaching Space: 1	Student Space (18)	
B00A - R1014 - General Learning Space - (59.09 SQM) - Teaching Space: 1	Student Space (27)	
B00A - R1015 - Tea Room - (12.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Staff Study - (39.4 SQM)	Office (9)	
B00A - R1017 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1022 - Interview/Office - Type 1 - (19.26 SQM)	Office (4)	
B00A - R1024 - General Learning Space - (55.2 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0001 - Senior Learning Centre - (90.22 SQM)	Student Space (41)	
B00B - R0005 - Food Technology L.S. - (71.71 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R0011 - Computer Learning Space - (53.53 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0025 - Food Technology L.S. - (84.11 SQM) - Teaching Space: 1	Student Space (39)	
B00B - R0026 - Food/Research Space - (21.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Preparation - Materials - (26.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R0029 - Tea Room - (7.13 SQM)	Not Applicable	Circulation or storage space.
B00B - R0030 - Staff Study - (24.76 SQM)	Office (6)	
B00B - R0031 - Materials Learning Space - Type 1 - (72.76 SQM) - Teaching Space: 1	Student Space (33)	
B00B - R1001 - Wood Technology L.S. - (79.49 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R1007 - Materials Technology L.S. - (67.49 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R1010 - Music Learning Space - (58.5 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1012 - Art Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1013 - Art Learning Space - (52.28 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1017 - Music Learning Space - (50.53 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1022 - Staff Study - (21.24 SQM)	Office (5)	
B00B - R1025 - Metal Technology L.S. - (85.97 SQM) - Teaching Space: 1	Student Space (39)	
B00C - R0002 - Movement - (318.14 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Student Canteen - (56.35 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0014 - Movement - (5.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0024 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R0027 - Movement - (8.75 SQM)	Not Applicable	Circulation or storage space.
B00C - R1007 - Movement - (8.91 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Movement - (8.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - General Learning Space - (65.06 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R0010 - Laboratory L.S. - (85.97 SQM) - Teaching Space: 1	● Student Space (39)	
B00D - R0014 - General Learning Space - (51.4 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0015 - Laboratory L.S. - (92.65 SQM) - Teaching Space: 1	● Student Space (42)	
B00D - R0016 - Preparation - Science - (29.01 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Laboratory L.S. - (93.05 SQM) - Teaching Space: 1	● Student Space (43)	
B00D - R1003 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1004 - General Learning Space - (58.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1006 - Computer Learning Space - (65.65 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1007 - Computer Learning Space - (58.67 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1008 - General Learning Space - (53.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1010 - General Learning Space - (58.75 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1011 - General Learning Space - (52.43 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1012 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1013 - General Learning Space - (59 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R1017 - Staff Study - (19.92 SQM)	○ Office (4)	
B00D - R1019 - Staff Study - (19.07 SQM)	○ Office (4)	
B00E - R0001 - Interview/Office - Type 1 - (15.61 SQM)	○ Office (3)	
B00E - R0002 - Tea Room - (11.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R0003 - Staff Study - (26.03 SQM)	○ Office (6)	
B00E - R0004 - Staff Study - (79.91 SQM)	○ Office (19)	
B00E - R0005 - Tea Room - (5.59 SQM)	Not Applicable	Circulation or storage space.
B00E - R0006 - Staff Study - (52.65 SQM)	○ Office (13)	
B00E - R0011 - Computer Learning Space - (32.25 SQM) - Teaching Space: 1	● Student Space (14)	
B00E - R0012 - General Learning Space - (52.94 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0015 - Laboratory L.S. - (92.72 SQM) - Teaching Space: 1	● Student Space (43)	
B00E - R0017 - Preparation - Science - (29.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0018 - Laboratory L.S. - (85.9 SQM) - Teaching Space: 1	● Student Space (39)	
B00E - R0021 - Main Entry - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00E - R0022 - Main Area - (291.78 SQM)	Not Applicable	Circulation or storage space.
B00E - R0023 - Seminar/Study - (13.25 SQM)	○ Office (3)	
B00E - R0024 - Seminar/Study - (13.14 SQM)	○ Office (3)	
B00E - R0025 - Staff Study - (13.43 SQM)	○ Office (3)	
B00E - R0027 - Audio Visual Workroom - (26.84 SQM)	● Student Space (12)	
B00E - R0035 - Tea Room - (5.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (53.82 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1002 - General Learning Space - (71.66 SQM) - Teaching Space: 1	● Student Space (33)	
B00E - R1006 - Staff Study - (5.01 SQM)	○ Office (1)	
B00E - R1010 - General Learning Space - (58.64 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1011 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1012 - General Learning Space - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1018 - General Learning Space - (59.23 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1019 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1020 - Staff Study - (20.98 SQM)	○ Office (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1022 - General Learning Space - (59.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R1023 - General Learning Space - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1024 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1028 - General Learning Space - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1029 - Performance Workshop - (25.96 SQM)	● Student Space (12)	
B00E - R1030 - Staff Study - (36.22 SQM)	● Office (9)	
B00G - R0007 - Staff Kitchen - (12 SQM)	● Office (3)	
B00G - R0011 - Gymnasium - (442.29 SQM)	● Student Space (205)	
B00G - R0021 - Stage - (86.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (18.16 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Main Area - (92.01 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Interview/Office - Type 2 - (21.05 SQM)	● Office (5)	
B00L - R0001 - General Learning Space - (69.31 SQM) - Teaching Space: 1	● Student Space (32)	
B00L - R0002 - Practical Activities - (15.11 SQM)	● Student Space (7)	
NS 110 10471 - NS 110 10471 - Learning Unit - Single Secondary/Secure - (57 SQM)	● Student Space (26)	
OS 501 14119 - OS 501 14119 - Admin Staff/Principal/Deputy/Dup/Clinic - (209 SQM)	● Office (52)	
OS 600 13532 - OS 600 13532 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 15942 - OS 600 15942 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 600 19844 - OS 600 19844 - Learning Unit - Small - ( SQM)	● Student Space ( )	
OS 601 11530 - OS 601 11530 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 12464 - OS 601 12464 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13482 - OS 601 13482 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13652 - OS 601 13652 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14287 - OS 601 14287 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14414 - OS 601 14414 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14499 - OS 601 14499 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14986 - OS 601 14986 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 16291 - OS 601 16291 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 751 13582 - OS 751 13582 - Learning Unit - ESL - (76 SQM)	● Student Space (35)	