

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Lynwood Park Public School (4258)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Blacktown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

4258 - Lynwood Park Public School  
Site Plan (12777)



1:963

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (58.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00A - R0004 - Movement - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Reading Area - (113.92 SQM)	● Student Space (52)	
B00A - R0012 - Movement - (16.02 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Interview - (15.64 SQM)	○ Office (3)	
B00A - R0017 - Home Base - (58.45 SQM) - Teaching Space: 1	● Student Space (27)	
B00B - R0001 - Staff Room - (57.9 SQM)	○ Office (14)	
B00B - R0004 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - Movement - (14.26 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Movement - (12.82 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Canteen - (30.65 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Staff Kitchen - (12.73 SQM)	○ Office (3)	
B00C - R0001 - Home Base - (56.4 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0004 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (6.39 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Home Base - (56.89 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0014 - Duplicating Workroom - (21.27 SQM)	○ Office (5)	
B00C - R0017 - Interview - (10.54 SQM)	○ Office (2)	
B00C - R0020 - Clerical Office/Workroom - (10.36 SQM)	○ Office (2)	
B00C - R0022 - Movement - (10.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0025 - Home Base - (56.48 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0026 - Home Base - (56.37 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0027 - Entry Vestibule - (11.3 SQM)	Not Applicable	Circulation or storage space.
B00C - R0028 - Movement - (8.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0029 - Clerical Office - (18.56 SQM)	○ Office (4)	
B00D - R0001 - Home Base - (56.85 SQM) - Teaching Space: 1	● Student Space (26)	
B00D - R0002 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Home Base - (56.78 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0001 - Home Base - (58.46 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0004 - Movement - (12.87 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Staff Room Annexe - (58.77 SQM)	○ Office (14)	
B00F - R0002 - Movement - (6.08 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Practical Activities - 1hb - (71.26 SQM)	● Student Space (33)	
B00F - R0007 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0010 - Deputy Principal - (15.45 SQM)	○ Office (3)	
B00F - R0011 - Movement - (15.91 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0016 - Home Base - (56.95 SQM) - Teaching Space: 1	● Student Space (26)	
B00F - R0019 - Movement - (6.31 SQM)	Not Applicable	Circulation or storage space.
B00F - R0020 - Staff Room Annexe - (20.52 SQM)	○ Office (5)	
B00G - R0001 - Home Base - (58.45 SQM) - Teaching Space: 1	● Student Space (27)	
B00G - R0005 - Movement - (6.44 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (56.79 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0001 - Communal Space - (147.21 SQM)	● Student Space (68)	
B00J - R0002 - Raised Platform - (60.08 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Movement - (6.51 SQM)	Not Applicable	Circulation or storage space.
B00J - R0005 - Movement - (11.96 SQM)	Not Applicable	Circulation or storage space.