

VENTILATION AUDIT REPORT

SCHOOL:	Macintyre High School (8490)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Northern Tablelands
LOCAL GOVERNMENT AREA:	Inverell

8490 - Macintyre High School
Site Plan (12023)











Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Interview/Office - Type 1 - (13.35 SQM)	Office (3)	
B00A - R0003 - Audio Visual Workroom - (98.47 SQM)	Student Space (45)	
B00A - R0004 - Interview - (13.42 SQM)	Office (3)	
B00A - R0010 - Commonroom - (117.99 SQM)	Office (29)	
B00A - R0011 - Staff Kitchen - (10.77 SQM)	Office (2)	
B00A - R0014 - Ancillary Staff - (26.12 SQM)	Office (6)	
B00A - R0016 - Deputy Principal Office - (22.51 SQM)	Office (5)	
B00A - R0020 - Movement - (154.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Administration - Clerical - (29.07 SQM)	Office (7)	
B00A - R0022 - Administration - Clerical - (27.63 SQM)	Office (6)	
B00A - R0023 - Principal Office - (22.15 SQM)	Office (5)	
B00A - R0030 - Movement - (46.94 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Interview/Office - Type 1 - (11.18 SQM)	Office (2)	
B00A - R0032 - Interview - (11.55 SQM)	Office (2)	
B00A - R0035 - Interview/Office - Type 1 - (12.24 SQM)	Office (3)	
B00A - R0036 - Interview - (12.28 SQM)	Office (3)	
B00A - R0037 - Movement - (53.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - General Learning Space - (64.93 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1002 - General Learning Space - (64.71 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1003 - General Learning Space - (53.77 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1010 - Clinic - Boys - (12.66 SQM)	Office (3)	
B00A - R1011 - Clinic - Girls - (16.68 SQM)	Office (4)	
B00A - R1013 - Staff Study - (16.73 SQM)	Office (4)	
B00A - R1014 - Interview/Office - Type 1 - (12.74 SQM)	Office (3)	
B00A - R1015 - Movement - (64.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R1016 - Staff Study - (31.09 SQM)	Office (7)	
B00A - R1017 - General Learning Space - (52.96 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1018 - General Learning Space - (53.03 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1019 - General Learning Space - (53.4 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R1020 - Movement - (75.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R1021 - General Learning Space - (53.7 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0003 - Senior Study - (25.97 SQM)	Office (6)	
B00B - R1010 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - General Learning Space - (94.06 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0004 - Staff Study - (32.82 SQM)	Office (8)	
B00C - R0005 - Computer Learning Space - (93.87 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0006 - Movement - (48.42 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - General Learning Space - (92.76 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R1004 - Staff Study - (32.86 SQM)	Office (8)	
B00C - R1006 - General Learning Space - (92.94 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R1007 - Movement - (29.44 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Movement - (92.61 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Laboratory L.S. - (93.95 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R0006 - Preparation - (36.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Laboratory L.S. - (93.68 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R1009 - Laboratory L.S. - (92.66 SQM) - Teaching Space: 1	Student Space (42)	
B00D - R1010 - Laboratory L.S. - (93.05 SQM) - Teaching Space: 1	Student Space (43)	
B00D - R1011 - Preparation - Science - (54.52 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0003 - General Learning Space - (52.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0005 - Staff Study - (24.23 SQM)	● Office (6)	
B00E - R0007 - General Learning Space - (52.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0008 - General Learning Space - (52.39 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R0014 - Movement - (45.55 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Movement - (20.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R1002 - General Learning Space - (51.3 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1004 - Staff Study - (25.36 SQM)	● Office (6)	
B00E - R1005 - Staff Study - (46.85 SQM)	● Office (11)	
B00E - R1008 - General Learning Space - (52.32 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1009 - General Learning Space - (51.59 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R1010 - Movement - (38.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Welding Area - (13.23 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Outdoor Workshop - (63.68 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Workshop Area - (185.12 SQM)	● Student Space (85)	
B00F - R1002 - Staff Study - (56.6 SQM)	● Office (14)	
B00F - R1006 - Design L.S. - (66.17 SQM) - Teaching Space: 1	● Student Space (30)	
B00F - R1007 - Metal Technology Bay - (23.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R1008 - Movement - (7.17 SQM)	Not Applicable	Circulation or storage space.
B00F - R1009 - Computer Learning Space - (66.62 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R0001 - Materials Technology L.S. - (170.72 SQM) - Teaching Space: 1	● Student Space (79)	
B00G - R0002 - Wood Technology Bay - (19.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Art Learning Space - (66.29 SQM) - Teaching Space: 1	● Student Space (30)	
B00G - R1002 - Food Technology L.S. - (94.24 SQM) - Teaching Space: 1	● Student Space (43)	
B00G - R1010 - General Learning Space - (48.27 SQM) - Teaching Space: 1	● Student Space (22)	
B00G - R1011 - Kitchen - Type 1 - (95.49 SQM)	● Student Space (44)	
B00G - R1012 - Preparation - (18.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Staff Study - (11.28 SQM)	● Office (2)	
B00H - R0004 - Art Learning Space - (60.82 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R0006 - Art Learning Space - (62.43 SQM) - Teaching Space: 1	● Student Space (28)	
B00H - R1008 - Movement - (5.2 SQM)	Not Applicable	Circulation or storage space.
B00H - R1010 - Staff Study - (13.59 SQM)	● Office (3)	
B00H - R1011 - Music Learning Space - (155.16 SQM) - Teaching Space: 1	● Student Space (71)	
B00J - R0001 - Student Canteen - (59.46 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Staff Study - (11.3 SQM)	● Office (2)	
B00J - R0009 - Movement - (28.14 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Performance Workspace - (101.59 SQM) - Teaching Space: 1	● Student Space (47)	
B00J - R0017 - Multi-Purpose Space - (459.94 SQM)	● Student Space (213)	
B00J - R0018 - Movement - (327.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - General Assistants - (33.07 SQM)	● Office (8)	
B00J - R1004 - Staff Study - (11.4 SQM)	● Office (2)	
B00J - R1008 - Movement - (19.76 SQM)	Not Applicable	Circulation or storage space.
B00J - R1014 - General Learning Space - (42.99 SQM) - Teaching Space: 1	● Student Space (19)	
B00J - R1017 - Gymnasium - (32.6 SQM)	● Student Space (15)	
B00J - R1018 - General Learning Space - (30.58 SQM) - Teaching Space: 1	● Student Space (14)	
B00J - R1020 - Movement - (252.54 SQM)	Not Applicable	Circulation or storage space.
B00J - R1021 - Staff Kitchen - (5.36 SQM)	● Office (1)	
B00J - R1023 - Movement - (5.17 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R1025 - General Learning Space - (69.12 SQM) - Teaching Space: 1	 Student Space (32)	
B00J - R1026 - General Learning Space - (67.11 SQM) - Teaching Space: 1	 Student Space (31)	
B00L - R0001 - Seminar - (13.98 SQM)	 Office (3)	
B00L - R0002 - Seminar - (13.49 SQM)	 Office (3)	
B00L - R0003 - Seminar - (14.28 SQM)	 Office (3)	
B00L - R0004 - Audio Visual Workroom - (24.13 SQM)	 Student Space (11)	
B00L - R0005 - Workroom - (21.26 SQM)	 Office (5)	
B00L - R0007 - Movement - (18.27 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Main Area - (279.04 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - General Learning Space - (42.09 SQM) - Teaching Space: 1	 Student Space (19)	