

VENTILATION AUDIT REPORT

SCHOOL:	Macksville Public School (2444)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Nambucca

2444 - Macksville Public School
Site Plan (11795)



1:1,005

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0003 - Movement - (26.92 SQM)	Not Applicable	Circulation or storage space.
B002 - R0004 - Movement - (15.74 SQM)	Not Applicable	Circulation or storage space.
B002 - R0005 - Movement - (6.16 SQM)	Not Applicable	Circulation or storage space.
B002 - R0006 - Movement - (6.69 SQM)	Not Applicable	Circulation or storage space.
B002 - R0007 - Home Base - (47.41 SQM) - Teaching Space: 1	● Student Space (21)	
B002 - R0008 - Withdrawal Space - 1hb - (12.09 SQM)	● Student Space (5)	
B002 - R0009 - Special Programs Room - (46.78 SQM)	● Student Space (21)	
B002 - R0010 - Withdrawal Space - 1hb - (11.39 SQM)	● Student Space (5)	
B003 - R0009 - Home Base - (54.45 SQM) - Teaching Space: 1	● Student Space (25)	
B003 - R0010 - Practical Activities - 1hb - (11.99 SQM)	● Student Space (5)	
B003 - R0011 - Withdrawal Space - 2hb - (9.19 SQM)	● Student Space (4)	
B003 - R0012 - Home Base - (47.65 SQM) - Teaching Space: 1	● Student Space (22)	
B003 - R0013 - Practical Activities - 1hb - (7.36 SQM)	● Student Space (3)	
B003 - R0015 - Special Programs Room - (44.09 SQM)	● Student Space (20)	
B004 - R0003 - Interview - (8.82 SQM)	● Office (2)	
B004 - R0004 - Interview - (13.2 SQM)	● Office (3)	
B004 - R0005 - Home Base - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B004 - R0006 - Home Base - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B004 - R0007 - Home Base - (52.29 SQM) - Teaching Space: 1	● Student Space (24)	
B004 - R0008 - Home Base - (55.57 SQM) - Teaching Space: 1	● Student Space (25)	
B004 - R0011 - Movement - (77.75 SQM)	Not Applicable	Circulation or storage space.
B005 - R0013 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B005 - R0016 - Staff Room - (50.62 SQM)	● Office (12)	
B005 - R0018 - Staff Room Annexe - (11.04 SQM)	● Office (2)	
B005 - R0019 - Interview - (10.48 SQM)	● Office (2)	
B005 - R0020 - Principal - (16.03 SQM)	● Office (4)	
B005 - R0022 - Interview - (9.16 SQM)	● Office (2)	
B005 - R0023 - Deputy Principal - Type 1 - (14.63 SQM)	● Office (3)	
B005 - R0025 - Clerical Office - (17.64 SQM)	● Office (4)	
B005 - R0028 - Sick Bay - (11.52 SQM)	● Student Space (5)	
B005 - R0029 - Clerical/Printing - (10.46 SQM)	Not Applicable	Circulation or storage space.
B005 - R0030 - Movement - (7.81 SQM)	Not Applicable	Circulation or storage space.
B005 - R0032 - Movement - (24.56 SQM)	Not Applicable	Circulation or storage space.
B005 - R0033 - Movement - (18.01 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Communal Space - (146.47 SQM)	● Student Space (67)	
B006 - R0002 - Raised Platform - (61.65 SQM)	Not Applicable	Circulation or storage space.
B006 - R0016 - Movement - (6.54 SQM)	Not Applicable	Circulation or storage space.
B006 - R0017 - Movement - (10.65 SQM)	Not Applicable	Circulation or storage space.
B006 - R0018 - Canteen - (26.51 SQM)	Not Applicable	Circulation or storage space.
B006 - R0020 - Movement - (11.6 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - Reading Area - (158.5 SQM)	● Student Space (73)	
B008 - R0002 - Movement - (65.99 SQM)	Not Applicable	Circulation or storage space.
B008 - R9001 - Movement - (22.89 SQM)	Not Applicable	Circulation or storage space.
B008 - R9005 - Movement - (13.92 SQM)	Not Applicable	Circulation or storage space.
B013 - R0003 - Canteen - (30.07 SQM)	Not Applicable	Circulation or storage space.
B013 - R0004 - Movement - (18.71 SQM)	Not Applicable	Circulation or storage space.
B013 - R0005 - Practical Activities - 1hb - (11.91 SQM)	● Student Space (5)	
B013 - R0006 - Deputy Principal - (11.18 SQM)	● Office (2)	
B013 - R0007 - Movement - (20.63 SQM)	Not Applicable	Circulation or storage space.
B013 - R0008 - Movement - (41.9 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B013 - R0009 - Clerical Office - (13.53 SQM)	Office (3)	
B013 - R0010 - Practical Activities - E - (25.59 SQM)	Student Space (11)	
B013 - R0011 - Movement - (7.26 SQM)	Not Applicable	Circulation or storage space.
B013 - R0012 - Raised Platform - (39.9 SQM)	Not Applicable	Circulation or storage space.
B013 - R0013 - Communal Space - (123.76 SQM)	Student Space (57)	
B015 - R0001 - Movement - (9.41 SQM)	Not Applicable	Circulation or storage space.
B015 - R0002 - Home Base - (59.49 SQM) - Teaching Space: 1	Student Space (27)	
B015 - R0004 - Movement - (89.63 SQM)	Not Applicable	Circulation or storage space.
B015 - R0008 - Practical Activities - 1hb - (12.95 SQM)	Student Space (6)	
B015 - R0010 - Home Base - (58.78 SQM) - Teaching Space: 1	Student Space (27)	
B015 - R0011 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B015 - R0012 - Movement - (9.41 SQM)	Not Applicable	Circulation or storage space.
B015 - R0013 - Withdrawal Space - 1hb - (10.92 SQM)	Student Space (5)	
B015 - R0014 - Movement - (9.41 SQM)	Not Applicable	Circulation or storage space.
B015 - R0015 - Home Base - (59.49 SQM) - Teaching Space: 1	Student Space (27)	
B015 - R0016 - Movement - (9.41 SQM)	Not Applicable	Circulation or storage space.
B015 - R0017 - Withdrawal Space - 1hb - (10.92 SQM)	Student Space (5)	
B015 - R0023 - Movement - (43.38 SQM)	Not Applicable	Circulation or storage space.
B015 - R0024 - Practical Activities - 1hb - (9.56 SQM)	Student Space (4)	
OS 602 12589 - OS 602 12589 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13399 - OS 602 13399 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 13705 - OS 603 13705 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	