




VENTILATION AUDIT REPORT

SCHOOL:	Maclean High School (8362)
AMU REGION:	North Coast
STATE ELECTORATE:	Clarence
LOCAL GOVERNMENT AREA:	Clarence Valley









Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0011 - Movement - (84.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Teachers Aides - (18.63 SQM)	Office (4)	
B00A - R0013 - Duplicating Workroom - (25.83 SQM)	Office (6)	
B00A - R0014 - Interview/Office - Type 1 - (14.48 SQM)	Office (3)	
B00A - R0017 - Clinic - Boys - (12.33 SQM)	Office (3)	
B00A - R0018 - Clinic - Girls - (12.88 SQM)	Office (3)	
B00A - R0021 - Clinic-Waiting - (8.26 SQM)	Office (2)	
B00A - R0023 - Special Learning Space - (44.73 SQM) - Teaching Space: 1	Student Space (20)	
B00A - R0024 - Commonroom - (106.8 SQM)	Office (26)	
B00A - R0029 - Movement - (5.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (15.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Administration - Clerical - (9.39 SQM)	Office (2)	
B00A - R0036 - Interview/Meeting - (12.75 SQM)	Office (3)	
B00A - R0037 - Public Reception - (19.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0038 - Administration - Clerical - (55.58 SQM)	Office (13)	
B00A - R0039 - Movement - (30.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0040 - Deputy Principal Office - (20.26 SQM)	Office (5)	
B00A - R0041 - Principal Office - (14.14 SQM)	Office (3)	
B00A - R0042 - Student Waiting - (5.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0044 - Pupil Entry - (17.47 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Senior Study - (14.66 SQM)	Office (3)	
B00A - R1002 - Staff Study - (46.97 SQM)	Office (11)	
B00A - R1003 - General Learning Space - (50.41 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1004 - General Learning Space - (50.2 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1005 - General Learning Space - (50.07 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1006 - General Learning Space - (62.54 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1008 - Study Space - (24.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - General Learning Space - (49.65 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1010 - General Learning Space - (50.46 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R1012 - Movement - (112.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Movement - (85.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Commonroom - (45.74 SQM)	Office (11)	
B00B - R0015 - Interview/Office - Type 1 - (9.39 SQM)	Office (2)	
B00B - R0016 - Senior Seminar - (9.55 SQM)	Office (2)	
B00B - R0017 - Senior Study - (45.16 SQM)	Office (11)	
B00B - R0018 - Senior Seminar - (9.36 SQM)	Office (2)	
B00B - R0021 - General Learning Space - (51.6 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0022 - General Learning Space - (51.67 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0025 - General Learning Space - (51.24 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1001 - General Learning Space - (50.14 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1002 - General Learning Space - (50.06 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1003 - General Learning Space - (50.14 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1004 - General Learning Space - (62.85 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R1006 - General Learning Space - (50.07 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1007 - Staff Study - (26.66 SQM)	Office (6)	
B00B - R1009 - Movement - (78.14 SQM)	Not Applicable	Circulation or storage space.
B00B - R9001 - Darkroom Space - (37.05 SQM)	Office (9)	
B00B - R9002 - Darkroom Space - (11.84 SQM)	Office (2)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R9008 - Movement - (38.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R9010 - Darkroom Space - (26.86 SQM)	Office (6)	
B00C - R0013 - Staff Study - (65.18 SQM)	Office (16)	
B00C - R0017 - Movement - (71.04 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - General Learning Space - (50.67 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0019 - Study Space - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0020 - Study Space - (12.35 SQM)	Not Applicable	Circulation or storage space.
B00C - R0021 - General Learning Space - (51.17 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0024 - General Learning Space - (50.96 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0025 - General Learning Space - (51.02 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0026 - Computer Learning Space - (65.19 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R9005 - Movement - (223.63 SQM)	Not Applicable	Circulation or storage space.
B00C - R9006 - Student Canteen - (60.08 SQM)	Not Applicable	Circulation or storage space.
B00C - R9011 - Movement - (94.97 SQM)	Not Applicable	Circulation or storage space.
B00C - R9013 - Practical Activity Area - (18 SQM)	Student Space (8)	
B00C - R9014 - General Learning Space - S/P - (46.51 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0001 - Staff Study - (34.82 SQM)	Office (8)	
B00D - R0002 - Art Learning Space - (64.49 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0003 - Art Learning Space - (51.74 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R0006 - Art Learning Space - (51.38 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0009 - Workshop - (16.99 SQM)	Student Space (7)	
B00D - R0012 - Art Learning Space - (79.44 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R0013 - Movement - (67.48 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (108.38 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Interview/Office - Type 1 - (16.94 SQM)	Office (4)	
B00D - R1002 - Staff Study - (25.62 SQM)	Office (6)	
B00D - R1004 - General Learning Space - (51.38 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R1007 - Music Learning Space - (100.1 SQM) - Teaching Space: 1	Student Space (46)	
B00D - R1008 - Music Learning Space - (51.75 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1010 - Movement - (79.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - Practice/Seminar - (14.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R1014 - Practice/Seminar - (13.69 SQM)	Not Applicable	Circulation or storage space.
B00D - R1017 - Movement - (6.93 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Laboratory L.S. - (92.29 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0006 - General Learning Space - (59.05 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R0007 - Laboratory L.S. - (92.29 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R0008 - Preparation - (40.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (154.61 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Laboratory L.S. - (92.29 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R1002 - Laboratory L.S. - (92.29 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R1003 - Preparation - (39.69 SQM)	Not Applicable	Circulation or storage space.
B00E - R1007 - Staff Study - (58.89 SQM)	Office (14)	
B00E - R1008 - Movement - (142.52 SQM)	Not Applicable	Circulation or storage space.
B00E - R2001 - Serviced Learning Space - (58.52 SQM) - Teaching Space: 1	Student Space (27)	
B00E - R2002 - Laboratory L.S. - (92.29 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R2003 - Laboratory L.S. - (92.29 SQM) - Teaching Space: 1	Student Space (42)	
B00E - R2004 - Serviced Learning Space - (50.73 SQM) - Teaching Space: 1	Student Space (23)	
B00E - R2005 - Preparation - (32.12 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R2007 - Movement - (142.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R9005 - Movement - (31.87 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Multi-Purpose Space - (459.07 SQM)	● Student Space (212)	
B00F - R0008 - Staff Study - (16.04 SQM)	● Office (4)	
B00H - R0005 - Movement - (26.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (10.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (11.66 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Multi-Purpose Space - (169.99 SQM)	● Student Space (78)	
B00H - R0012 - Stage - (5.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R0014 - Stage - (5.79 SQM)	Not Applicable	Circulation or storage space.
B00H - R0015 - Stage - (31.71 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Movement - (30.8 SQM)	Not Applicable	Circulation or storage space.
B00H - R9006 - Movement - (8.66 SQM)	Not Applicable	Circulation or storage space.
B00H - R9007 - Movement - (8.62 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Seminar - (22.51 SQM)	● Office (5)	
B00L - R0005 - Seminar - (17.31 SQM)	● Office (4)	
B00L - R0006 - Seminar - (17.14 SQM)	● Office (4)	
B00L - R0007 - Audio Visual Workroom - (34.8 SQM)	● Student Space (16)	
B00L - R0008 - Workroom - (58.45 SQM)	● Office (14)	
B00L - R0010 - Main Area - (510.37 SQM)	Not Applicable	Circulation or storage space.
B00L - R0011 - Entry - (18.11 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Movement - (73.49 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Movement - (26.23 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Study Space - (11.32 SQM)	Not Applicable	Circulation or storage space.
B00L - R1003 - General Learning Space - (49.34 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1004 - Staff Study - (13.32 SQM)	● Office (3)	
B00L - R1005 - Staff Study - (16.29 SQM)	● Office (4)	
B00L - R1006 - General Learning Space - (49.14 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1009 - General Learning Space - (48.7 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1010 - General Learning Space - (48.23 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1012 - General Learning Space - (48.31 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1013 - General Learning Space - (49.34 SQM) - Teaching Space: 1	● Student Space (22)	
B00L - R1014 - Movement - (67.77 SQM)	Not Applicable	Circulation or storage space.
B00L - R1015 - Movement - (8.21 SQM)	Not Applicable	Circulation or storage space.
B00L - R1016 - Movement - (7.68 SQM)	Not Applicable	Circulation or storage space.
B00L - R9006 - Movement - (302.76 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement - (175.19 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Materials Technology L.S. - (92.15 SQM) - Teaching Space: 1	● Student Space (42)	
B00M - R0006 - Welding Area - (12.87 SQM)	Not Applicable	Circulation or storage space.
B00M - R0008 - Metal Technology Bay - (33.45 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Wood Technology Bay - (8.72 SQM)	Not Applicable	Circulation or storage space.
B00M - R0013 - Materials Technology L.S. - (246.75 SQM) - Teaching Space: 1	● Student Space (114)	
B00M - R0014 - Wood Technology Bay - (38.5 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Staff Study - (37.16 SQM)	● Office (9)	
B00M - R0019 - Design/Technology L.S. - (74.69 SQM) - Teaching Space: 1	● Student Space (34)	
B00M - R0020 - Seminar/Technology Space - (18.21 SQM)	● Office (4)	
B00M - R0022 - Design L.S. - (74.68 SQM) - Teaching Space: 1	● Student Space (34)	
B00M - R0024 - Seminar/Technology Space - (18.06 SQM)	● Office (4)	
B00M - R0025 - Design L.S. - (74.97 SQM) - Teaching Space: 1	● Student Space (34)	
B00M - R9001 - Movement - (43.76 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R9002 - Movement - (122.76 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Design/Technology L.S. - (99.06 SQM) - Teaching Space: 1	 Student Space (45)	
B00N - R0003 - Movement - (31.87 SQM)	Not Applicable	Circulation or storage space.
B00N - R0008 - Seminar/Technology Space - (38.62 SQM)	 Office (9)	
B00N - R0009 - Food Technology L.S. - (74.2 SQM) - Teaching Space: 1	 Student Space (34)	
B00N - R0012 - Food Technology L.S. - (73.71 SQM) - Teaching Space: 1	 Student Space (34)	
B00N - R0013 - Movement - (38.8 SQM)	Not Applicable	Circulation or storage space.
B00O - R0006 - Movement - (14.91 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Outdoor Workshop - (64.31 SQM)	Not Applicable	Circulation or storage space.
B00P - R0003 - Workshop Area - (189.72 SQM)	 Student Space (88)	
B00P - R0004 - General Learning Space - (47.65 SQM) - Teaching Space: 1	 Student Space (22)	