

VENTILATION AUDIT REPORT

SCHOOL:	Macquarie Fields High School (8553)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown

8553 - Macquarie Fields High School
Site Plan (10469)



1:2,324

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal Office - (14.4 SQM)	Office (3)	
B00A - R0002 - Ancillary Staff - (12.16 SQM)	Office (3)	
B00A - R0005 - Clinic - (12.17 SQM)	Office (3)	
B00A - R0007 - Administration - Clerical - (12.15 SQM)	Office (3)	
B00A - R0008 - Administration - Executive - (11.83 SQM)	Office (2)	
B00A - R0009 - Movement - (63.88 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal Office - (18.41 SQM)	Office (4)	
B00A - R0016 - Administration - Clerical - (34.33 SQM)	Office (8)	
B00A - R0020 - Interview/Meeting - (17.49 SQM)	Office (4)	
B00A - R0022 - Leading Teacher - (18.19 SQM)	Office (4)	
B00B - R0005 - Food Technology L.S. - (103.1 SQM) - Teaching Space: 1	Student Space (47)	
B00B - R0007 - Preparation - Materials - (18.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Movement - (39.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Textiles Technology L.S. - (68.26 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R0013 - Performance Workshop - (68.44 SQM)	Student Space (31)	
B00B - R0014 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Food Technology L.S. - (103.24 SQM) - Teaching Space: 1	Student Space (47)	
B00B - R0018 - Staff Study - (22.96 SQM)	Office (5)	
B00C - R0002 - Laboratory L.S. - (79.03 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0003 - Preparation - Science - (31.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Laboratory L.S. - (78.85 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0007 - Interview/Meeting - (11.82 SQM)	Office (2)	
B00C - R0008 - Laboratory L.S. - (78.94 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0009 - Preparation - Science - (31.12 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Laboratory L.S. - (79.03 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0012 - Laboratory L.S. - (79.03 SQM) - Teaching Space: 1	Student Space (36)	
B00C - R0016 - Movement - (119.66 SQM)	Not Applicable	Circulation or storage space.
B00C - R0018 - Staff Study - (35.97 SQM)	Office (8)	
B00D - R0001 - General Learning Space - (47.2 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0002 - General Learning Space - (36.46 SQM) - Teaching Space: 1	Student Space (16)	
B00D - R0004 - General Learning Space - (47 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0005 - General Learning Space - (47.06 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0012 - General Learning Space - (47.2 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R0015 - Study Space - (14.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0017 - Movement - (9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Staff Study - (34.8 SQM)	Office (8)	
B00D - R0022 - Movement - (158.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Interview/Office - Type 1 - (12.43 SQM)	Office (3)	
B00D - R1002 - General Learning Space - (47.06 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1003 - General Learning Space - (36.46 SQM) - Teaching Space: 1	Student Space (16)	
B00D - R1004 - General Learning Space - (36.52 SQM) - Teaching Space: 1	Student Space (16)	
B00D - R1005 - General Learning Space - (47.12 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1006 - General Learning Space - (47.04 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1007 - Study Space - (14.27 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Study Space - (12.25 SQM)	Not Applicable	Circulation or storage space.
B00D - R1013 - General Learning Space - (47.12 SQM) - Teaching Space: 1	Student Space (21)	
B00D - R1017 - Staff Study - (35.01 SQM)	Office (8)	
B00D - R1019 - Movement - (145.06 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R0006 - General Learning Space - (46.42 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0007 - General Learning Space - (46.92 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0008 - General Learning Space - (36.46 SQM) - Teaching Space: 1	Student Space (16)	
B00E - R0009 - General Learning Space - (36.34 SQM) - Teaching Space: 1	Student Space (16)	
B00E - R0010 - General Learning Space - (47 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0011 - General Learning Space - (46.34 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0014 - Movement - (98.85 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Staff Study - (38 SQM)	Office (9)	
B00F - R0002 - Computer Learning Space - (47.2 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0007 - General Learning Space - (47.06 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0008 - General Learning Space - (47.06 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0009 - General Learning Space - (36.58 SQM) - Teaching Space: 1	Student Space (16)	
B00F - R0010 - General Learning Space - (36.46 SQM) - Teaching Space: 1	Student Space (16)	
B00F - R0011 - General Learning Space - (46.92 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0012 - Interview/Office - Type 1 - (14.27 SQM)	Office (3)	
B00F - R0013 - Senior Seminar - (14.27 SQM)	Office (3)	
B00F - R0014 - Interview/Office - Type 1 - (12.21 SQM)	Office (3)	
B00F - R0016 - Staff Study - (35.29 SQM)	Office (8)	
B00F - R0018 - Movement - (131.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Tiered Learning Area - (61.76 SQM)	Student Space (28)	
B00G - R0007 - Audio Visual Workroom - (24.74 SQM)	Student Space (11)	
B00G - R0010 - Study Space - (8.35 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Study Space - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Senior Study - (62.94 SQM)	Office (15)	
B00G - R0016 - Main Area - (262.89 SQM)	Not Applicable	Circulation or storage space.
B00G - R0018 - Computer Learning Space - (59.91 SQM) - Teaching Space: 1	Student Space (27)	
B00G - R0021 - Tea Room - (5.23 SQM)	Not Applicable	Circulation or storage space.
B00G - R0022 - Movement - (10.04 SQM)	Not Applicable	Circulation or storage space.
B00G - R0023 - Movement - (147.14 SQM)	Not Applicable	Circulation or storage space.
B00G - R1003 - Movement - (6.91 SQM)	Not Applicable	Circulation or storage space.
B00G - R1005 - Commonroom - (74.52 SQM)	Office (18)	
B00G - R1006 - Staff Kitchen - (12.09 SQM)	Office (3)	
B00H - R0002 - Multi Media Workshop - (24.89 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Art Learning Space - (57.85 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0005 - Art Learning Space - (57.63 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0007 - Movement - (19.02 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Art Learning Space - (57.7 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0010 - Art Learning Space - (63.12 SQM) - Teaching Space: 1	Student Space (29)	
B00H - R0014 - Interview/Office - Type 1 - (17.13 SQM)	Office (4)	
B00J - R0001 - Wood Technology L.S. - (89.69 SQM) - Teaching Space: 1	Student Space (41)	
B00J - R0002 - Wood Technology Bay - (33.43 SQM)	Not Applicable	Circulation or storage space.
B00J - R0011 - Metal Technology Bay - (34.96 SQM)	Not Applicable	Circulation or storage space.
B00J - R0014 - Movement - (69.28 SQM)	Not Applicable	Circulation or storage space.
B00J - R0019 - Wood Technology L.S. - (87.32 SQM) - Teaching Space: 1	Student Space (40)	
B00J - R0021 - Metal Technology L.S. - (78.59 SQM) - Teaching Space: 1	Student Space (36)	
B00J - R0026 - Metal Technology L.S. - (82.48 SQM) - Teaching Space: 1	Student Space (38)	
B00J - R1003 - Design/Technology L.S. - (57.05 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R1004 - Design/Technology L.S. - (57.06 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R1005 - Movement - (11.04 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R1007 - Staff Study - (21.93 SQM)	Office (5)	
B00K - R0001 - Music Learning Space - (76.45 SQM) - Teaching Space: 1	Student Space (35)	
B00K - R0003 - Staff Study - (25.76 SQM)	Office (6)	
B00K - R0006 - Practice/Seminar - (25.32 SQM)	Not Applicable	Circulation or storage space.
B00K - R0007 - Music Learning Space - (61.35 SQM) - Teaching Space: 1	Student Space (28)	
B00K - R0008 - Movement - (17.52 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Deputy Principal Office - (17.9 SQM)	Office (4)	
B00L - R0006 - Movement - (28.35 SQM)	Not Applicable	Circulation or storage space.
B00L - R0009 - Stage - (99.22 SQM)	Not Applicable	Circulation or storage space.
B00L - R0010 - Movement - (28.12 SQM)	Not Applicable	Circulation or storage space.
B00L - R0020 - Multi-Purpose Space - (463.68 SQM)	Student Space (215)	
B00L - R0021 - Student Canteen - (56.39 SQM)	Not Applicable	Circulation or storage space.
B00L - R0023 - Interview/Office - Type 1 - (13.03 SQM)	Office (3)	
B00L - R0039 - Staff Study - (22.72 SQM)	Office (5)	
B00L - R0040 - Movement - (6.55 SQM)	Not Applicable	Circulation or storage space.
B00L - R0041 - Movement - (6.61 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Growing/Breeding - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - General Assistants - (8.24 SQM)	Office (2)	
B00N - R0001 - Interview/Meeting - (11.89 SQM)	Office (2)	
NS 110 15245 - NS 110 15245 - Learning Unit - Single Secondary/Secure - (57 SQM)	Student Space (26)	
NS 110 15247 - NS 110 15247 - Learning Unit - Single Secondary/Secure - (57 SQM)	Student Space (26)	
OS 523 18123 - OS 523 18123 - Staff Study With Toilets - (76 SQM)	Office (19)	
OS 600 11102 - OS 600 11102 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 600 17744 - OS 600 17744 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 10829 - OS 601 10829 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11736 - OS 601 11736 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 12506 - OS 601 12506 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13358 - OS 601 13358 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13870 - OS 601 13870 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 13956 - OS 601 13956 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 720 15938 - OS 720 15938 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.