


VENTILATION AUDIT REPORT

SCHOOL:	Macquarie Fields Public School (4064)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Macquarie Fields
LOCAL GOVERNMENT AREA:	Campbelltown



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0004 - Principal - (23.02 SQM)	Office (5)	
B00A - R0005 - Entry Vestibule - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Clerical Office - (15.09 SQM)	Office (3)	
B00A - R0008 - Deputy Principal - (12.46 SQM)	Office (3)	
B00A - R0010 - Sick Bay - (6.48 SQM)	Student Space (3)	
B00A - R0013 - Duplicating Workroom - (23.15 SQM)	Office (5)	
B00A - R0016 - Movement - (21.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Home Base - (56.24 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0021 - Home Base - (56.23 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0028 - Special Programs Room - (56.31 SQM)	Student Space (26)	
B00B - R0002 - Withdrawal Space - 1hb - (16.5 SQM)	Student Space (7)	
B00B - R0004 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0005 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0007 - Withdrawal Space - 1hb - (12.72 SQM)	Student Space (5)	
B00B - R0009 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0010 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0012 - Interview - (12.63 SQM)	Office (3)	
B00B - R0014 - Home Base - (53.65 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R0015 - Home Base - (53.58 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0001 - Home Base - (57.35 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0009 - Home Base - (57.05 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0010 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0015 - Practical Activities - 1hb - (12.99 SQM)	Student Space (6)	
B00C - R0016 - Practical Activities/Movement - 1hb - (5.76 SQM)	Student Space (2)	
B00D - R0001 - Movement - (6.84 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (65.52 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0005 - Movement - (7.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Home Base - (65.24 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0002 - Staff Room - (92.46 SQM)	Office (23)	
B00E - R0003 - Staff Room Annexe - (11.02 SQM)	Office (2)	
B00E - R0004 - Staff Kitchen - (10.91 SQM)	Office (2)	
B00F - R0003 - Staff Room Annexe - (14.46 SQM)	Office (3)	
B00F - R0008 - Home Base - (57.12 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0009 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B00F - R0015 - Home Base - (71.34 SQM) - Teaching Space: 1	Student Space (33)	
B00F - R0020 - Movement - (11.35 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Staff Room Annexe - (21.03 SQM)	Office (5)	
B00F - R0025 - Practical Activities/Movement - 1hb - (9.18 SQM)	Student Space (4)	
B00F - R0027 - Movement - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0029 - Practical Activities/Movement - 1hb - (16.89 SQM)	Student Space (7)	
B00F - R0030 - Home Base - (53.71 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0032 - Practical Activities/Movement - 1hb - (10.46 SQM)	Student Space (4)	
B00G - R0002 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B00G - R0006 - Movement - (5.92 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Home Base - (57.43 SQM) - Teaching Space: 1	Student Space (26)	
B00H - R0001 - Reading Area - (213.77 SQM)	Student Space (99)	
B00H - R0002 - Seminar/Study - (14.06 SQM)	Office (3)	
B00H - R0007 - Special Programs Room - (41.71 SQM)	Student Space (19)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00I - R0005 - Canteen - (43.58 SQM)	Not Applicable	Circulation or storage space.
B00I - R0007 - Movement - (22.08 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Movement - (22.07 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Staff Kitchen - (20.76 SQM)	Office (5)	
B00K - R0015 - Movement - (10.28 SQM)	Not Applicable	Circulation or storage space.
B00K - R0018 - Communal Space - (199.2 SQM)	Student Space (92)	
B00K - R0019 - Raised Platform - (50.2 SQM)	Not Applicable	Circulation or storage space.
B00K - R0020 - Movement - (8.6 SQM)	Not Applicable	Circulation or storage space.
B00O - R0002 - Practical Activities - (19.26 SQM)	Student Space (8)	
B00O - R0004 - Practical Activities - (19.27 SQM)	Student Space (8)	
B00O - R0006 - Withdrawal Space - 2hb - (11.64 SQM)	Student Space (5)	
B00O - R0008 - Home Base - (58.82 SQM) - Teaching Space: 1	Student Space (27)	
B00O - R0009 - Home Base - (58.41 SQM) - Teaching Space: 1	Student Space (27)	
B00Q - R0002 - Practical Activities/Movement - 1hb - (19.11 SQM)	Student Space (8)	
B00Q - R0004 - Home Base - (60.57 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0005 - Withdrawal Space - 2hb - (11.74 SQM)	Student Space (5)	
B00Q - R0006 - Home Base - (60.42 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0008 - Practical Activities/Movement - 1hb - (18.74 SQM)	Student Space (8)	
B00Q - R0010 - Practical Activities/Movement - 1hb - (19.13 SQM)	Student Space (8)	
B00Q - R0012 - Home Base - (60.61 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0013 - Withdrawal Space - 2hb - (11.74 SQM)	Student Space (5)	
B00Q - R0014 - Home Base - (60.58 SQM) - Teaching Space: 1	Student Space (28)	
B00Q - R0016 - Practical Activities/Movement - 1hb - (19.12 SQM)	Student Space (8)	
B00Q - R0017 - Movement - (5.08 SQM)	Not Applicable	Circulation or storage space.
B00Q - R0018 - Special Programs Room - (33.13 SQM)	Student Space (15)	
OS 602 10358 - OS 602 10358 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10382 - OS 602 10382 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11509 - OS 602 11509 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12016 - OS 602 12016 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12874 - OS 602 12874 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 12909 - OS 602 12909 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13530 - OS 602 13530 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 13606 - OS 602 13606 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14563 - OS 602 14563 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14780 - OS 602 14780 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 14949 - OS 602 14949 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15039 - OS 602 15039 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 603 10379 - OS 603 10379 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	Student Space (35)	
OS 750 12225 - OS 750 12225 - Learning Unit - ESL - (38 SQM)	Student Space (17)	