

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Maitland East Public School (2451)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Maitland</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Maitland</b>

2451 - Maitland East Public School  
Site Plan (10263)



Printed: 24-Sep-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (66.58 SQM)	Office (16)	
B00A - R0003 - Interview - (19.27 SQM)	Office (4)	
B00A - R0004 - Movement - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room Annexe - (27.52 SQM)	Office (6)	
B00A - R0008 - Movement - (9.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (47.22 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Duplicating Workroom - (38.04 SQM)	Office (9)	
B00A - R0012 - Movement - (14.06 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Deputy Principal - (16.94 SQM)	Office (4)	
B00A - R0014 - Entry Vestibule - (7.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Clerical Office - (17.23 SQM)	Office (4)	
B00A - R0016 - Principal - (29.31 SQM)	Office (7)	
B00A - R0017 - Movement - (5.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (41.93 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Home Base - (60.39 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R0021 - Practical Activities - 1hb - (31 SQM)	Student Space (14)	
B00A - R0023 - Movement - (8.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0025 - Home Base - (56.38 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0026 - Home Base - (56.65 SQM) - Teaching Space: 1	Student Space (26)	
B00A - R0028 - Staff Room Annexe - (9.9 SQM)	Office (2)	
B00A - R0029 - Sick Bay - (10.12 SQM)	Student Space (4)	
B00B - R0001 - Home Base - (66.8 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0006 - Home Base - (70.92 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0008 - Movement - (26.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (12.92 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Practical Activities - 1hb - (35.77 SQM)	Student Space (16)	
B00B - R0015 - Staff Room Annexe - (13.06 SQM)	Office (3)	
B00B - R0017 - Movement - (19.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - Practical Activities - 1hb - (51.36 SQM)	Student Space (23)	
B00B - R1004 - Movement - (25.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R1005 - Home Base - (70.46 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1007 - Home Base - (66.12 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R1010 - Movement - (9.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (33.22 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Practical Activities - 1hb - (7.29 SQM)	Student Space (3)	
B00C - R0004 - Home Base - (56.96 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0005 - Home Base - (57.04 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R0007 - Practical Activities - 1hb - (7.28 SQM)	Student Space (3)	
B00D - R0001 - Withdrawal Space - 1hb - (22.98 SQM)	Student Space (10)	
B00D - R0003 - Withdrawal Space - 1hb - (11.34 SQM)	Student Space (5)	
B00D - R0004 - Staff Room Annexe - (8.56 SQM)	Office (2)	
B00E - R0004 - Movement - (17.06 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Movement - (10.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (44.02 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Special Programs Room - (43.94 SQM)	Student Space (20)	
B00G - R0003 - Movement - (16.42 SQM)	Not Applicable	Circulation or storage space.
B00H - R0001 - Home Base - (45.53 SQM) - Teaching Space: 1	Student Space (21)	
B00H - R0002 - Practical Activities - 1hb - (7.98 SQM)	Student Space (3)	
B00H - R0003 - Movement - (30.45 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Home Base - (45.62 SQM) - Teaching Space: 1	Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0005 - Practical Activities - 1hb - (8.04 SQM)	● Student Space (3)	
B00I - R0001 - Movement - (67.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0009 - Raised Platform - (50.84 SQM)	Not Applicable	Circulation or storage space.
B00I - R0015 - Communal Space - (198.93 SQM)	● Student Space (92)	
B00I - R0016 - Movement - (35.67 SQM)	Not Applicable	Circulation or storage space.
B00I - R0019 - Movement - (8.57 SQM)	Not Applicable	Circulation or storage space.
B00I - R0021 - Canteen - (45.02 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (12.53 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Withdrawal Space - 1hb - (12.6 SQM)	● Student Space (5)	
B00J - R0003 - Home Base - (60.52 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0004 - Practical Activities - 1hb - (21.12 SQM)	● Student Space (9)	
B00J - R0006 - Movement - (37.48 SQM)	Not Applicable	Circulation or storage space.
B00J - R0007 - Home Base - (60.01 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0008 - Practical Activities - 1hb - (20.13 SQM)	● Student Space (9)	
B00J - R0011 - Withdrawal Space - 1hb - (6.15 SQM)	● Student Space (2)	
B00J - R0012 - Home Base - (56.93 SQM) - Teaching Space: 1	● Student Space (26)	
B00J - R0013 - Practical Activities - 1hb - (24.83 SQM)	● Student Space (11)	
B00J - R0018 - Home Base - (60.16 SQM) - Teaching Space: 1	● Student Space (27)	
B00J - R0019 - Practical Activities - 1hb - (20.23 SQM)	● Student Space (9)	
B00J - R0020 - Withdrawal Space - 1hb - (12.6 SQM)	● Student Space (5)	
B00J - R0021 - Movement - (12.49 SQM)	Not Applicable	Circulation or storage space.
B00J - R0022 - Home Base - (60.45 SQM) - Teaching Space: 1	● Student Space (28)	
B00J - R0024 - Practical Activities - 1hb - (21.2 SQM)	● Student Space (9)	
B00K - R0001 - Reading Area - (227.82 SQM)	● Student Space (105)	
B00K - R0003 - Special Programs Room - (43.91 SQM)	● Student Space (20)	
B00K - R0006 - Movement - (17.68 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (38.48 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00L - R0004 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (59.2 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00M - R0002 - Practical Activities - 1hb - (18.85 SQM)	● Student Space (8)	
B00M - R0004 - Home Base - (60.07 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (11.53 SQM)	● Student Space (5)	
B00M - R0006 - Practical Activities - 1hb - (18.85 SQM)	● Student Space (8)	
B00M - R0007 - Home Base - (60.07 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0002 - Home Base - (67.49 SQM) - Teaching Space: 1	● Student Space (31)	
B00N - R0004 - Home Base - (67.49 SQM) - Teaching Space: 1	● Student Space (31)	
B00N - R0006 - Practical Activities - 3hb - (37.97 SQM)	● Student Space (17)	
B00N - R0011 - Home Base - (66.75 SQM) - Teaching Space: 1	● Student Space (30)	
OS 602 10947 - OS 602 10947 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	