


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Maitland Grossmann High School (8127)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Maitland</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Maitland</b>

8127 - Maitland Grossmann High School  
Site Plan (10470)



1:1,382

Printed: 14-Aug-2021










## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Materials Technology L.S. - (91.52 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0002 - Wood Technology Bay - (38.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Materials Technology L.S. - (90.46 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R0004 - Staff Study - (25.62 SQM)	○ Office (6)	
B00A - R0005 - Design L.S. - (91.33 SQM) - Teaching Space: 1	● Student Space (42)	
B00A - R0008 - Movement - (188.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Student Canteen - (45.95 SQM)	Not Applicable	Circulation or storage space.
B00A - R1002 - Preparation - (17.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Growing/Breeding - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Interview/Office - Type 1 - (14.09 SQM)	○ Office (3)	
B00A - R1010 - Design L.S. - (64.95 SQM) - Teaching Space: 1	● Student Space (30)	
B00A - R1013 - Movement - (18.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R1015 - Staff Study - (20.13 SQM)	○ Office (5)	
B00A - R1016 - Stage - (25.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Music Learning Space - (51.96 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R1019 - Music Learning Space - (51.53 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1023 - Laboratory L.S. - (38.34 SQM) - Teaching Space: 1	● Student Space (17)	
B00A - R1024 - Science Laboratory - (39.42 SQM)	● Student Space (18)	
B00A - R1027 - Staff Kitchen - (8.19 SQM)	○ Office (2)	
B00A - R1028 - Staff Study - (37.63 SQM)	○ Office (9)	
B00A - R1029 - General Learning Space - (79.2 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0003 - Preparation - (24.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0005 - General Learning Space - (51.74 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0006 - Preparation - (25.46 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Darkroom Space - (23.97 SQM)	○ Office (5)	
B00B - R0013 - Laboratory L.S. - (39.54 SQM) - Teaching Space: 1	● Student Space (18)	
B00B - R0014 - Science Laboratory - (51.09 SQM)	● Student Space (23)	
B00B - R0015 - Laboratory L.S. - (40.32 SQM) - Teaching Space: 1	● Student Space (18)	
B00B - R0016 - Science Laboratory - (50.3 SQM)	● Student Space (23)	
B00B - R1001 - General Learning Space - (51.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1005 - Art Learning Space - (51.89 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1006 - Art Learning Space - (65.29 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1010 - Art Learning Space - (65.08 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R1013 - Staff Study - (25.37 SQM)	○ Office (6)	
B00C - R0004 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R0005 - General Learning Space - (53.13 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0006 - General Learning Space - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0008 - General Learning Space - (51.31 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0009 - General Learning Space - (52.03 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0010 - General Learning Space - (51.31 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0011 - Staff Study - (24.79 SQM)	○ Office (6)	
B00C - R0012 - Interview/Office - Type 1 - (11.62 SQM)	○ Office (2)	
B00C - R1001 - General Learning Space - (65.16 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1005 - General Learning Space - (65.07 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1006 - Design L.S. - (65.15 SQM) - Teaching Space: 1	● Student Space (30)	
B00C - R1010 - Deputy Principal Office - (14.7 SQM)	○ Office (3)	
B00C - R1011 - Interview/Office - Type 1 - (14.57 SQM)	○ Office (3)	
B00C - R1013 - Movement - (18.35 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R1014 - Seminar - (20.9 SQM)	Office (5)	
B00C - R1016 - Interview/Office - Type 1 - (11.66 SQM)	Office (2)	
B00C - R1017 - Deputy Principal Office - (12.22 SQM)	Office (3)	
B00D - R0002 - Food Technology L.S. - (81.08 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0003 - Food/Research Space - (24.9 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Food Technology L.S. - (64.42 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0007 - Staff Study - (25.3 SQM)	Office (6)	
B00D - R0008 - Staff Kitchen - (25.66 SQM)	Office (6)	
B00D - R0011 - Clinic - Boys - (18.66 SQM)	Office (4)	
B00D - R0012 - Deputy Principal Office - (12.86 SQM)	Office (3)	
B00D - R0013 - Clinic - Girls - (18.48 SQM)	Office (4)	
B00D - R0022 - Administration - Clerical - (15.5 SQM)	Office (3)	
B00D - R0023 - Principal Office - (24.33 SQM)	Office (6)	
B00D - R0028 - Duplicating Workroom - (24.45 SQM)	Office (6)	
B00D - R0029 - Interview/Office - Type 1 - (13.92 SQM)	Office (3)	
B00D - R0033 - Movement - (43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0034 - Public Entry - (105.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0037 - Administration - Clerical - (53.89 SQM)	Office (13)	
B00D - R0038 - Administration - Executive - (8.54 SQM)	Office (2)	
B00D - R1001 - General Learning Space - (52.25 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1002 - General Learning Space - (52.25 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1003 - General Learning Space - (52.25 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1004 - General Learning Space - (52.17 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1005 - General Learning Space - (52.17 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1006 - General Learning Space - (52.18 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1007 - Staff Study - (25.51 SQM)	Office (6)	
B00D - R9001 - Movement - (33.42 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Ancillary Staff - (12.92 SQM)	Office (3)	
B00E - R1002 - Preparation - (29.13 SQM)	Not Applicable	Circulation or storage space.
B00E - R1003 - Growing/Breeding - (9.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R1010 - Staff Study - (25.56 SQM)	Office (6)	
B00E - R1011 - Movement - (6.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R1012 - Movement - (6.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R1015 - Staff Study - (13.95 SQM)	Office (3)	
B00E - R1017 - Movement - (5.99 SQM)	Not Applicable	Circulation or storage space.
B00E - R1025 - Science Laboratory - (52.17 SQM)	Student Space (24)	
B00E - R1026 - Laboratory L.S. - (39.56 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R1027 - Preparation - Science - (39.03 SQM)	Not Applicable	Circulation or storage space.
B00E - R1028 - Laboratory L.S. - (40.62 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R1029 - Science Laboratory - (51.43 SQM)	Student Space (23)	
B00E - R1030 - Science Laboratory - (52.82 SQM)	Student Space (24)	
B00E - R1031 - Laboratory L.S. - (40.29 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R2001 - Movement - (6.04 SQM)	Not Applicable	Circulation or storage space.
B00E - R2002 - Performance Workspace - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R2004 - Staff Kitchen - (6.16 SQM)	Office (1)	
B00E - R2005 - Special Learning Space - (51.57 SQM)	Student Space (23)	
B00E - R2008 - Staff Study - (25.94 SQM)	Office (6)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R2009 - General Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R2010 - General Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R2011 - Special Learning Space - (52.74 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R2014 - Special Learning Space - (52.67 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R2018 - Special Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R2024 - Design L.S. - (66.01 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R2036 - Staff Study - (31.58 SQM)	Office (7)	
B00E - R2038 - Movement - (20.24 SQM)	Not Applicable	Circulation or storage space.
B00E - R3001 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R3002 - Seminar - (29.07 SQM)	Office (7)	
B00E - R3003 - General Learning Space - (75.87 SQM) - Teaching Space: 1	Student Space (35)	
B00E - R3007 - Staff Study - (25.57 SQM)	Office (6)	
B00E - R3008 - General Learning Space - (38.72 SQM) - Teaching Space: 1	Student Space (17)	
B00E - R3009 - General Learning Space - (39.08 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R3010 - General Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R3013 - General Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R3014 - General Learning Space - (52.9 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R3017 - General Learning Space - (52.32 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R3018 - General Learning Space - (52.61 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R3019 - Computer Learning Space - (52.68 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R3020 - Computer Learning Space - (52.31 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0001 - Metal Technology Bay - (33.93 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Movement - (8.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Materials Technology L.S. - (80.65 SQM) - Teaching Space: 1	Student Space (37)	
B00F - R0004 - Welding Area - (8.95 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Welding Area - (11.55 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Movement - (5.38 SQM)	Not Applicable	Circulation or storage space.
B00H - M0002 - General Learning Space - (38.21 SQM) - Teaching Space: 1	Student Space (17)	
B00H - R0001 - Movement - (16.57 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Movement - (19.88 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Movement - (156.21 SQM)	Not Applicable	Circulation or storage space.
B00H - R0008 - Seminar - (18.26 SQM)	Office (4)	
B00H - R0009 - Movement - (25.64 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Stage - (134.07 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Multi-Purpose Space - (436.77 SQM)	Student Space (202)	
B00H - R0025 - Movement - (10.15 SQM)	Not Applicable	Circulation or storage space.
B00H - R0026 - Kitchen - Type 2 - (29.5 SQM)	Student Space (13)	
B00H - R9001 - Movement - (55.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R9013 - Movement - (26.86 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Main Area - (401.67 SQM)	Not Applicable	Circulation or storage space.
B00L - R0003 - Audio Visual Workroom - (34.77 SQM)	Student Space (16)	
B00L - R0004 - Workroom - (39.41 SQM)	Office (9)	
B00L - R0006 - Pupil Entry - (16.19 SQM)	Not Applicable	Circulation or storage space.
B00L - R0007 - Movement - (5.75 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Seminar - (13.45 SQM)	Office (3)	
B00L - R0013 - Seminar - (20.95 SQM)	Office (5)	
B00L - R0014 - Movement - (9.71 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Gymnasium - (709.87 SQM)	Student Space (329)	
NS 110 13095 - NS 110 13095 - Learning Unit - Single Secondary/Secure - (57 SQM)	Student Space (26)	

Entity Location	Audit Condition Classification (Capacity)	Comment
NS 110 17813 - NS 110 17813 - Learning Unit - Single Secondary/Secure - (57 SQM)	 Student Space (26)	
OS 601 10369 - OS 601 10369 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12666 - OS 601 12666 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 12858 - OS 601 12858 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13106 - OS 601 13106 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13213 - OS 601 13213 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14194 - OS 601 14194 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 14879 - OS 601 14879 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 15710 - OS 601 15710 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	