

VENTILATION AUDIT REPORT

SCHOOL:	Maitland High School (8126)
AMU REGION:	Hunter/Central Coast
STATE ELECTORATE:	Maitland
LOCAL GOVERNMENT AREA:	Maitland

8126 - Maitland High School
Site Plan (13148)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Workroom - (14.78 SQM)	Office (3)	
B00A - R0004 - Movement - (24.39 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Design L.S. - (48.62 SQM) - Teaching Space: 1	Student Space (22)	
B00A - R0007 - Design L.S. - (50.23 SQM) - Teaching Space: 1	Student Space (23)	
B00A - R0008 - General Learning Space - (51.93 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0009 - General Learning Space - (53.87 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0010 - Gymnasium - (53.12 SQM) - Teaching Space: 1	Student Space (24)	
B00A - R0012 - Movement - (54.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (9.93 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (9.19 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Stage - (68.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Multi-Purpose Space - (275.24 SQM)	Student Space (127)	
B00B - R0009 - Movement - (21.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (69.96 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R9002 - Movement - (13.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R9007 - Movement - (9.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R9013 - Staff Study - (15.7 SQM)	Office (3)	
B00C - R0001 - Food Technology L.S. - (100.38 SQM) - Teaching Space: 1	Student Space (46)	
B00C - R0002 - Food/Research Space - (21.03 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Staff Study - (21.85 SQM)	Office (5)	
B00C - R0007 - Food Technology L.S. - (100.37 SQM) - Teaching Space: 1	Student Space (46)	
B00E - R0005 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Stage - (60.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (12.76 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Multi-Purpose Space - (616.12 SQM)	Student Space (285)	
B00E - R0019 - Movement - (88.48 SQM)	Not Applicable	Circulation or storage space.
B00E - R0021 - Staff Study - (37.51 SQM)	Office (9)	
B00H - R0002 - Movement - (14.5 SQM)	Not Applicable	Circulation or storage space.
B00H - R0003 - Materials Technology L.S. - (67.47 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R0004 - Materials Technology L.S. - (66.93 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R0008 - Staff Study - (19.54 SQM)	Office (4)	
B00H - R0010 - Staff Study - (14.22 SQM)	Office (3)	
B00H - R0011 - Staff Kitchen - (15.25 SQM)	Office (3)	
B00H - R0012 - Movement - (10.43 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Movement - (7.11 SQM)	Not Applicable	Circulation or storage space.
B00H - R0017 - Movement - (20.1 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Movement - (24.46 SQM)	Not Applicable	Circulation or storage space.
B00H - R1003 - Music Learning Space - (67.11 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R1006 - Staff Study - (10.88 SQM)	Office (2)	
B00H - R1008 - Staff Study - (21.44 SQM)	Office (5)	
B00H - R1009 - Staff Study - (16.54 SQM)	Office (4)	
B00H - R1010 - Practice/Seminar - (5.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R1011 - Practice/Seminar - (5.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R1014 - Music Learning Space - (67.18 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R1015 - Practice/Seminar - (10.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R1016 - Movement - (18.91 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Seminar - (20.88 SQM)	Office (5)	
B00L - R0002 - Workroom - (16.59 SQM)	Office (4)	
B00L - R0004 - Main Area - (32.57 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00L - R0008 - Main Area - (48.54 SQM)	Not Applicable	Circulation or storage space.
B00L - R0012 - Seminar - (24.7 SQM)	Office (6)	
B00L - R0013 - Movement - (31.82 SQM)	Not Applicable	Circulation or storage space.
B00L - R0014 - Movement - (27.47 SQM)	Not Applicable	Circulation or storage space.
B00L - R0016 - Movement - (42.44 SQM)	Not Applicable	Circulation or storage space.
B00L - R1001 - Main Area - (153.59 SQM)	Not Applicable	Circulation or storage space.
B00L - R1002 - Main Area - (49.88 SQM)	Not Applicable	Circulation or storage space.
B00L - R1004 - Movement - (8.39 SQM)	Not Applicable	Circulation or storage space.
B00L - R1008 - Movement - (30.2 SQM)	Not Applicable	Circulation or storage space.
B00M - R0003 - Student Canteen - (46.51 SQM)	Not Applicable	Circulation or storage space.
B00M - R0012 - Movement - (119.73 SQM)	Not Applicable	Circulation or storage space.
B00M - R0015 - Movement - (8.82 SQM)	Not Applicable	Circulation or storage space.
B00M - R1003 - Computer Learning Space - (79.78 SQM) - Teaching Space: 1	Student Space (37)	
B00M - R1004 - Computer Learning Space - (53.4 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R1005 - Computer Learning Space - (52.89 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R1006 - Movement - (85.53 SQM)	Not Applicable	Circulation or storage space.
B00M - R1009 - Staff Study - (20.37 SQM)	Office (5)	
B00M - R2006 - Movement - (87.1 SQM)	Not Applicable	Circulation or storage space.
B00M - R2009 - General Learning Space - Type 10 - (40.19 SQM) - Teaching Space: 0.5	Student Space (18)	
B00M - R2010 - Science Laboratory - (46.43 SQM)	Student Space (21)	
B00M - R2011 - Preparation - Science - (38.39 SQM)	Not Applicable	Circulation or storage space.
B00M - R2012 - Science Laboratory - (46.21 SQM)	Student Space (21)	
B00M - R2013 - General Learning Space - Type 10 - (40.11 SQM) - Teaching Space: 0.5	Student Space (18)	
B00M - R3003 - General Learning Space - (52.52 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R3004 - Staff Study - (25.68 SQM)	Office (6)	
B00M - R3006 - Staff Study - (12.51 SQM)	Office (3)	
B00M - R3007 - General Learning Space - (52.97 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R3008 - General Learning Space - (52.82 SQM) - Teaching Space: 1	Student Space (24)	
B00M - R3009 - Movement - (85.11 SQM)	Not Applicable	Circulation or storage space.
B00P - R0002 - Workshop - (32.82 SQM)	Student Space (15)	
B00P - R0003 - Art Learning Space - (69.84 SQM) - Teaching Space: 1	Student Space (32)	
B00P - R0006 - Staff Study - (17.18 SQM)	Office (4)	
B00P - R0007 - General Learning Space - (47.23 SQM) - Teaching Space: 1	Student Space (21)	
B00P - R0009 - Senior Seminar - (69.06 SQM)	Office (17)	
B00P - R0016 - Movement - (18.79 SQM)	Not Applicable	Circulation or storage space.
B00P - R0021 - Movement - (105.64 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Laboratory L.S. - (88.99 SQM) - Teaching Space: 1	Student Space (41)	
B00P - R1002 - Preparation - (34.16 SQM)	Not Applicable	Circulation or storage space.
B00P - R1003 - Laboratory L.S. - (88.16 SQM) - Teaching Space: 1	Student Space (40)	
B00P - R1005 - General Learning Space - (52.14 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R1009 - General Learning Space - (52.14 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R1010 - General Learning Space - (52.51 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R1012 - Clinic - Girls - (15.9 SQM)	Office (3)	
B00P - R1018 - Movement - (10.09 SQM)	Not Applicable	Circulation or storage space.
B00P - R1021 - Duplicating Workroom - (32.11 SQM)	Office (8)	
B00P - R1022 - Ancillary Staff - (19.02 SQM)	Office (4)	
B00P - R1023 - General Learning Space - (52.19 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R1024 - General Learning Space - (52.19 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R1027 - Interview/Office - Type 1 - (21.63 SQM)	Office (5)	
B00P - R1028 - Interview/Office - Type 1 - (14.51 SQM)	Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R1029 - Staff Study - (36.77 SQM)	Office (9)	
B00P - R1031 - Movement - (252.62 SQM)	Not Applicable	Circulation or storage space.
B00P - R1032 - Administration - Clerical - (52.42 SQM)	Office (13)	
B00P - R1034 - Movement - (40.17 SQM)	Not Applicable	Circulation or storage space.
B00P - R1036 - Leading Teacher - (21.26 SQM)	Office (5)	
B00P - R1039 - Principal Office - (22.04 SQM)	Office (5)	
B00P - R1045 - Staff Study - (15.26 SQM)	Office (3)	
B00P - R1048 - Administration - Executive - (12.38 SQM)	Office (3)	
B00P - R2003 - Preparation - (15.19 SQM)	Not Applicable	Circulation or storage space.
B00P - R2004 - General Learning Space - (53.24 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2005 - General Learning Space - (53.24 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2007 - General Learning Space - (53.79 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2009 - General Learning Space - (53.3 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2010 - General Learning Space - (53.04 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2011 - General Learning Space - (53.54 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2012 - Deputy Principal Office - (31.72 SQM)	Office (7)	
B00P - R2013 - General Learning Space - (53.38 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2014 - General Learning Space - (53.37 SQM) - Teaching Space: 1	Student Space (24)	
B00P - R2015 - Computer Learning Space - (51.25 SQM) - Teaching Space: 1	Student Space (23)	
B00P - R2017 - Staff Study - (21.24 SQM)	Office (5)	
B00P - R2020 - Staff Study - (44.5 SQM)	Office (11)	
B00P - R2021 - Staff Study - (10.22 SQM)	Office (2)	
B00P - R2022 - Commonroom - (136.04 SQM)	Office (34)	
B00P - R2025 - Darkroom Space - (8.48 SQM)	Office (2)	
B00P - R2028 - Darkroom Space - (9.05 SQM)	Office (2)	
B00P - R2033 - Art Learning Space - (91.93 SQM) - Teaching Space: 1	Student Space (42)	
B00P - R2034 - Staff Study - (16.23 SQM)	Office (4)	
B00P - R2035 - Movement - (228.28 SQM)	Not Applicable	Circulation or storage space.
B00S - R0004 - Movement - (219.36 SQM)	Not Applicable	Circulation or storage space.
B00S - R0005 - Movement - (17.18 SQM)	Not Applicable	Circulation or storage space.
B00S - R0006 - Movement - (9.94 SQM)	Not Applicable	Circulation or storage space.
B00S - R0012 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
B00S - R0013 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00S - R1004 - Art Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00S - R1008 - Staff Study - (26.09 SQM)	Office (6)	
B00S - R1011 - Movement - (9.11 SQM)	Not Applicable	Circulation or storage space.
B00S - R1016 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00S - R1017 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
B00S - R1019 - Photographic Studio - (14.51 SQM)	Office (3)	
B00S - R1021 - Art Learning Space - (72.03 SQM) - Teaching Space: 1	Student Space (33)	
B00S - R1024 - Movement - (72.3 SQM)	Not Applicable	Circulation or storage space.
B00S - R2007 - Staff Study - (52.24 SQM) - Teaching Space: 1	Office (13)	
B00S - R2008 - Movement - (79.5 SQM)	Not Applicable	Circulation or storage space.
B00S - R2010 - Movement - (9.14 SQM)	Not Applicable	Circulation or storage space.
B00S - R2015 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00S - R2016 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
B00S - R2018 - General Learning Space - Type 10 - (46.47 SQM) - Teaching Space: 0.5	Student Space (21)	
B00S - R2019 - Science Laboratory - (45.78 SQM)	Student Space (21)	
B00S - R2021 - Staff Study - (36.59 SQM)	Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00S - R3004 - General Learning Space - (52.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00S - R3005 - General Learning Space - (52.53 SQM) - Teaching Space: 1	● Student Space (24)	
B00S - R3006 - General Learning Space - (52.38 SQM) - Teaching Space: 1	● Student Space (24)	
B00S - R3007 - Staff Study - (25.71 SQM)	● Office (6)	
B00S - R3008 - Movement - (76.45 SQM)	Not Applicable	Circulation or storage space.
B00S - R3013 - Movement - (8.64 SQM)	Not Applicable	Circulation or storage space.
B00W - R0002 - Materials Technology L.S. - (94.32 SQM) - Teaching Space: 1	● Student Space (43)	
B00W - R0003 - Staff Study - (37.6 SQM)	● Office (9)	
B00W - R0004 - Movement - (12.41 SQM)	Not Applicable	Circulation or storage space.
B00W - R0005 - Materials Technology L.S. - (89.42 SQM) - Teaching Space: 1	● Student Space (41)	
B00W - R0006 - Metal Technology Bay - (32.7 SQM)	Not Applicable	Circulation or storage space.
B00W - R0009 - Welding Area - (8.86 SQM)	Not Applicable	Circulation or storage space.
B00W - R0014 - Movement - (16.96 SQM)	Not Applicable	Circulation or storage space.
B00W - R0015 - Materials Technology L.S. - (90.68 SQM) - Teaching Space: 1	● Student Space (42)	
B00W - R0016 - Wood Technology Bay - (26.73 SQM)	Not Applicable	Circulation or storage space.
B00W - R0017 - Materials Technology L.S. - (90.27 SQM) - Teaching Space: 1	● Student Space (41)	
B00W - R0020 - Movement - (26.97 SQM)	Not Applicable	Circulation or storage space.
B00X - R0001 - Gymnasium - (141.02 SQM)	● Student Space (65)	
OS 601 15254 - OS 601 15254 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19491 - OS 601 19491 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 19851 - OS 601 19851 - Learning Unit - Standard/Withdrawal - (57 SQM)	● Student Space (26)	