


VENTILATION AUDIT REPORT

SCHOOL:	Manilla Central School (7305)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Tamworth
LOCAL GOVERNMENT AREA:	Tamworth

7305 - Manilla Central School
Site Plan (12794)



1:770

Printed: 27-Nov-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room Annexe - (11.14 SQM)	Office (2)	
B00A - R0002 - Sick Bay - (7.34 SQM)	Student Space (3)	
B00A - R0003 - Staff Room - (48.69 SQM)	Office (12)	
B00A - R0007 - Clerical Office/Workroom - (25.17 SQM)	Office (6)	
B00A - R0010 - Movement - (6.57 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Interview - (10.97 SQM)	Office (2)	
B00B - R0001 - Home Base - (64.15 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R0002 - Practical Activities - 1hb - (5.51 SQM)	Student Space (2)	
B00B - R0004 - Home Base - (49.99 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R0005 - Practical Activities - 1hb - (5.63 SQM)	Student Space (2)	
B00B - R0006 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Special Programs Room - (47.48 SQM)	Student Space (22)	
B00F - R0001 - Home Base - (49.11 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0002 - Music Learning Space - (52.87 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0003 - General Learning Space - (48.42 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0006 - Home Base - (47.41 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0010 - Canteen - (19.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0022 - Movement - (74.89 SQM)	Not Applicable	Circulation or storage space.
B00F - R0023 - Sick Bay - (8.03 SQM)	Student Space (3)	
B00F - R0025 - Home Base - (44.62 SQM) - Teaching Space: 1	Student Space (20)	
B00F - R0027 - Duplicating Workroom - (19.63 SQM)	Office (4)	
B00F - R0028 - Home Base - (52.09 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0030 - Interview - (7.91 SQM)	Office (1)	
B00F - R0032 - Home Base - (46.96 SQM) - Teaching Space: 1	Student Space (21)	
B00F - R0034 - Movement - (70.03 SQM)	Not Applicable	Circulation or storage space.
B00F - R0036 - Staff Room Annexe - (10.88 SQM)	Office (2)	
B00F - R0037 - Reading Area - (123.7 SQM)	Student Space (57)	
B00F - R0039 - Home Base - (49.16 SQM) - Teaching Space: 1	Student Space (22)	
B00F - R0041 - Staff Room Annexe - (13.52 SQM)	Office (3)	
B00F - R0042 - Movement - (42.49 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Reading Area - (136.54 SQM)	Student Space (63)	
B00G - R0006 - Seminar/Study - (12.89 SQM)	Office (3)	
B00G - R0007 - Seminar/Study - (12.78 SQM)	Office (3)	
B00H - R0002 - Interview - (12.63 SQM)	Office (3)	
B00H - R0004 - Staff Room Annexe - (24.86 SQM)	Office (6)	
B00H - R0006 - Design L.S. - (75.54 SQM) - Teaching Space: 1	Student Space (35)	
B00H - R0012 - Food Technology L.S. - (75.21 SQM) - Teaching Space: 1	Student Space (34)	
B00H - R0013 - Food/Research Space - (41.81 SQM)	Not Applicable	Circulation or storage space.
B00J - R0003 - Music Learning Space - (75.14 SQM) - Teaching Space: 1	Student Space (34)	
B00J - R0005 - Multi Media Studio - (22.74 SQM)	Not Applicable	Circulation or storage space.
B00J - R0008 - Art Learning Space - (69.64 SQM) - Teaching Space: 1	Student Space (32)	
B00J - R0011 - Computer Learning Space - (62.21 SQM) - Teaching Space: 1	Student Space (28)	
B00J - R0019 - Laboratory L.S. - (93.37 SQM) - Teaching Space: 1	Student Space (43)	
B00J - R0020 - Preparation - (39.45 SQM)	Not Applicable	Circulation or storage space.
B00J - R0023 - Laboratory L.S. - (93.44 SQM) - Teaching Space: 1	Student Space (43)	
B00M - R0001 - Computer Learning Space - (91.88 SQM) - Teaching Space: 1	Student Space (42)	
B00M - R0002 - Seminar - Type 1 - (19.11 SQM)	Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0002 - Practical Activities/Movement - 1hb - (19.39 SQM)	Student Space (8)	
B00N - R0004 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (10.69 SQM)	Student Space (4)	
B00N - R0006 - Home Base - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00N - R0008 - Practical Activities/Movement - 1hb - (19.39 SQM)	Student Space (8)	
B00O - R0002 - Practical Activities/Movement - 1hb - (19.39 SQM)	Student Space (8)	
B00O - R0004 - Home Base - (58.86 SQM) - Teaching Space: 1	Student Space (27)	
B00O - R0005 - Withdrawal Space - 2hb - (10.69 SQM)	Student Space (4)	
B00O - R0006 - Home Base - (58.77 SQM) - Teaching Space: 1	Student Space (27)	
B00O - R0008 - Practical Activities/Movement - 1hb - (19.39 SQM)	Student Space (8)	
B0A1 - R0002 - Duplicating Workroom - (17.3 SQM)	Office (4)	
B0A1 - R0004 - Clerical Office - (21.48 SQM)	Office (5)	
B0A1 - R0005 - Public Entry - (31.17 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0006 - Deputy Principal - (19.93 SQM)	Office (4)	
B0A1 - R0011 - Interview - (15.13 SQM)	Office (3)	
B0A1 - R0012 - Principal - (20.8 SQM)	Office (5)	
B0A1 - R0013 - Interview - (13.59 SQM)	Office (3)	
B0A1 - R0015 - Movement - (20.79 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0004 - Movement - (161.16 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0008 - Movement - (14.44 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0011 - Canteen - (41.51 SQM)	Not Applicable	Circulation or storage space.
B0C1 - R0003 - General Learning Space - (52.99 SQM) - Teaching Space: 1	Student Space (24)	
B0C1 - R0004 - General Learning Space - (53.09 SQM) - Teaching Space: 1	Student Space (24)	
B0C1 - R0005 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B0C1 - R0006 - General Learning Space - (51.1 SQM) - Teaching Space: 1	Student Space (23)	
B0C1 - R0007 - Staff Room Annexe - (23.96 SQM)	Office (5)	
B0C1 - R0009 - Staff Room Annexe - (26.54 SQM)	Office (6)	
B0C1 - R0010 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B0D1 - R0007 - Staff Room Annexe - (6.04 SQM)	Office (1)	
B0D1 - R0009 - Staff Room - (59.09 SQM)	Office (14)	
B0D1 - R0010 - Staff Room Annexe - (26.29 SQM)	Office (6)	
B0D1 - R0011 - General Learning Space - (52.66 SQM) - Teaching Space: 1	Student Space (24)	
B0D1 - R0012 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B0D1 - R0013 - Serviced Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B0E1 - R0002 - Senior Seminar - (23.66 SQM)	Office (5)	
B0E1 - R0003 - Seminar/Study - (14.4 SQM)	Office (3)	
B0E1 - R0004 - Staff Room Annexe - (25.49 SQM)	Office (6)	
B0E1 - R0012 - Workshop Area - (150.56 SQM)	Student Space (69)	
B0E1 - R0018 - Workshop Area - (94.02 SQM)	Student Space (43)	
B0E1 - R0020 - General Learning Space - (28.75 SQM) - Teaching Space: 1	Student Space (13)	
B0F1 - R0002 - Multi-Purpose Space - (458.43 SQM)	Student Space (212)	
B0F1 - R0009 - Raised Platform - (94.51 SQM)	Not Applicable	Circulation or storage space.