


VENTILATION AUDIT REPORT

SCHOOL:	Manly Vale Public School (4021)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Manly
LOCAL GOVERNMENT AREA:	Northern Beaches

4021 - Manly Vale Public School
Site Plan (11185)
















































1:1,348




Printed: 16-Mar-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R0001 - Canteen - (26.21 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Staff Room Annexe - (19.5 SQM)	Office (4)	
B00K - R0003 - Interview/Office - Type 3 - (16.81 SQM)	Office (4)	
B00K - R0004 - Movement - (55.29 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Staff Room - (48.94 SQM)	Office (12)	
B00K - R0010 - Sick Bay - (8.96 SQM)	Student Space (4)	
B00K - R0013 - Deputy Principal - (12.13 SQM)	Office (3)	
B00K - R0014 - Principal - (17.21 SQM)	Office (4)	
B00K - R0015 - Interview - (13.24 SQM)	Office (3)	
B00K - R0016 - Duplicating Workroom - (23.88 SQM)	Office (5)	
B00K - R0017 - Clerical Office - (26.94 SQM)	Office (6)	
B00K - R0018 - Entry Vestibule - (23.15 SQM)	Not Applicable	Circulation or storage space.
B00K - R0021 - Deputy Principal - Type 1 - (12.46 SQM)	Office (3)	
B00K - R0022 - Deputy Principal - Type 1 - (14.16 SQM)	Office (3)	
B00K - R0023 - Deputy Principal - Type 2 - (26.03 SQM)	Office (6)	
B00K - R0024 - Clerical Office - (14.32 SQM)	Office (3)	
B00L - R0001 - Communal Space - (377.46 SQM)	Student Space (175)	
B00L - R0006 - Canteen - (46.62 SQM)	Not Applicable	Circulation or storage space.
B00L - R0013 - Staff Room - (109.45 SQM)	Office (27)	
B00L - R0014 - Staff Room Annexe - (43.81 SQM)	Office (10)	
B00M - R0001 - Home Base - (64.69 SQM) - Teaching Space: 1	Student Space (30)	
B00M - R0002 - Home Base - (64.68 SQM) - Teaching Space: 1	Student Space (30)	
B00M - R0005 - Withdrawal Space - 2hb - (12.68 SQM)	Student Space (5)	
B00M - R0007 - Practical Activities - 4hb - (91.93 SQM)	Student Space (42)	
B00M - R0009 - Home Base - (68.81 SQM) - Teaching Space: 1	Student Space (31)	
B00M - R0010 - Home Base - (68.85 SQM) - Teaching Space: 1	Student Space (31)	
B00M - R0011 - Withdrawal Space - 2hb - (12.69 SQM)	Student Space (5)	
B00M - R0012 - Home Base - (64.55 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R0013 - Home Base - (64.54 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R0015 - Practical Activities - 4hb - (92.19 SQM)	Student Space (42)	
B00M - R0023 - Movement - (47.25 SQM)	Not Applicable	Circulation or storage space.
B00M - R1001 - Home Base - (64.64 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R1002 - Home Base - (64.67 SQM) - Teaching Space: 1	Student Space (30)	
B00M - R1005 - Withdrawal Space - 2hb - (12.23 SQM)	Student Space (5)	
B00M - R1007 - Practical Activities - 4hb - (91.89 SQM)	Student Space (42)	
B00M - R1009 - Home Base - (68.81 SQM) - Teaching Space: 1	Student Space (31)	
B00M - R1010 - Home Base - (68.86 SQM) - Teaching Space: 1	Student Space (31)	
B00M - R1011 - Withdrawal Space - 2hb - (11.99 SQM)	Student Space (5)	
B00M - R1012 - Home Base - (64.52 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R1013 - Home Base - (64.2 SQM) - Teaching Space: 1	Student Space (29)	
B00M - R1015 - Practical Activities - 2hb - (90.7 SQM)	Student Space (42)	
B00N - R0001 - Movement - (522.04 SQM)	Not Applicable	Circulation or storage space.
B00N - R1001 - Reading Area - (284.39 SQM)	Student Space (131)	
B00N - R1005 - Seminar/Study - (33.36 SQM)	Office (8)	
B00N - R1006 - Seminar/Study - (34.59 SQM)	Office (8)	
B00N - R1007 - Seminar/Study - (31.97 SQM)	Office (7)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R1008 - Seminar/Study - (35.94 SQM)	 Office (8)	
B00O - R0001 - Home Base - (64.08 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R0002 - Home Base - (64.03 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R0005 - Withdrawal Space - 2hb - (11.29 SQM)	 Student Space (5)	
B00O - R0007 - Practical Activities - 4hb - (89.35 SQM)	 Student Space (41)	
B00O - R0009 - Home Base - (64.58 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R0010 - Home Base - (64.53 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R0011 - Withdrawal Space - 2hb - (11.79 SQM)	 Student Space (5)	
B00O - R0012 - Home Base - (64 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R0013 - Home Base - (63.84 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R0015 - Practical Activities - 4hb - (89.43 SQM)	 Student Space (41)	
B00O - R0017 - Withdrawal Space - 2hb - (11.79 SQM)	 Student Space (5)	
B00O - R0018 - Home Base - (63.55 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R0019 - Home Base - (62.99 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1001 - Home Base - (62.99 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1002 - Home Base - (63.34 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1005 - Withdrawal Space - 2hb - (11.48 SQM)	 Student Space (5)	
B00O - R1007 - Practical Activities - 4hb - (89.78 SQM)	 Student Space (41)	
B00O - R1009 - Home Base - (63.81 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1010 - Home Base - (63.55 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1011 - Withdrawal Space - 2hb - (11.24 SQM)	 Student Space (5)	
B00O - R1012 - Home Base - (64 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1013 - Home Base - (63.84 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1015 - Practical Activities - 4hb - (89.42 SQM)	 Student Space (41)	
B00O - R1017 - Withdrawal Space - 2hb - (11.51 SQM)	 Student Space (5)	
B00O - R1018 - Home Base - (63.55 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1019 - Home Base - (62.99 SQM) - Teaching Space: 1	 Student Space (29)	
B00O - R1024 - Movement - (38.61 SQM)	Not Applicable	Circulation or storage space.
B00P - R0001 - Movement - (681.72 SQM)	Not Applicable	Circulation or storage space.
B00P - R1001 - Home Base - (63.44 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R1002 - Home Base - (63.36 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R1003 - Withdrawal Space - 2hb - (11.74 SQM)	 Student Space (5)	
B00P - R1005 - Practical Activities - 4hb - (89.21 SQM)	 Student Space (41)	
B00P - R1007 - Home Base - (64.45 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R1008 - Home Base - (64.02 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R1009 - Withdrawal Space - 2hb - (11.77 SQM)	 Student Space (5)	
B00P - R1010 - Home Base - (63.87 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R1011 - Home Base - (64.03 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R1013 - Practical Activities - 2hb - (141.14 SQM)	 Student Space (65)	
B00P - R1016 - Practical Activities - 2hb - (114.85 SQM)	 Student Space (53)	
B00P - R2001 - Home Base - (64.49 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R2002 - Home Base - (64.51 SQM) - Teaching Space: 1	 Student Space (29)	
B00P - R2003 - Withdrawal Space - 2hb - (12.67 SQM)	 Student Space (5)	
B00P - R2005 - Practical Activities - 4hb - (91.86 SQM)	 Student Space (42)	
B00P - R2007 - Home Base - (65.48 SQM) - Teaching Space: 1	 Student Space (30)	
B00P - R2008 - Home Base - (65.37 SQM) - Teaching Space: 1	 Student Space (30)	
B00P - R2009 - Withdrawal Space - 2hb - (12.69 SQM)	 Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00P - R2010 - Home Base - (65.35 SQM) - Teaching Space: 1	 Student Space (30)	
B00P - R2011 - Home Base - (65.54 SQM) - Teaching Space: 1	 Student Space (30)	
B00P - R2013 - Practical Activities - 2hb - (99.39 SQM)	 Student Space (46)	