

VENTILATION AUDIT REPORT

SCHOOL:	Manly West Public School (2469)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Manly
LOCAL GOVERNMENT AREA:	Northern Beaches

2469 - Manly West Public School
Site Plan (11836)



















1:867

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (5.19 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Home Base - (70.22 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0008 - Home Base - (70.02 SQM) - Teaching Space: 1	● Student Space (32)	
B00A - R0011 - Home Base - (51.32 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0014 - Interview - (21.16 SQM)	○ Office (5)	
B00A - R0016 - Staff Room Annexe - (20.54 SQM)	○ Office (5)	
B00A - R0019 - Home Base - (50.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0022 - Movement - (7.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Home Base - (50.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0025 - Home Base - (50.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R0029 - Movement - (176.09 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (48.06 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1002 - Home Base - (56.26 SQM) - Teaching Space: 1	● Student Space (26)	
B00A - R1004 - Home Base - (51.32 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1006 - Interview - (21.71 SQM)	○ Office (5)	
B00A - R1007 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - Home Base - (50.89 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1013 - Home Base - (50.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1014 - Home Base - (50.64 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1018 - Movement - (213.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R9004 - Movement - (71.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (6.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0018 - Home Base - (65.68 SQM) - Teaching Space: 1	● Student Space (30)	
B00B - R0020 - Home Base - (112.13 SQM) - Teaching Space: 1	● Student Space (52)	
B00B - R0021 - Home Base - (107.44 SQM) - Teaching Space: 1	● Student Space (49)	
B00B - R0022 - Withdrawal Space - 1hb - (15.83 SQM)	● Student Space (7)	
B00B - R0023 - Withdrawal Space - 1hb - (15.84 SQM)	● Student Space (7)	
B00C - R0001 - Home Base - (57.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0005 - Home Base - (57.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R0010 - Home Base - (57.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1001 - Home Base - (57.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1004 - Home Base - (57.71 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1009 - Home Base - (57.72 SQM) - Teaching Space: 1	● Student Space (26)	
B00C - R1010 - Movement - (81.39 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Sick Bay - (13.8 SQM)	● Student Space (6)	
B00D - R0004 - Clerical Office - (14.05 SQM)	○ Office (3)	
B00D - R0007 - Home Base - (43.01 SQM) - Teaching Space: 1	● Student Space (19)	
B00D - R0008 - Home Base - (46.89 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0009 - Duplicating Workroom - (27.74 SQM)	○ Office (6)	
B00D - R0010 - Principal - (19.54 SQM)	○ Office (4)	
B00D - R0011 - Entry Vestibule - (17.76 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Home Base - (47.04 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0014 - Home Base - (47.16 SQM) - Teaching Space: 1	● Student Space (21)	
B00D - R0015 - Home Base - (47.96 SQM) - Teaching Space: 1	● Student Space (22)	
B00D - R0016 - Home Base - (52.68 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0018 - Deputy Principal - (12.2 SQM)	○ Office (3)	
B00D - R0019 - Staff Kitchen - (18.87 SQM)	○ Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0022 - Staff Room - (47.53 SQM)	 Office (11)	
B00D - R0023 - Staff Room - (47.54 SQM)	 Office (11)	
B00D - R0024 - Movement - (50.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0027 - Movement - (37.51 SQM)	Not Applicable	Circulation or storage space.
B00D - R0031 - Reading Area - (47.23 SQM)	 Student Space (21)	
B00D - R0032 - Reading Area - (47.23 SQM)	 Student Space (21)	
B00D - R0034 - Reading Area - (53.16 SQM)	 Student Space (24)	
B00D - R0036 - Movement - (5.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0041 - Movement - (23.68 SQM)	Not Applicable	Circulation or storage space.
B00D - R0043 - Reading Area - (58.2 SQM)	 Student Space (27)	
B00G - R0004 - Canteen - (45.24 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Special Programs Room - (54.42 SQM)	 Student Space (25)	
B00J - R0003 - Special Programs Room - (57.71 SQM)	 Student Space (26)	
B00K - R0004 - Communal Space - (203.83 SQM)	 Student Space (94)	
B00K - R0005 - Raised Platform - (62.97 SQM)	Not Applicable	Circulation or storage space.
B00K - R0006 - Movement - (12.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R0008 - Movement - (5.77 SQM)	Not Applicable	Circulation or storage space.
OS 602 12601 - OS 602 12601 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13955 - OS 602 13955 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 14091 - OS 602 14091 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15389 - OS 602 15389 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16141 - OS 602 16141 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 17673 - OS 602 17673 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 13627 - OS 603 13627 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	