

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Maraylya Public School (2472)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Hawkesbury</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Hawkesbury</b>

2472 - Maraylya Public School  
Site Plan (12797)




















1:862

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (73.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Staff Room - (41.99 SQM)	 Office (10)	
B00A - R0006 - Duplicating Workroom - (13.73 SQM)	 Office (3)	
B00A - R0007 - Clerical Office/Workroom - (16.5 SQM)	 Office (4)	
B00A - R0008 - Entry Vestibule - (17.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Sick Bay - (9.69 SQM)	 Student Space (4)	
B00A - R0011 - Principal - (21.6 SQM)	 Office (5)	
B00A - R0013 - Canteen - (13.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (20.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (42.79 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Home Base - (62.71 SQM) - Teaching Space: 1	 Student Space (29)	
B00B - R0003 - Movement - (26.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Practical Activities - 1hb - (13.53 SQM)	 Student Space (6)	
B00B - R0005 - Movement - (52.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (62.32 SQM) - Teaching Space: 1	 Student Space (28)	
B00B - R0007 - Home Base - (68.93 SQM) - Teaching Space: 1	 Student Space (31)	
B00B - R0008 - Practical Activities - 1hb - (9.1 SQM)	 Student Space (4)	
B00C - R0001 - Special Programs Room - (46.77 SQM)	 Student Space (21)	
B00C - R0002 - Movement - (12.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Movement - (12.79 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Movement - (20.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Reading Area - (65.04 SQM)	 Student Space (30)	
B00F - R0001 - Practical Activities - 1hb - (18.92 SQM)	 Student Space (8)	
B00F - R0002 - Practical Activities - 1hb - (18.87 SQM)	 Student Space (8)	
B00F - R0003 - Withdrawal Space - 2hb - (11.57 SQM)	 Student Space (5)	
B00F - R0005 - Home Base - (60.73 SQM) - Teaching Space: 1	 Student Space (28)	
B00F - R0006 - Home Base - (60.69 SQM) - Teaching Space: 1	 Student Space (28)	