

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Marayong Heights Public School (4282)</b>
<b>AMU REGION:</b>	<b>Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Blacktown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blacktown</b>

4282 - Marayong Heights Public School  
Site Plan (11186)



1:1,077

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0006 - Movement - (24.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0008 - Raised Platform - (53.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (9.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Communal Space - (153.94 SQM)	● Student Space (71)	
B00D - R0015 - Canteen - (27.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (6.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Reading Area - (164.94 SQM)	● Student Space (76)	
B00F - R0001 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0003 - Withdrawal Space - 2hb - (11.54 SQM)	● Student Space (5)	
B00F - R0004 - Home Base - (60.06 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0006 - Practical Activities - 1hb - (18.91 SQM)	● Student Space (8)	
B00F - R0007 - Practical Activities - 1hb - (18.96 SQM)	● Student Space (8)	
B0AA - R0002 - Practical Activities - 1hb - (20 SQM)	● Student Space (9)	
B0AA - R0003 - Home Base - (62.89 SQM) - Teaching Space: 1	● Student Space (29)	
B0AA - R0004 - Withdrawal Space - 2hb - (11.09 SQM)	● Student Space (5)	
B0AA - R0005 - Home Base - (62.68 SQM) - Teaching Space: 1	● Student Space (29)	
B0AA - R0006 - Practical Activities - 1hb - (19.61 SQM)	● Student Space (9)	
B0AA - R0009 - Practical Activities - 1hb - (19.59 SQM)	● Student Space (9)	
B0AA - R0010 - Home Base - (62.82 SQM) - Teaching Space: 1	● Student Space (29)	
B0AA - R0011 - Withdrawal Space - 2hb - (11.1 SQM)	● Student Space (5)	
B0AA - R0012 - Home Base - (62.84 SQM) - Teaching Space: 1	● Student Space (29)	
B0AA - R0013 - Practical Activities - 1hb - (20.07 SQM)	● Student Space (9)	
B0AA - R0020 - Staff Room Annexe - (20.64 SQM)	● Office (5)	
B0AA - R0021 - Staff Room - (44.48 SQM)	● Office (11)	
B0AA - R0024 - Deputy Principal - (13.26 SQM)	● Office (3)	
B0AA - R0025 - Deputy Principal - (13.15 SQM)	● Office (3)	
B0AA - R0026 - Interview - (13.15 SQM)	● Office (3)	
B0AA - R0028 - Sick Bay - (8.24 SQM)	● Student Space (3)	
B0AA - R0029 - Clerical Office - (17.74 SQM)	● Office (4)	
B0AA - R0030 - Entry Vestibule - (24.09 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0032 - Principal - (16.79 SQM)	● Office (4)	
B0AA - R0037 - Movement - (36.02 SQM)	Not Applicable	Circulation or storage space.
B0AA - R0038 - Clerical Office - (12.75 SQM)	● Office (3)	
B0AA - R0039 - Sick Bay - (6.69 SQM)	● Student Space (3)	
BOCC - R0006 - Special Programs Room - (32.5 SQM)	● Student Space (15)	
BOCC - R0013 - Home Base - (99.61 SQM) - Teaching Space: 1	● Student Space (46)	
BOCC - R0014 - Special Programs Room - (71.8 SQM)	● Student Space (33)	
BOI1 - R0027 - Home Base - (50.27 SQM) - Teaching Space: 1	● Student Space (23)	
BOI1 - R0028 - Withdrawal Space - 2hb - (8.51 SQM)	● Student Space (3)	
BOI1 - R0029 - Home Base - (50.46 SQM) - Teaching Space: 1	● Student Space (23)	
BOI1 - R0033 - Home Base - (64.52 SQM) - Teaching Space: 1	● Student Space (29)	
BOI1 - R0034 - Withdrawal Space - 2hb - (9.15 SQM)	● Student Space (4)	
BOI1 - R0035 - Home Base - (50.53 SQM) - Teaching Space: 1	● Student Space (23)	
BOI1 - R0037 - Practical Activities - 1hb - (22.95 SQM)	● Student Space (10)	
BOI1 - R0038 - Practical Activities - 1hb - (22.75 SQM)	● Student Space (10)	
BOI1 - R0039 - Practical Activities - 1hb - (29.21 SQM)	● Student Space (13)	
BOI1 - R0040 - Practical Activities - 1hb - (22.55 SQM)	● Student Space (10)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B012 - R0011 - Home Base - (50.29 SQM) - Teaching Space: 1	● Student Space (23)	
B012 - R0012 - Practical Activities - 1hb - (22.79 SQM)	● Student Space (10)	
B012 - R0013 - Withdrawal Space - 2hb - (8.86 SQM)	● Student Space (4)	
B012 - R0014 - Home Base - (50.17 SQM) - Teaching Space: 1	● Student Space (23)	
B012 - R0015 - Practical Activities - 1hb - (22.81 SQM)	● Student Space (10)	
OS 603 17454 - OS 603 17454 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	