

VENTILATION AUDIT REPORT

SCHOOL:	Marie Bashir Public School (4652)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Strathfield
LOCAL GOVERNMENT AREA:	Strathfield

4652 - Marie Bashir Public School
Site Plan (14780)



1:778









Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M1004 - Movement - (13.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Clerical Office - (8.62 SQM)	Office (2)	
B00A - R0006 - Clerical Office - (8.62 SQM)	Office (2)	
B00A - R0008 - Movement - (21.45 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Practical Activities - (7.91 SQM)	Student Space (3)	
B00A - R0034 - Movement - (13.1 SQM)	Not Applicable	Circulation or storage space.
B00A - R0054 - Movement - (35.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0055 - Home Base - (97.62 SQM) - Teaching Space: 1	Student Space (45)	
B00A - R0056 - Practical Activities - (29.69 SQM)	Student Space (13)	
B00A - R0057 - Withdrawal Space - 2hb - (18.07 SQM)	Student Space (8)	
B00A - R0058 - Home Base - (78.77 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0059 - Home Base - (79.45 SQM) - Teaching Space: 1	Student Space (36)	
B00A - R0060 - Withdrawal Space - 2hb - (9.82 SQM)	Student Space (4)	
B00A - R0061 - Practical Activities - (25.09 SQM)	Student Space (11)	
B00A - R0062 - Home Base - (101.8 SQM) - Teaching Space: 1	Student Space (47)	
B00A - R1007 - Raised Platform - (214.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1008 - Communal Space - (762.25 SQM)	Student Space (353)	
B00A - R1011 - Movement - (167.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R1024 - Movement - (8.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R2001 - Communal Space - (141.53 SQM)	Student Space (65)	
B00A - R2004 - Movement - (59.77 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Clerical Office/Workroom - (41.91 SQM)	Office (10)	
B00B - R0008 - Entry Vestibule - (30.06 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Sick Bay - (6.54 SQM)	Student Space (3)	
B00B - R0013 - Sick Bay - (6.57 SQM)	Student Space (3)	
B00B - R0014 - Movement - (13.55 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Movement - (55.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Interview - (9 SQM)	Office (2)	
B00B - R0017 - Principal - (26.88 SQM)	Office (6)	
B00B - R0022 - Staff Room - (50.74 SQM)	Office (12)	
B00B - R0025 - Deputy Principal - (16.18 SQM)	Office (4)	
B00B - R0026 - Special Programs Room - (36.43 SQM)	Student Space (16)	
B00B - R0027 - Practical Activities - (5.97 SQM)	Student Space (2)	
B00B - R0028 - Home Base - (70.88 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R0029 - Practical Activities - (7.5 SQM)	Student Space (3)	
B00B - R0030 - Home Base - (60.36 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R0031 - Practical Activities - (8.24 SQM)	Student Space (3)	
B00B - R0032 - Home Base - (64.95 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0033 - Home Base - (65.84 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0034 - Home Base - (79.31 SQM) - Teaching Space: 1	Student Space (36)	
B00B - R0036 - Withdrawal Space - 2hb - (10.71 SQM)	Student Space (4)	
B00B - R0041 - Movement - (8 SQM)	Not Applicable	Circulation or storage space.
B00B - R0062 - Home Base - (55.53 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0064 - Practical Activities - 1hb - (11.62 SQM)	Student Space (5)	
B00B - R0065 - Home Base - (55.74 SQM) - Teaching Space: 1	Student Space (25)	
B00B - R0066 - Withdrawal Space - 1hb - (9.98 SQM)	Student Space (4)	
B00B - R0067 - Home Base - (88.23 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R1025 - Practical Activities - 1hb - (12.83 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1026 - Home Base - (61.11 SQM) - Teaching Space: 1	Student Space (28)	
B00B - R1030 - Home Base - (57.92 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1031 - Practical Activities - 1hb - (12.3 SQM)	Student Space (5)	
B00B - R1033 - Practical Activities - 1hb - (13.01 SQM)	Student Space (6)	
B00B - R1035 - Home Base - (63.92 SQM) - Teaching Space: 1	Student Space (29)	
B00B - R1036 - Home Base - (29.2 SQM) - Teaching Space: 1	Student Space (13)	
B00B - R1040 - Home Base - (58.08 SQM) - Teaching Space: 1	Student Space (26)	
B00B - R1041 - Movement - (23.43 SQM)	Not Applicable	Circulation or storage space.
B00B - R1042 - Practical Activities - (12.5 SQM)	Student Space (5)	
B00B - R1043 - Home Base - (156.75 SQM) - Teaching Space: 1	Student Space (72)	
B00B - R1044 - Practical Activities - (34.48 SQM)	Student Space (15)	
B00B - R1045 - Withdrawal Space - 1hb - (11.88 SQM)	Student Space (5)	
B00B - R1046 - Home Base - (87.99 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R1047 - Practical Activities - (20.71 SQM)	Student Space (9)	
B00B - R1048 - Withdrawal Space - 1hb - (9.03 SQM)	Student Space (4)	
B00B - R9011 - Movement - (16.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R9022 - Movement - (17.02 SQM)	Not Applicable	Circulation or storage space.
B00B - R9023 - Movement - (17.82 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Canteen - (51.31 SQM)	Not Applicable	Circulation or storage space.
B00C - R0012 - Movement - (26.52 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Home Base - (51.07 SQM) - Teaching Space: 1	Student Space (23)	
B00C - R0014 - Practical Activities - 1hb - (11.52 SQM)	Student Space (5)	
B00C - R0015 - Home Base/Practical Activities - (62.63 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0016 - Practical Activities - 1hb - (10.7 SQM)	Student Space (4)	
B00C - R1006 - Reading Area - (277.89 SQM)	Student Space (128)	
B00C - R1009 - Movement - (6.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R2015 - Movement - (40.95 SQM)	Not Applicable	Circulation or storage space.
B00C - R2016 - Practical Activities - (29.58 SQM)	Student Space (13)	
B00C - R2017 - Home Base - (67.36 SQM) - Teaching Space: 1	Student Space (31)	
B00C - R2018 - Withdrawal Space - 2hb - (15.14 SQM)	Student Space (7)	
B00C - R2019 - Home Base - (56.85 SQM) - Teaching Space: 1	Student Space (26)	
B00C - R2020 - Withdrawal Space - 2hb - (15.17 SQM)	Student Space (7)	
B00C - R2021 - Home Base - (76.58 SQM) - Teaching Space: 1	Student Space (35)	
B00C - R2022 - Practical Activities - (28.66 SQM)	Student Space (13)	
B00C - R2023 - Practical Activities - (24.26 SQM)	Student Space (11)	
B00C - R2025 - Movement - (9.08 SQM)	Not Applicable	Circulation or storage space.
B00D - R0014 - Home Base - (70.48 SQM) - Teaching Space: 1	Student Space (32)	
B00D - R0015 - Practical Activities - (19.38 SQM)	Student Space (8)	
B00D - R0016 - Withdrawal Space - 1hb - (10.91 SQM)	Student Space (5)	
B00D - R0017 - Withdrawal Space - 1hb - (10.55 SQM)	Student Space (4)	
B00D - R0018 - Practical Activities - (16.12 SQM)	Student Space (7)	
B00D - R0019 - Home Base - (60.81 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0025 - Movement - (5.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R1010 - Home Base - (78.52 SQM) - Teaching Space: 1	Student Space (36)	
B00D - R1011 - Withdrawal Space - 1hb - (11.84 SQM)	Student Space (5)	
B00D - R1012 - Home Base - (68.05 SQM) - Teaching Space: 1	Student Space (31)	
B00D - R1013 - Withdrawal Space - 2hb - (11.84 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1014 - Home Base - (67.55 SQM) - Teaching Space: 1	 Student Space (31)	
B00D - R1015 - Practical Activities - (35.63 SQM)	 Student Space (16)	
B00D - R2008 - Home Base - (78.52 SQM) - Teaching Space: 1	 Student Space (36)	
B00D - R2009 - Withdrawal Space - 2hb - (11.84 SQM)	 Student Space (5)	
B00D - R2010 - Home Base - (68.05 SQM) - Teaching Space: 1	 Student Space (31)	
B00D - R2011 - Withdrawal Space - 1hb - (11.84 SQM)	 Student Space (5)	
B00D - R2012 - Home Base - (67.55 SQM) - Teaching Space: 1	 Student Space (31)	
B00D - R2013 - Practical Activities - (35.63 SQM)	 Student Space (16)	