

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Marks Point Public School (3898)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Swansea</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Lake Macquarie</b>

3898 - Marks Point Public School  
Site Plan (10471)



1:706

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (24.1 SQM)	Office (6)	
B00A - R0003 - Movement - (6.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Duplicating Workroom - (7.42 SQM)	Office (1)	
B00A - R0006 - Clerical Office - (16.79 SQM)	Office (4)	
B00A - R0008 - Entry Vestibule - (16.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Movement - (6.38 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal - (16.75 SQM)	Office (4)	
B00B - R0001 - Home Base - (66.04 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0004 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (65.79 SQM) - Teaching Space: 1	Student Space (30)	
B00B - R0012 - Raised Platform - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Communal Space - (56.68 SQM)	Student Space (26)	
B00B - R0015 - Home Base - (95.02 SQM) - Teaching Space: 1	Student Space (44)	
B00C - R0001 - Canteen - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Movement - (27.57 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Communal Space - (111.46 SQM)	Student Space (51)	
B00E - R0002 - Withdrawal Space - 1hb - (11.17 SQM)	Student Space (5)	
B00E - R0004 - Movement - (77.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Home Base - (53.48 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - Home Base - (53.48 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0008 - Withdrawal Space - 1hb - (11.08 SQM)	Student Space (5)	
B00E - R0009 - Home Base - (53.41 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0010 - Home Base - (53.48 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0004 - Home Base - (52.3 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0005 - Movement - (26.61 SQM)	Not Applicable	Circulation or storage space.
B00G - R0006 - Home Base - (52.32 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0002 - Communal Space - (142.32 SQM)	Student Space (66)	
B00H - R0003 - Movement - (5.51 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Raised Platform - (61.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (13.46 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Reading Area - (95.55 SQM)	Student Space (44)	
OS 523 10258 - OS 523 10258 - Staff Study With Toilets - (76 SQM)	Office (19)	