

VENTILATION AUDIT REPORT

SCHOOL:	Marrickville High School (8540)
AMU REGION:	Sydney
STATE ELECTORATE:	Summer Hill
LOCAL GOVERNMENT AREA:	Inner West

8540 - Marrickville High School
Site Plan (12799)



1:1,166

Printed: 01-May-2021




Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - M0001 - Movement - (59.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Movement - (10.29 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (196.41 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - General Assistants - (8.24 SQM)	Office (2)	
B00A - R0020 - Multi-Purpose Space - (106.57 SQM)	Student Space (49)	
B00A - R0024 - Movement - (48 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Movement - (33.66 SQM)	Not Applicable	Circulation or storage space.
B00A - R0033 - Multi-Purpose Space - (415.06 SQM)	Student Space (192)	
B00A - R0035 - Movement - (35.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0039 - Student Canteen - (38.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0043 - Movement - (17.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Food Technology L.S. - (80.04 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R1002 - Food/Research Space - (15.99 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Food/Research Space - (14.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R1004 - Food Technology L.S. - (80.39 SQM) - Teaching Space: 1	Student Space (37)	
B00A - R1008 - Staff Study - (36.68 SQM)	Office (9)	
B00A - R1011 - Design L.S. - (64.1 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1012 - Computer Learning Space - (64.34 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R1015 - Computer Learning Space - (64.91 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1020 - Study Space - (22.24 SQM)	Not Applicable	Circulation or storage space.
B00A - R1023 - Movement - (165.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R2001 - Special Learning Space - (67.74 SQM) - Teaching Space: 1	Student Space (31)	
B00A - R2002 - Staff Study - (12.45 SQM)	Office (3)	
B00A - R2003 - Commonroom - (16.07 SQM)	Office (4)	
B00A - R2009 - General Learning Space - (65.28 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R2012 - General Learning Space - (65.49 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R2013 - Darkroom Space - (26.94 SQM)	Office (6)	
B00A - R2014 - Staff Study - (36.55 SQM)	Office (9)	
B00A - R2016 - Art Learning Space - (64.93 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R2017 - Art Learning Space - (66.01 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R2018 - Art Learning Space - (83.06 SQM) - Teaching Space: 1	Student Space (38)	
B00A - R2020 - Art Learning Space - (60.61 SQM) - Teaching Space: 1	Student Space (28)	
B00A - R2024 - Movement - (158.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R2028 - General Learning Space - (31.98 SQM) - Teaching Space: 1	Student Space (14)	
B00A - R2029 - General Learning Space - (31.76 SQM) - Teaching Space: 1	Student Space (14)	
B00A - R2030 - Staff Study - (14.66 SQM)	Office (3)	
B00A - R2031 - General Learning Space - (80.58 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0006 - Movement - (22.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0011 - Materials Technology L.S. - (129.8 SQM)	Student Space (60)	
B00B - R0012 - Materials Technology L.S. - (118.02 SQM) - Teaching Space: 1	Student Space (54)	
B00B - R1001 - Music Learning Space - (100.03 SQM) - Teaching Space: 1	Student Space (46)	
B00B - R1005 - Music Learning Space - (82.39 SQM) - Teaching Space: 1	Student Space (38)	
B00B - R1006 - Staff Study - (32.06 SQM)	Office (8)	
B00B - R1007 - Movement - (22.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Movement - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Staff Study - (21.99 SQM)	Office (5)	
B00D - R0001 - Materials Technology L.S. - (81.75 SQM) - Teaching Space: 1	Student Space (37)	
B00D - R0003 - Welding Area - (5.78 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Materials Technology L.S. - (82.92 SQM) - Teaching Space: 1	Student Space (38)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0005 - Metal Technology Bay - (31.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Movement - (8.7 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Movement - (16.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - General Learning Space - (53.3 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1002 - Duplicating Workroom - (25.43 SQM)	● Office (6)	
B00D - R1003 - General Learning Space - (53.22 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R1004 - Movement - (43.64 SQM)	Not Applicable	Circulation or storage space.
B00D - R1005 - Movement - (13.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Interview/Office - Type 1 - (15.94 SQM)	● Office (3)	
B00E - R0007 - Movement - (70.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (13.29 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Movement - (15.32 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - Staff Study - (41.58 SQM)	● Office (10)	
B00E - R1004 - Interview/Office - Type 1 - (15.68 SQM)	● Office (3)	
B00E - R1008 - Movement - (42.71 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (83.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R1001 - Interview/Office - Type 1 - (11.41 SQM)	● Office (2)	
B00F - R1004 - Movement - (11.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R1007 - General Learning Space - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0003 - General Learning Space - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0004 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00G - R0008 - Leading Teacher - (15.13 SQM)	● Office (3)	
B00G - R0009 - Public Entry - (16.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Clerical Office - (27.84 SQM)	● Office (6)	
B00G - R0012 - Staff Study - (51.61 SQM)	● Office (12)	
B00G - R0014 - Movement - (26.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0015 - Movement - (19.6 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - General Learning Space - (38.47 SQM) - Teaching Space: 1	● Student Space (17)	
B00G - R1007 - Movement - (50.5 SQM)	Not Applicable	Circulation or storage space.
B00G - R1008 - General Learning Space - (38.75 SQM) - Teaching Space: 1	● Student Space (17)	
B00G - R1009 - General Learning Space - (39.97 SQM) - Teaching Space: 1	● Student Space (18)	
B00G - R1010 - General Learning Space - (39.47 SQM) - Teaching Space: 1	● Student Space (18)	
B00G - R1011 - General Learning Space - (39.47 SQM) - Teaching Space: 1	● Student Space (18)	
B00H - M0001 - Main Area - (216.74 SQM)	Not Applicable	Circulation or storage space.
B00H - M0004 - Audio Visual Workroom - (8.04 SQM)	● Student Space (3)	
B00H - M0008 - Workroom - (38.4 SQM)	● Office (9)	
B00H - M0009 - Workroom - (31.64 SQM)	● Office (7)	
B00H - R0002 - Principal Office - (20.86 SQM)	● Office (5)	
B00H - R0006 - Interview/Meeting - (23.64 SQM)	● Office (5)	
B00H - R0007 - Commonroom - (124.94 SQM)	● Office (31)	
B00H - R0008 - Commonroom - (7.13 SQM)	● Office (1)	
B00H - R0013 - Clinic-Waiting - (14.47 SQM)	● Office (3)	
B00H - R0017 - Movement - (21.82 SQM)	Not Applicable	Circulation or storage space.
B00H - R0018 - Leading Teacher - (20.48 SQM)	● Office (5)	
B00H - R0019 - Ancillary Staff - (11.31 SQM)	● Office (2)	
B00H - R0023 - Administration - Clerical - (37.16 SQM)	● Office (9)	
B00H - R0024 - Staff Study - (26.42 SQM)	● Office (6)	
B00H - R0026 - Administration - Clerical - (16.28 SQM)	● Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0028 - Deputy Principal Office - (15.29 SQM)	Office (3)	
B00H - R0029 - Workroom - (15.31 SQM)	Office (3)	
B00H - R0033 - Main Area - (320.44 SQM)	Not Applicable	Circulation or storage space.
B00H - R0035 - General Learning Space - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0036 - General Learning Space - (52.29 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0037 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0038 - General Learning Space - (52.65 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R0040 - Movement - (47.04 SQM)	Not Applicable	Circulation or storage space.
B00H - R0048 - Deputy Principal Office - (25.8 SQM)	Office (6)	
B00H - R0049 - Movement - (5.63 SQM)	Not Applicable	Circulation or storage space.
B00H - R0050 - Staff Study - (13 SQM)	Office (3)	
B00H - R0052 - Movement - (13.08 SQM)	Not Applicable	Circulation or storage space.
B00H - R0053 - Public Entry - (47.01 SQM)	Not Applicable	Circulation or storage space.
B00H - R0054 - Movement - (397.41 SQM)	Not Applicable	Circulation or storage space.
B00H - R0055 - Movement - (25.81 SQM)	Not Applicable	Circulation or storage space.
B00H - R0058 - Entry - (10.78 SQM)	Not Applicable	Circulation or storage space.
B00H - R0066 - Movement - (60.07 SQM)	Not Applicable	Circulation or storage space.
B00H - R1001 - Laboratory L.S. - (93.13 SQM) - Teaching Space: 1	Student Space (43)	
B00H - R1002 - Preparation - (12.19 SQM)	Not Applicable	Circulation or storage space.
B00H - R1004 - Preparation - (33.05 SQM)	Not Applicable	Circulation or storage space.
B00H - R1005 - Laboratory L.S. - (93.24 SQM) - Teaching Space: 1	Student Space (43)	
B00H - R1008 - General Learning Space - (47.16 SQM) - Teaching Space: 1	Student Space (21)	
B00H - R1009 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1010 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1011 - General Learning Space - (52.79 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1012 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R1016 - Laboratory L.S. - (94.76 SQM) - Teaching Space: 1	Student Space (43)	
B00H - R1018 - Laboratory L.S. - (88.27 SQM) - Teaching Space: 1	Student Space (40)	
B00H - R1019 - Preparation - (12.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R1021 - Preparation - (30.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R1024 - Movement - (346.62 SQM)	Not Applicable	Circulation or storage space.
B00H - R1025 - Movement - (15.58 SQM)	Not Applicable	Circulation or storage space.
B00H - R1029 - Staff Study - (46.59 SQM)	Office (11)	
B00H - R2001 - General Learning Space - (93.33 SQM) - Teaching Space: 1	Student Space (43)	
B00H - R2002 - Special Learning Space - (50.55 SQM) - Teaching Space: 1	Student Space (23)	
B00H - R2003 - Special Learning Space - (67.33 SQM) - Teaching Space: 1	Student Space (31)	
B00H - R2004 - Staff Study - (15.34 SQM)	Office (3)	
B00H - R2005 - Staff Study - (9.03 SQM)	Office (2)	
B00H - R2008 - General Learning Space - (47.22 SQM) - Teaching Space: 1	Student Space (21)	
B00H - R2009 - General Learning Space - (52.8 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R2010 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R2011 - General Learning Space - (52.86 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R2012 - General Learning Space - (52.94 SQM) - Teaching Space: 1	Student Space (24)	
B00H - R2016 - General Learning Space - (40.41 SQM) - Teaching Space: 1	Student Space (18)	
B00H - R2017 - Seminar - Type 1 - (12.82 SQM)	Office (3)	
B00H - R2018 - Seminar - Type 1 - (13.29 SQM)	Office (3)	
B00H - R2019 - Staff Study - (69.3 SQM)	Office (17)	
B00H - R2020 - Staff Study - (13 SQM)	Office (3)	
B00H - R2022 - Laboratory L.S. - (94.05 SQM) - Teaching Space: 1	Student Space (43)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R2024 - Laboratory L.S. - (89.22 SQM) - Teaching Space: 1	 Student Space (41)	
B00H - R2025 - Preparation - (11.67 SQM)	Not Applicable	Circulation or storage space.
B00H - R2027 - Preparation - (30.28 SQM)	Not Applicable	Circulation or storage space.
B00H - R2030 - Movement - (334.18 SQM)	Not Applicable	Circulation or storage space.
B00H - R2035 - Staff Study - (46.59 SQM)	 Office (11)	
B00H - R2037 - Staff Study - (13.54 SQM)	 Office (3)	