

VENTILATION AUDIT REPORT

SCHOOL:	Marsden High School (8225)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ryde
LOCAL GOVERNMENT AREA:	Ryde




















Siteplan

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Food Technology L.S. - (64.14 SQM) - Teaching Space: 1	Student Space (29)	
B00A - R0010 - Staff Study - (25.07 SQM)	Office (6)	
B00A - R0013 - Laboratory L.S. - (88.48 SQM) - Teaching Space: 1	Student Space (41)	
B00A - R0014 - Preparation - Science - (27.42 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Food Technology L.S. - (38.61 SQM) - Teaching Space: 1	Student Space (17)	
B00A - R0017 - Food Technology L.S. - (91.3 SQM) - Teaching Space: 1	Student Space (42)	
B00A - R0019 - Preparation - Materials - (16.74 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (143.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Materials Technology L.S. - (65.15 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1004 - Computer Learning Space - (65.26 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1006 - Computer Learning Space - (65.33 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1007 - Practice/Seminar - (19.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R1010 - General Learning Space - (64.74 SQM) - Teaching Space: 1	Student Space (30)	
B00A - R1011 - Performance Workshop - (65.1 SQM)	Student Space (30)	
B00A - R1016 - Movement - (94.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R1017 - Movement - (21.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Leading Teacher - (18.55 SQM)	Office (4)	
B00B - R0003 - Laboratory L.S. - (87.18 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0005 - Laboratory L.S. - (87.18 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0013 - Preparation - Science - (38.76 SQM)	Not Applicable	Circulation or storage space.
B00B - R0014 - Music Learning Space - (80.86 SQM) - Teaching Space: 1	Student Space (37)	
B00B - R0019 - Movement - (88.3 SQM)	Not Applicable	Circulation or storage space.
B00B - R1003 - Staff Study - (21.79 SQM)	Office (5)	
B00B - R1004 - General Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1005 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1006 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1007 - General Learning Space - (52.01 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1008 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1012 - Movement - (87.42 SQM)	Not Applicable	Circulation or storage space.
B00B - R1016 - General Learning Space - (82.21 SQM) - Teaching Space: 1	Student Space (38)	
B00C - R0004 - Deputy Principal Office - (14.89 SQM)	Office (3)	
B00C - R0006 - Deputy Principal Office - (14.85 SQM)	Office (3)	
B00C - R0007 - Administration - Clerical - (5.58 SQM)	Office (1)	
B00C - R0008 - Administration - Clerical - (11.64 SQM)	Office (2)	
B00C - R0009 - Principal Office - (16.73 SQM)	Office (4)	
B00C - R0016 - Clinic - (8.09 SQM)	Office (2)	
B00C - R0021 - Public Reception - (33.99 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Administration - Clerical - (34.5 SQM)	Office (8)	
B00C - R0024 - Ancillary Staff - (14.88 SQM)	Office (3)	
B00C - R0031 - Movement - (43.73 SQM)	Not Applicable	Circulation or storage space.
B00C - R0035 - Computer Learning Space - (42.38 SQM) - Teaching Space: 1	Student Space (19)	
B00C - R1001 - General Learning Space - (65.68 SQM) - Teaching Space: 1	Student Space (30)	
B00C - R1005 - General Learning Space - (52.08 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1006 - General Learning Space - (51.86 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R1009 - Interview/Office - Type 1 - (19.09 SQM)	Office (4)	
B00C - R1012 - Staff Study - (23.12 SQM)	Office (5)	
B00C - R1014 - Movement - (77.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - General Learning Space - (65.13 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0012 - Movement - (130.62 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0014 - General Learning Space - (51.36 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R0016 - Staff Study - (25.61 SQM)	○ Office (6)	
B00D - R0017 - Staff Study - (22.56 SQM)	○ Office (5)	
B00D - R0019 - Staff Study - (49.87 SQM)	○ Office (12)	
B00D - R0020 - Tea Room - (15.41 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Interview/Office - Type 1 - (17.09 SQM)	○ Office (4)	
B00D - R1002 - General Learning Space - (65.87 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1003 - General Learning Space - (65.44 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1004 - General Learning Space - (65.15 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1005 - General Learning Space - (65.66 SQM) - Teaching Space: 1	● Student Space (30)	
B00D - R1008 - Movement - (103.62 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Interview/Office - Type 1 - (9.82 SQM)	○ Office (2)	
B00E - R0010 - General Learning Space - (38.84 SQM) - Teaching Space: 1	● Student Space (18)	
B00E - R0011 - General Learning Space - (38.86 SQM) - Teaching Space: 1	● Student Space (18)	
B00E - R0012 - General Learning Space - (51.35 SQM) - Teaching Space: 1	● Student Space (23)	
B00E - R0013 - Movement - (74.77 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Staff Study - (65.07 SQM)	○ Office (16)	
B00E - R0016 - Commonroom - (139.93 SQM)	○ Office (34)	
B00E - R0017 - Staff Kitchen - (16.53 SQM)	○ Office (4)	
B00E - R1001 - General Learning Space - (52.51 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1002 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1004 - General Learning Space - (65.13 SQM) - Teaching Space: 1	● Student Space (30)	
B00E - R1007 - Interview/Office - Type 1 - (19.05 SQM)	○ Office (4)	
B00E - R1009 - General Learning Space - (51.93 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1010 - General Learning Space - (51.86 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1011 - General Learning Space - (52.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00E - R1012 - Movement - (101.85 SQM)	Not Applicable	Circulation or storage space.
B00F - R0002 - Staff Study - (18.88 SQM)	○ Office (4)	
B00F - R0011 - Design L.S. - (71.76 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0013 - Movement - (6.07 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Metal Technology L.S. - (72.2 SQM) - Teaching Space: 1	● Student Space (33)	
B00F - R0017 - Metal Technology Bay - (16.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0019 - Wood Technology L.S. - (75.65 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0021 - Wood Technology L.S. - (75.76 SQM) - Teaching Space: 1	● Student Space (35)	
B00F - R0023 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B00G - M0001 - Senior Study - (114.55 SQM)	○ Office (28)	
B00G - R0001 - Main Area - (195.9 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Main Entry - (61.03 SQM)	Not Applicable	Circulation or storage space.
B00G - R0007 - Audio Visual Workroom - (36.94 SQM)	● Student Space (17)	
B00G - R0009 - Movement - (22.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Study Space - (39.83 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - General Assistants - (16.85 SQM)	○ Office (4)	
B00H - R1007 - Staff Study - (27.02 SQM)	○ Office (6)	
B00H - R2005 - Staff Study - (27.53 SQM)	○ Office (6)	
B00H - R2008 - Staff Study - (25.43 SQM)	○ Office (6)	
B00I - R0001 - Student Canteen - (35.26 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Laboratory L.S. - (93.77 SQM) - Teaching Space: 1	● Student Space (43)	
B00J - R0002 - Preparation - Science - (29.23 SQM)	Not Applicable	Circulation or storage space.
B00J - R1001 - Art Learning Space - (79.93 SQM) - Teaching Space: 1	● Student Space (37)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00J - R1002 - Dark Room - (26.47 SQM)	 Office (6)	
B00J - R1003 - Multi Media Studio - (26.07 SQM)	Not Applicable	Circulation or storage space.
B00J - R1008 - Staff Study - (21.95 SQM)	 Office (5)	
B00J - R2001 - Art Learning Space - (59.29 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R2004 - Art Learning Space - (52.94 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R0001 - Laboratory L.S. - (92.6 SQM) - Teaching Space: 1	 Student Space (42)	
B00K - R0004 - Laboratory L.S. - (93.38 SQM) - Teaching Space: 1	 Student Space (43)	
B00K - R0011 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00K - R0015 - Preparation - Science - (30.13 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - General Learning Space - (52.21 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R1002 - General Learning Space - (52.95 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R1003 - General Learning Space - (52.94 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R1006 - General Learning Space - (53.24 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R1012 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00K - R2001 - General Learning Space - (52.36 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R2002 - General Learning Space - (52.87 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R2003 - General Learning Space - (52.87 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R2006 - Computer Learning Space - (53.38 SQM) - Teaching Space: 1	 Student Space (24)	
B00K - R2012 - Movement - (11.31 SQM)	Not Applicable	Circulation or storage space.
B00K - R2016 - Staff Study - (26.76 SQM)	 Office (6)	
B00L - M0003 - Movement - (164.58 SQM)	Not Applicable	Circulation or storage space.
B00L - M0006 - Movement - (17.93 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Stage - (109.45 SQM)	Not Applicable	Circulation or storage space.
B00L - R0004 - Multi-Purpose Space - (332.29 SQM)	 Student Space (154)	
B00L - R0006 - Staff Kitchen - (11.84 SQM)	 Office (2)	
B00L - R0007 - Movement - (19.32 SQM)	Not Applicable	Circulation or storage space.
B00L - R9013 - Movement - (9.04 SQM)	Not Applicable	Circulation or storage space.
B00L - R9020 - Movement - (9.12 SQM)	Not Applicable	Circulation or storage space.
OS 600 12115 - OS 600 12115 - Learning Unit - Small - (57 SQM)	 Student Space (26)	
OS 600 16268 - OS 600 16268 - Learning Unit - Small - (57 SQM)	 Student Space (26)	