

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Marton Public School (4431)</b>
<b>AMU REGION:</b>	<b>Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Heathcote</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Sutherland</b>

4431 - Marton Public School  
Site Plan (12804)



Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Duplicating Workroom - (14.24 SQM)	Office (3)	
B00A - R0006 - Clerical Office - (13.21 SQM)	Office (3)	
B00A - R0007 - Clerical Office - (12.71 SQM)	Office (3)	
B00A - R0008 - Movement - (7.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Entry Vestibule - (27.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Staff Room Annexe - (14.28 SQM)	Office (3)	
B00A - R0014 - Movement - (20.77 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Canteen - (27.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Staff Room - (59.2 SQM)	Office (14)	
B00A - R1003 - Movement - (9.13 SQM)	Not Applicable	Circulation or storage space.
B00A - R1005 - Movement - (23.26 SQM)	Not Applicable	Circulation or storage space.
B00A - R1009 - Staff Room Annexe - (13 SQM)	Office (3)	
B00A - R1012 - Principal - (19.73 SQM)	Office (4)	
B00A - R1013 - Deputy Principal - (19.43 SQM)	Office (4)	
B00B - R0001 - Home Base - (88.36 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0002 - Home Base - (88.37 SQM) - Teaching Space: 1	Student Space (40)	
B00B - R0009 - Movement - (6.28 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (38.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0015 - Practical Activities - 1hb - (32.06 SQM)	Student Space (14)	
B00B - R0016 - Home Base - (70.88 SQM) - Teaching Space: 1	Student Space (32)	
B00B - R1005 - Movement - (11.41 SQM)	Not Applicable	Circulation or storage space.
B00B - R1008 - Home Base - (67.75 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R1009 - Home Base - (67.75 SQM) - Teaching Space: 1	Student Space (31)	
B00B - R1012 - Movement - (10.84 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Home Base - (60.04 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0002 - Home Base - (60.27 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0003 - Movement - (8.65 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (7.02 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Movement - (8.26 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Movement - (31.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0013 - Movement - (12.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Home Base - (54.1 SQM) - Teaching Space: 1	Student Space (25)	
B00C - R1005 - Movement - (10 SQM)	Not Applicable	Circulation or storage space.
B00C - R1008 - Home Base - (60.59 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1009 - Home Base - (60.43 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R1012 - Movement - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00C - R1013 - Withdrawal Space - 1hb - (19.53 SQM)	Student Space (9)	
B00D - R0001 - Home Base - (65.51 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R0002 - Practical Activities - 1hb - (20.81 SQM)	Student Space (9)	
B00D - R0004 - Movement - (8.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - Movement - (48.5 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Home Base - (51.1 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0011 - Practical Activities - 1hb - (18.72 SQM)	Student Space (8)	
B00D - R0012 - Home Base - (51.1 SQM) - Teaching Space: 1	Student Space (23)	
B00D - R0013 - Practical Activities - 1hb - (18.72 SQM)	Student Space (8)	
B00D - R0016 - Practical Activities - 1hb - (20.94 SQM)	Student Space (9)	
B00D - R0017 - Home Base - (65.59 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1004 - Movement - (14.87 SQM)	Not Applicable	Circulation or storage space.
B00D - R1008 - Practical Activities - 1hb - (18.72 SQM)	Student Space (8)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R1009 - Home Base - (51.1 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1010 - Home Base - (51.1 SQM) - Teaching Space: 1	● Student Space (23)	
B00D - R1011 - Practical Activities - 1hb - (18.72 SQM)	● Student Space (8)	
B00D - R1013 - Movement - (28.28 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Movement - (5.74 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Movement - (5.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Movement - (46.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0014 - Home Base - (70.09 SQM) - Teaching Space: 1	● Student Space (32)	
B00E - R0015 - Home Base - (57.07 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R0016 - Practical Activities - 1hb - (11.79 SQM)	● Student Space (5)	
B00E - R0019 - Special Programs Room - Type 1 - (76.18 SQM)	● Student Space (35)	
B00E - R0023 - Movement - (12.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0027 - Special Programs Room - Type 1 - (69.22 SQM)	● Student Space (32)	
B00E - R0028 - Staff Kitchen - (10.71 SQM)	● Office (2)	
B00E - R1002 - Movement - (15.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R1004 - Movement - (22.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Practical Activities - 1hb - (12.97 SQM)	● Student Space (6)	
B00E - R1007 - Home Base - (56.5 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1008 - Home Base - (56.51 SQM) - Teaching Space: 1	● Student Space (26)	
B00E - R1009 - Practical Activities - 1hb - (12.98 SQM)	● Student Space (6)	
B00F - R0001 - Reading Area - (200.24 SQM)	● Student Space (92)	
B00F - R0002 - Seminar/Study - (13.05 SQM)	● Office (3)	
B00F - R0008 - Movement - (13.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Communal Space - (239.07 SQM)	● Student Space (110)	