

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mary Brooksbank School (5721)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Campbelltown</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

5721 - Mary Brooksbank School  
Site Plan (11192)



1:1,053

Printed: 13-Oct-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (56.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Movement - (55.52 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Movement - (137.04 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Canteen - (13.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Reading Area - (63.3 SQM)	● Student Space (29)	
B00A - R0011 - Movement - (9.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Movement - (20.97 SQM)	Not Applicable	Circulation or storage space.
B00A - R0015 - Movement - (36.33 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Staff Room Annexe - (19.26 SQM)	● Office (4)	
B00A - R0018 - Staff Room - (44.59 SQM)	● Office (11)	
B00A - R0019 - Staff Room Annexe - (13.4 SQM)	● Office (3)	
B00A - R0022 - Movement - (46.34 SQM)	Not Applicable	Circulation or storage space.
B00A - R0023 - Practical Activities - S - 1hb - (29.72 SQM)	● Student Space (13)	
B00A - R0024 - Home Base - S - (31.21 SQM) - Teaching Space: 1	● Student Space (14)	
B00A - R0025 - Withdrawal - S - (8.79 SQM)	● Student Space (4)	
B00A - R0029 - Practical Activities - S - 1hb - (58.55 SQM)	● Student Space (27)	
B00A - R0030 - Staff Kitchen - (11.65 SQM)	● Office (2)	
B00A - R0031 - Practical Activities - S - 1hb - (29.38 SQM)	● Student Space (13)	
B00A - R0032 - Home Base - S - (31.26 SQM) - Teaching Space: 1	● Student Space (14)	
B00A - R0035 - Withdrawal - S - (8.85 SQM)	● Student Space (4)	
B00A - R0036 - Sick Bay - (15.02 SQM)	● Student Space (6)	
B00A - R0041 - Deputy Principal - (12.98 SQM)	● Office (3)	
B00A - R0042 - Principal - (16.96 SQM)	● Office (4)	
B00A - R0043 - Duplicating Workroom - (20.45 SQM)	● Office (5)	
B00A - R0044 - Entry Vestibule - (12.58 SQM)	Not Applicable	Circulation or storage space.
B00A - R0045 - Clerical Office - (14.91 SQM)	● Office (3)	
B00A - R0046 - Interview - (13.18 SQM)	● Office (3)	
B00A - R0047 - Movement - (31.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Communal Space - (74.86 SQM)	● Student Space (34)	
B00B - R0003 - Movement - (5.24 SQM)	Not Applicable	Circulation or storage space.
B00B - R0010 - Home Base - M - (61.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0011 - Withdrawal - M - (8.82 SQM)	● Student Space (4)	
B00B - R0018 - Practical Activities - M - 1hb - (68.61 SQM)	● Student Space (31)	
B00B - R0019 - Home Base - M - (61.81 SQM) - Teaching Space: 1	● Student Space (28)	
B00B - R0021 - Withdrawal - M - (8.88 SQM)	● Student Space (4)	
B00B - R0024 - Movement - (95.17 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (95.48 SQM)	Not Applicable	Circulation or storage space.
B00C - R0007 - Movement - (21.46 SQM)	Not Applicable	Circulation or storage space.
B00C - R0008 - Withdrawal - S - (5.62 SQM)	● Student Space (2)	
B00C - R0010 - Home Base - S - (61.71 SQM) - Teaching Space: 1	● Student Space (28)	
B00C - R0014 - Home Base - M - (59.96 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0017 - Practical Activities - M - 1hb - (32.3 SQM)	● Student Space (14)	
B00C - R0019 - Withdrawal - M - (5.42 SQM)	● Student Space (2)	
B00C - R0020 - Home Base - M - (60.07 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0021 - Withdrawal - M - (5.38 SQM)	● Student Space (2)	
B00C - R0027 - Practical Activities - M - 1hb - (32.43 SQM)	● Student Space (15)	
B00C - R0029 - Withdrawal - M - (5.59 SQM)	● Student Space (2)	
B00C - R0030 - Home Base - M - (61.87 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00C - R0033 - Movement - (19.58 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Withdrawal Space - 1hb - (8.84 SQM)	● Student Space (4)	
B00D - R0002 - Outdoor Learning Area - (8.52 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Home Base - E - (31.21 SQM) - Teaching Space: 1	● Student Space (14)	
B00D - R0004 - Practical Activities - E - (29.95 SQM)	● Student Space (13)	
B00D - R0006 - Practical Activities - E - (58.55 SQM)	● Student Space (27)	
B00D - R0007 - Staff Kitchen - (11.08 SQM)	● Office (2)	
B00D - R0008 - Practical Activities - E - (30 SQM)	● Student Space (13)	
B00D - R0010 - Home Base - E - (31.26 SQM) - Teaching Space: 1	● Student Space (14)	
B00D - R0012 - Outdoor Learning Area - (8.59 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Withdrawal Space - 1hb - (8.78 SQM)	● Student Space (4)	
B00D - R0014 - Movement - (46.15 SQM)	Not Applicable	Circulation or storage space.
B00D - R0018 - Movement - (44.74 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Raised Platform - (21.62 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Communal Space - (115.58 SQM)	● Student Space (53)	
B00D - R0024 - Movement - (39.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Entry Vestibule - (12.14 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Movement - (21.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Hydrotherapy - Pool - (189.66 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (45.04 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Special Programs Room - Type 1 - (6.24 SQM)	● Student Space (2)	
B00F - R0002 - Special Programs Room - Type 1 - (33.25 SQM)	● Student Space (15)	
OS 522 17436 - OS 522 17436 - Staff Study - (38 SQM)	● Office (9)	
OS 621 11173 - OS 621 11173 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 16022 - OS 621 16022 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 19441 - OS 621 19441 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 19457 - OS 621 19457 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 19536 - OS 621 19536 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	
OS 621 19719 - OS 621 19719 - Learning Unit Single - PWD - (95 SQM)	● Student Space (44)	