

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Maryland Public School (4600)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Wallsend</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

4600 - Maryland Public School  
Site Plan (10484)






1:987

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (9.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Staff Room - (49.21 SQM)	Office (12)	
B00A - R0003 - Staff Room Annexe - (18.95 SQM)	Office (4)	
B00A - R0004 - Movement - (13.89 SQM)	Not Applicable	Circulation or storage space.
B00A - R0005 - Staff Room Annexe - (14.16 SQM)	Office (3)	
B00A - R0006 - Principal - (17.87 SQM)	Office (4)	
B00A - R0007 - Deputy Principal - (12.94 SQM)	Office (3)	
B00A - R0013 - Clerical Office - (18.39 SQM)	Office (4)	
B00A - R0014 - Movement - (19.59 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Sick Bay - (9.24 SQM)	Student Space (4)	
B00A - R0017 - Duplicating Workroom - (23.79 SQM)	Office (5)	
B00A - R0019 - Staff Room Annexe - (14.24 SQM)	Office (3)	
B00A - R0020 - Movement - (21.03 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Entry Vestibule - (13.83 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (112.5 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Canteen - (30.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Movement - (20.86 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Reading Area - (161.6 SQM)	Student Space (74)	
B00C - R0005 - Movement - (28.76 SQM)	Not Applicable	Circulation or storage space.
B00C - R0006 - Special Programs Room - (36.83 SQM)	Student Space (17)	
B00D - R0001 - Movement - (50.79 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Withdrawal Space - 1hb - (5.96 SQM)	Student Space (2)	
B00D - R0005 - Home Base - (60.96 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0006 - Practical Activities - 1hb - (18.7 SQM)	Student Space (8)	
B00D - R0007 - Home Base - (60.88 SQM) - Teaching Space: 1	Student Space (28)	
B00D - R0008 - Practical Activities - 1hb - (18.7 SQM)	Student Space (8)	
B00D - R0009 - Withdrawal Space - 1hb - (6.51 SQM)	Student Space (3)	
B00E - R0001 - Movement - (51 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Withdrawal Space - 1hb - (5.96 SQM)	Student Space (2)	
B00E - R0005 - Home Base - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0006 - Practical Activities - 1hb - (18.7 SQM)	Student Space (8)	
B00E - R0007 - Home Base - (60.89 SQM) - Teaching Space: 1	Student Space (28)	
B00E - R0008 - Practical Activities - 1hb - (18.73 SQM)	Student Space (8)	
B00E - R0009 - Withdrawal Space - 1hb - (6.49 SQM)	Student Space (3)	
B00F - R0001 - Movement - (49.67 SQM)	Not Applicable	Circulation or storage space.
B00F - R0004 - Withdrawal Space - 1hb - (5.96 SQM)	Student Space (2)	
B00F - R0005 - Home Base - (60.8 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0006 - Practical Activities - 1hb - (18.85 SQM)	Student Space (8)	
B00F - R0007 - Home Base - (60.88 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0008 - Practical Activities - 1hb - (18.8 SQM)	Student Space (8)	
B00F - R0009 - Withdrawal Space - 1hb - (6.54 SQM)	Student Space (3)	
B00G - R0001 - Movement - (50.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Withdrawal Space - 1hb - (5.96 SQM)	Student Space (2)	
B00G - R0005 - Home Base - (60.81 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0006 - Practical Activities - 1hb - (18.8 SQM)	Student Space (8)	
B00G - R0007 - Home Base - (60.73 SQM) - Teaching Space: 1	Student Space (28)	
B00G - R0008 - Practical Activities - 1hb - (18.77 SQM)	Student Space (8)	
B00G - R0009 - Withdrawal Space - 1hb - (6.54 SQM)	Student Space (3)	
B00H - R0001 - Movement - (50.95 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0004 - Withdrawal Space - 1hb - (5.94 SQM)	 Student Space (2)	
B00H - R0005 - Home Base - (60.8 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0006 - Practical Activities - 1hb - (18.86 SQM)	 Student Space (8)	
B00H - R0007 - Home Base - (60.8 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0008 - Practical Activities - 1hb - (18.78 SQM)	 Student Space (8)	
B00H - R0009 - Withdrawal Space - 1hb - (6.5 SQM)	 Student Space (3)	
B00I - R0001 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00I - R0004 - Movement - (9.45 SQM)	Not Applicable	Circulation or storage space.
B00I - R0005 - Raised Platform - (49.37 SQM)	Not Applicable	Circulation or storage space.
B00I - R0006 - Movement - (7.9 SQM)	Not Applicable	Circulation or storage space.
B00I - R0008 - Communal Space - (232.98 SQM)	 Student Space (108)	
B00I - R0015 - Movement - (7.67 SQM)	Not Applicable	Circulation or storage space.
B00I - R0020 - Movement - (7.06 SQM)	Not Applicable	Circulation or storage space.
B00I - R0022 - Movement - (5.33 SQM)	Not Applicable	Circulation or storage space.
B00K - R0012 - Staff Kitchen - (9.54 SQM)	 Office (2)	
B00L - R0003 - Practical Activities - 1hb - (19.29 SQM)	 Student Space (8)	
B00L - R0004 - Home Base - (61.62 SQM) - Teaching Space: 1	 Student Space (28)	
B00L - R0006 - Withdrawal Space - 2hb - (11.51 SQM)	 Student Space (5)	
B00L - R0008 - Practical Activities - 1hb - (20.1 SQM)	 Student Space (9)	
B00L - R0009 - Home Base - (60.48 SQM) - Teaching Space: 1	 Student Space (28)	
B00M - R0003 - Practical Activities - 1hb - (19.29 SQM)	 Student Space (8)	
B00M - R0004 - Home Base - (61.62 SQM) - Teaching Space: 1	 Student Space (28)	
B00M - R0006 - Withdrawal Space - 2hb - (11.51 SQM)	 Student Space (5)	
B00M - R0008 - Practical Activities - 1hb - (20.1 SQM)	 Student Space (9)	
B00M - R0009 - Home Base - (60.48 SQM) - Teaching Space: 1	 Student Space (28)	
B00N - R0002 - Practical Activities - 1hb - (19.83 SQM)	 Student Space (9)	
B00N - R0004 - Home Base - (59.96 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0005 - Withdrawal Space - 2hb - (11.6 SQM)	 Student Space (5)	
B00N - R0006 - Practical Activities - 1hb - (19.05 SQM)	 Student Space (8)	
B00N - R0007 - Home Base - (60.18 SQM) - Teaching Space: 1	 Student Space (27)	
B00N - R0010 - Special Programs Room - (31.83 SQM)	 Student Space (14)	
NS 101 12855 - NS 101 12855 - Learning Unit - Double Primary/PAA - (133 SQM)	 Student Space (61)	
OS 510 14633 - OS 510 14633 - Staff Common Room - (114 SQM)	 Office (28)	
OS 603 13336 - OS 603 13336 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	
OS 606 19129 - OS 606 19129 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	