


VENTILATION AUDIT REPORT

SCHOOL:	Matraville Soldiers Settlement Public School (4067)
AMU REGION:	Sydney
STATE ELECTORATE:	Maroubra
LOCAL GOVERNMENT AREA:	Randwick

4067 - Matraville Soldiers Settlement Public School
Site Plan (11193)



1:712

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Withdrawal Space - 1hb - (26.84 SQM)	● Student Space (12)	
B00A - R0003 - Practical Activities - 1hb - (19.06 SQM)	● Student Space (8)	
B00A - R0004 - Home Base - (53.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0006 - Home Base - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0008 - Practical Activities - 1hb - (10.63 SQM)	● Student Space (4)	
B00A - R0009 - Movement - (21.99 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Practical Activities - 1hb - (10.44 SQM)	● Student Space (4)	
B00B - R0003 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0005 - Movement - (19.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (76.61 SQM) - Teaching Space: 1	● Student Space (35)	
B00B - R0008 - Practical Activities - 1hb - (11.77 SQM)	● Student Space (5)	
B00C - R0002 - Practical Activities - 1hb - (10.21 SQM)	● Student Space (4)	
B00C - R0003 - Home Base - (53.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0006 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0007 - Practical Activities - 1hb - (11.44 SQM)	● Student Space (5)	
B00C - R0009 - Movement - (5.38 SQM)	Not Applicable	Circulation or storage space.
B00C - R0010 - Special Programs Room - (22.26 SQM)	● Student Space (10)	
B00D - R0004 - Practical Activities - Pre - (34.61 SQM)	● Student Space (16)	
B00D - R0005 - Home Base - Pre - (35.79 SQM) - Teaching Space: 1	● Student Space (16)	
B00D - R0006 - Practical Activities - Pre - (13.71 SQM)	● Student Space (6)	
B00D - R0012 - Movement - (10.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0013 - Movement - (17.94 SQM)	Not Applicable	Circulation or storage space.
B00D - R0016 - Home Base - (53.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0018 - Movement - (34.33 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Staff Kitchen - (14.24 SQM)	● Office (3)	
B00E - R0003 - Movement - (19.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0005 - Communal Space - (217.78 SQM)	● Student Space (101)	
B00E - R0006 - Movement - (7.1 SQM)	Not Applicable	Circulation or storage space.
B00E - R0011 - Raised Platform - (49.44 SQM)	Not Applicable	Circulation or storage space.
B00E - R0016 - Movement - (13.38 SQM)	Not Applicable	Circulation or storage space.
B00E - R0017 - Movement - (13.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R9001 - Movement - (52.98 SQM)	Not Applicable	Circulation or storage space.
B00E - R9003 - Staff Room Annexe - (13.6 SQM)	● Office (3)	
B00E - R9008 - Canteen - (31.65 SQM)	Not Applicable	Circulation or storage space.
B00E - R9009 - Movement - (135.54 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (11.9 SQM)	Not Applicable	Circulation or storage space.
B00F - R0008 - Movement - (5.18 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Special Programs Room - (59.49 SQM)	● Student Space (27)	
B00G - R0001 - Movement - (107.94 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Reading Area - (158.61 SQM)	● Student Space (73)	
B00G - R0005 - Special Programs Room - (34.52 SQM)	● Student Space (16)	
B00H - R0001 - Staff Room Annexe - (18.15 SQM)	● Office (4)	
B00H - R0002 - Staff Room - (42.95 SQM)	● Office (10)	
B00H - R0003 - Staff Room Annexe - (12.25 SQM)	● Office (3)	
B00H - R0004 - Staff Room Annexe - (12.29 SQM)	● Office (3)	
B00H - R0005 - Interview - (11.26 SQM)	● Office (2)	
B00H - R0007 - Sick Bay - (7.98 SQM)	● Student Space (3)	
B00H - R0008 - Clerical Office - (16.36 SQM)	● Office (4)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0009 - Entry Vestibule - (14.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0010 - Movement - (17.66 SQM)	Not Applicable	Circulation or storage space.
B00H - R0011 - Principal - (16.53 SQM)	Office (4)	
B00H - R0012 - Duplicating Workroom - (18.59 SQM)	Office (4)	
B00H - R0019 - Movement - (26.72 SQM)	Not Applicable	Circulation or storage space.
B00H - R0020 - Movement - (22.84 SQM)	Not Applicable	Circulation or storage space.
B00J - R0001 - Movement - (89.94 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Practical Activities - 1hb - (28 SQM)	Student Space (12)	
B00J - R0004 - Withdrawal Space - 1hb - (5.72 SQM)	Student Space (2)	
B00J - R0005 - Home Base - (50.07 SQM) - Teaching Space: 1	Student Space (23)	
B00J - R0006 - Home Base - (50.21 SQM) - Teaching Space: 1	Student Space (23)	
B00J - R0007 - Withdrawal Space - 1hb - (5.72 SQM)	Student Space (2)	
B00J - R0009 - Practical Activities - 1hb - (28.26 SQM)	Student Space (13)	
B00K - R0001 - Movement - (68.06 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Practical Activities - 1hb - (27.93 SQM)	Student Space (12)	
B00K - R0003 - Home Base - (49.51 SQM) - Teaching Space: 1	Student Space (22)	
B00K - R0005 - Withdrawal Space - 1hb - (12.32 SQM)	Student Space (5)	
B00K - R0006 - Home Base - (50 SQM) - Teaching Space: 1	Student Space (23)	
B00K - R0007 - Practical Activities - 1hb - (28.21 SQM)	Student Space (13)	
B00L - R0002 - Practical Activities/Movement - 1hb - (18.96 SQM)	Student Space (8)	
B00L - R0004 - Home Base - (61.14 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R0005 - Withdrawal Space - 2hb - (11.7 SQM)	Student Space (5)	
B00L - R0006 - Home Base - (61.14 SQM) - Teaching Space: 1	Student Space (28)	
B00L - R0008 - Practical Activities/Movement - 1hb - (18.96 SQM)	Student Space (8)	