


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mawarra Public School (4466)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Camden</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Camden</b>

4466 - Mawarra Public School  
Site Plan (10473)
















1:1,119

Printed: 07-Jul-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Staff Room - (53.31 SQM)	Office (13)	
B00A - R0002 - Duplicating Workroom - (13.56 SQM)	Office (3)	
B00A - R0006 - Staff Room Annexe - (12.99 SQM)	Office (3)	
B00A - R0007 - Sick Bay - (11.29 SQM)	Student Space (5)	
B00A - R0008 - Clerical Office - (18.3 SQM)	Office (4)	
B00A - R0009 - Entry Vestibule - (11.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal - (19.69 SQM)	Office (4)	
B00A - R0012 - Movement - (15.54 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Movement - (72.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0007 - Reading Area - (177.92 SQM)	Student Space (82)	
B00C - R0001 - Home Base - (60.32 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0002 - Practical Activities - 1hb - (11.25 SQM)	Student Space (5)	
B00C - R0004 - Practical Activities - 1hb - (11.71 SQM)	Student Space (5)	
B00C - R0005 - Home Base - (59.6 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0006 - Home Base - (60.95 SQM) - Teaching Space: 1	Student Space (28)	
B00C - R0007 - Practical Activities - 1hb - (11.26 SQM)	Student Space (5)	
B00C - R0010 - Practical Activities - 1hb - (11.25 SQM)	Student Space (5)	
B00C - R0011 - Home Base - (60.22 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0012 - Movement - (93.47 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (13.16 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Canteen - (27.33 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Interview - (12.43 SQM)	Office (3)	
B00D - R0009 - Staff Room Annexe - (13.77 SQM)	Office (3)	
B00D - R0012 - Staff Room Annexe - (14.29 SQM)	Office (3)	
B00D - R0017 - Movement - (31.54 SQM)	Not Applicable	Circulation or storage space.
B00D - R0020 - Movement - (75.96 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Home Base - (94.24 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0005 - Home Base - (94.81 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0013 - Home Base - (64.64 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0014 - Home Base - (64.64 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0019 - Movement - (106.7 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Staff Room Annexe - (13.88 SQM)	Office (3)	
B00F - R0002 - Practical Activities - 1hb - (11.5 SQM)	Student Space (5)	
B00F - R0003 - Home Base - (61.76 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0004 - Home Base - (61.6 SQM) - Teaching Space: 1	Student Space (28)	
B00F - R0005 - Practical Activities - 1hb - (11.5 SQM)	Student Space (5)	
B00F - R0010 - Movement - (75.7 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (35.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Communal Space - (202.94 SQM)	Student Space (94)	
B00G - R0008 - Movement - (14.09 SQM)	Not Applicable	Circulation or storage space.
B00G - R0010 - Movement - (9.63 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Raised Platform - (48.86 SQM)	Not Applicable	Circulation or storage space.
B00G - R0013 - Movement - (14.07 SQM)	Not Applicable	Circulation or storage space.
B00G - R0014 - Movement - (5.4 SQM)	Not Applicable	Circulation or storage space.
B00G - R0017 - Special Programs Room - (32.15 SQM)	Student Space (14)	
B00G - R0018 - Staff Kitchen - (18.61 SQM)	Office (4)	
B00H - R0002 - Practical Activities/Movement - 1hb - (18.55 SQM)	Student Space (8)	
B00H - R0004 - Home Base - (60.5 SQM) - Teaching Space: 1	Student Space (28)	
B00H - R0005 - Withdrawal Space - 2hb - (11.78 SQM)	Student Space (5)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0006 - Home Base - (60.59 SQM) - Teaching Space: 1	 Student Space (28)	
B00H - R0008 - Practical Activities/Movement - 1hb - (19.14 SQM)	 Student Space (8)	
B00H - R0010 - Movement - (5.91 SQM)	Not Applicable	Circulation or storage space.
B00H - R0013 - Special Programs Room - (32.29 SQM)	 Student Space (14)	
B00I - R0002 - Practical Activities/Movement - 1hb - (18.4 SQM)	 Student Space (8)	
B00I - R0004 - Home Base - (60.39 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0005 - Withdrawal Space - 2hb - (11.75 SQM)	 Student Space (5)	
B00I - R0006 - Home Base - (60.56 SQM) - Teaching Space: 1	 Student Space (28)	
B00I - R0008 - Practical Activities/Movement - 1hb - (19.13 SQM)	 Student Space (8)	
B00I - R0010 - Movement - (5.89 SQM)	Not Applicable	Circulation or storage space.
B00I - R0013 - Special Programs Room - (32.34 SQM)	 Student Space (15)	
OH 060 17030 - OH 060 17030 - OSHC Hub 60 - ( SQM)	 Student Space ( )	
OS 602 10201 - OS 602 10201 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 15816 - OS 602 15816 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 16787 - OS 602 16787 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	