

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mayfield East Public School (2506)</b>
<b>AMU REGION:</b>	<b>Hunter/Central Coast</b>
<b>STATE ELECTORATE:</b>	<b>Newcastle</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Newcastle</b>

2506 - Mayfield East Public School  
Site Plan (11527)



1:690

Printed: 30-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (17.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Sick Bay - (9.17 SQM)	● Student Space (4)	
B00A - R0004 - Duplicating Workroom - (13.44 SQM)	● Office (3)	
B00A - R0005 - Movement - (10.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Staff Room Annexe - (14.95 SQM)	● Office (3)	
B00A - R0007 - Staff Room Annexe - (14.95 SQM)	● Office (3)	
B00A - R0009 - Principal - (15.26 SQM)	● Office (3)	
B00A - R0010 - Entry Vestibule - (9.43 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Clerical Office - (18.41 SQM)	● Office (4)	
B00B - R0002 - Movement - (108.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Clerical Office - (12.65 SQM)	● Office (3)	
B00B - R0005 - Duplicating Workroom - (12.38 SQM)	● Office (3)	
B00B - R0006 - Home Base - (42.51 SQM) - Teaching Space: 1	● Student Space (19)	
B00B - R0007 - Practical Activities - 1hb - (5.17 SQM)	● Student Space (2)	
B00B - R0008 - Home Base - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0009 - Home Base - (47.56 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0014 - Special Programs Room - (17.42 SQM)	● Student Space (8)	
B00B - R0015 - Home Base - (47.63 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0016 - Home Base - (47.62 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0022 - Practical Activities - 4hb - (27.1 SQM)	● Student Space (12)	
B00B - R1001 - Movement - (17.04 SQM)	Not Applicable	Circulation or storage space.
B00B - R1002 - Withdrawal Space - 1hb - (9.5 SQM)	● Student Space (4)	
B00B - R1003 - Movement - (82.97 SQM)	Not Applicable	Circulation or storage space.
B00B - R1004 - Home Base - (49.17 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1005 - Home Base - (49.35 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1006 - Home Base - (49.16 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1007 - Home Base - (49.22 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1008 - Home Base - (49.43 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R1009 - Movement - (17.12 SQM)	Not Applicable	Circulation or storage space.
B00B - R1010 - Special Programs Room - (17.46 SQM)	● Student Space (8)	
B00C - R0002 - Movement - (40.23 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Staff Room - (61.38 SQM)	● Office (15)	
B00D - R0002 - Movement - (11.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0007 - Special Programs Room - (74.07 SQM)	● Student Space (34)	
B00D - R0009 - Movement - (77.99 SQM)	Not Applicable	Circulation or storage space.
B00D - R0011 - Movement - (8.37 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Special Programs Room - (47.67 SQM)	● Student Space (22)	
B00D - R0013 - Special Programs Room - (56.14 SQM)	● Student Space (26)	
B00E - R0001 - Movement - (59.95 SQM)	Not Applicable	Circulation or storage space.
B00E - R0002 - Canteen - (23.01 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (8.68 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Communal Space - (144.79 SQM)	● Student Space (67)	
B00H - R0003 - Movement - (5.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Raised Platform - (62.32 SQM)	Not Applicable	Circulation or storage space.
B00H - R0005 - Movement - (11.3 SQM)	Not Applicable	Circulation or storage space.
B00H - R0006 - Movement - (13.52 SQM)	Not Applicable	Circulation or storage space.
OS 602 18301 - OS 602 18301 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 606 19146 - OS 606 19146 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	