

VENTILATION AUDIT REPORT

SCHOOL:	Meadowbank Public School (3863)
AMU REGION:	Northern Sydney
STATE ELECTORATE:	Ryde
LOCAL GOVERNMENT AREA:	Ryde

3863 - Meadowbank Public School
Site Plan (10474)



1:699

Printed: 07-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Principal - (16.03 SQM)	Office (4)	
B00A - R0004 - Movement - (5.44 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Staff Room - (34.78 SQM)	Office (8)	
B00A - R0009 - Staff Kitchen - (13.63 SQM)	Office (3)	
B00A - R0010 - Entry Vestibule - (10.32 SQM)	Not Applicable	Circulation or storage space.
B00A - R0012 - Clerical Office - (10.33 SQM)	Office (2)	
B00A - R0013 - Duplicating Workroom - (15.28 SQM)	Office (3)	
B00A - R0018 - Movement - (5.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Canteen - (30.67 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Movement - (31.94 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (91.39 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R0010 - Home Base - (91.39 SQM) - Teaching Space: 1	Student Space (42)	
B00B - R1001 - Home Base - (59.43 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1003 - Home Base - (59.92 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1005 - Home Base - (59.93 SQM) - Teaching Space: 1	Student Space (27)	
B00B - R1008 - Home Base - (59.57 SQM) - Teaching Space: 1	Student Space (27)	
B00C - R0002 - Practical Activities - 1hb - (26.69 SQM)	Student Space (12)	
B00C - R0003 - Home Base - (53.73 SQM) - Teaching Space: 1	Student Space (24)	
B00C - R0004 - Special Programs Room - (53.66 SQM)	Student Space (24)	
B00C - R0005 - Movement - (30.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Communal Space - (143.25 SQM)	Student Space (66)	
B00D - R0002 - Raised Platform - (60.43 SQM)	Not Applicable	Circulation or storage space.
B00D - R0003 - Movement - (5.81 SQM)	Not Applicable	Circulation or storage space.
B00D - R0005 - Movement - (15 SQM)	Not Applicable	Circulation or storage space.
B00P - R0012 - Movement - (5.47 SQM)	Not Applicable	Circulation or storage space.
OS 534 12550 - OS 534 12550 - Library/Group Study/Office/A V Store - (152 SQM)	Student Space (70)	
OS 602 10102 - OS 602 10102 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10111 - OS 602 10111 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 10751 - OS 602 10751 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 11021 - OS 602 11021 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 15742 - OS 602 15742 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 602 17127 - OS 602 17127 - Learning Unit - Standard With P.A.A. - (76 SQM)	Student Space (35)	
OS 606 15054 - OS 606 15054 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 15163 - OS 606 15163 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 15242 - OS 606 15242 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 15969 - OS 606 15969 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19000 - OS 606 19000 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19005 - OS 606 19005 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19168 - OS 606 19168 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19200 - OS 606 19200 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19210 - OS 606 19210 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19244 - OS 606 19244 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	
OS 606 19586 - OS 606 19586 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	Student Space (35)	