

VENTILATION AUDIT REPORT

SCHOOL:	Melville High School (8566)
AMU REGION:	North Coast
STATE ELECTORATE:	Oxley
LOCAL GOVERNMENT AREA:	Kempsey

8566 - Melville High School
Site Plan (10647)



1:1,411

Printed: 12-Oct-2020








Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0001 - Gymnasium - (48.2 SQM)	● Student Space (22)	
B0A1 - M0001 - Movement - (10.08 SQM)	Not Applicable	Circulation or storage space.
B0A1 - M0002 - Movement - (136.78 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0002 - Student Canteen - (63.04 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0003 - Movement - (213.48 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0005 - Movement - (27.6 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0006 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0008 - General Assistants - (13.28 SQM)	● Office (3)	
B0A1 - R0010 - Movement - (389.24 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0014 - Staff Kitchen - (12.74 SQM)	● Office (3)	
B0A1 - R0015 - Public Entry - (83.15 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0018 - Movement - (5.48 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0019 - Gymnasium - (34.45 SQM)	● Student Space (15)	
B0A1 - R0020 - Multi-Purpose Space - (517.47 SQM)	● Student Space (240)	
B0A1 - R0023 - Movement - (6.43 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0024 - Movement - (20.19 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0025 - Movement - (5.26 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0027 - Stage - (99.48 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0036 - Staff Study - (15.73 SQM)	● Office (3)	
B0A1 - R0037 - Movement - (16.23 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0039 - Movement - (30.75 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0041 - Public Entry - (37.29 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0042 - Performance Workspace - (86.91 SQM) - Teaching Space: 1	● Student Space (40)	
B0A1 - R0045 - Multi-Purpose Space - (290.37 SQM)	● Student Space (134)	
B0A1 - R0047 - Pupil Entry - (6.23 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0057 - Seminar - (20.25 SQM)	● Office (5)	
B0A1 - R0058 - Seminar - (19.82 SQM)	● Office (4)	
B0A1 - R0062 - Movement - (69.01 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0063 - Movement - (56.13 SQM)	Not Applicable	Circulation or storage space.
B0A1 - R0064 - Movement - (24.2 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0001 - Movement - (34.34 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0004 - Clinic - Girls - (13.05 SQM)	● Office (3)	
B0B1 - R0009 - Duplicating Workroom - (29.54 SQM)	● Office (7)	
B0B1 - R0010 - Administration - Clerical - (36.22 SQM)	● Office (9)	
B0B1 - R0011 - Public Entry - (16.27 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0012 - Interview/Office - Type 1 - (13.81 SQM)	● Office (3)	
B0B1 - R0014 - Administration - Clerical - (13.73 SQM)	● Office (3)	
B0B1 - R0015 - Pupil Entry - (17.73 SQM)	Not Applicable	Circulation or storage space.
B0B1 - R0016 - Staff Study - (17.02 SQM)	● Office (4)	
B0B1 - R0017 - Principal Office - (19.32 SQM)	● Office (4)	
B0B1 - R0018 - Ancillary Staff - (23.26 SQM)	● Office (5)	
B0B2 - R0001 - Laboratory L.S. - (81.5 SQM) - Teaching Space: 1	● Student Space (37)	
B0B2 - R0002 - Preparation - (20.63 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0006 - Laboratory L.S. - (81.4 SQM) - Teaching Space: 1	● Student Space (37)	
B0B2 - R0007 - Preparation - (32.58 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0008 - Laboratory L.S. - (81.49 SQM) - Teaching Space: 1	● Student Space (37)	
B0B2 - R0010 - Growing/Breeding - (19.7 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0014 - Laboratory L.S. - (81.41 SQM) - Teaching Space: 1	● Student Space (37)	
B0B2 - R0015 - Preparation - (32.62 SQM)	Not Applicable	Circulation or storage space.
B0B2 - R0016 - Laboratory L.S. - (81.41 SQM) - Teaching Space: 1	● Student Space (37)	
B0B2 - R0018 - Staff Study - (36.77 SQM)	● Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOB2 - R0019 - Movement - (6.77 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0001 - Tiered Learning Area - (62.76 SQM)	● Student Space (29)	
BOC1 - R0007 - Staff Study - (40.23 SQM)	○ Office (10)	
BOC1 - R0009 - General Learning Space - (46.08 SQM) - Teaching Space: 1	● Student Space (21)	
BOC1 - R0010 - General Learning Space - (39.77 SQM) - Teaching Space: 1	● Student Space (18)	
BOC1 - R0011 - General Learning Space - (46.28 SQM) - Teaching Space: 1	● Student Space (21)	
BOC1 - R0012 - General Learning Space - (46.93 SQM) - Teaching Space: 1	● Student Space (21)	
BOC1 - R0013 - Movement - (8.47 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0014 - Interview/Office - Type 1 - (16.22 SQM)	○ Office (4)	
BOC1 - R0015 - General Learning Space - (46.94 SQM) - Teaching Space: 1	● Student Space (21)	
BOC1 - R0016 - General Learning Space - (46.31 SQM) - Teaching Space: 1	● Student Space (21)	
BOC1 - R0017 - General Learning Space - (39.77 SQM) - Teaching Space: 1	● Student Space (18)	
BOC1 - R0018 - General Learning Space - (46.02 SQM) - Teaching Space: 1	● Student Space (21)	
BOC1 - R0020 - Study Space - (14.86 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0021 - Movement - (8.01 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0023 - Entry - (13.21 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0024 - Seminar - (13.26 SQM)	○ Office (3)	
BOC1 - R0025 - Seminar - (13.44 SQM)	○ Office (3)	
BOC1 - R0026 - Seminar - (13.44 SQM)	○ Office (3)	
BOC1 - R0028 - Main Area - (345.96 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R0029 - Audio Visual Workroom - (30.15 SQM)	● Student Space (13)	
BOC1 - R0031 - Workroom - (32.99 SQM)	○ Office (8)	
BOC1 - R0032 - Staff Study - (11.32 SQM)	○ Office (2)	
BOC1 - R0033 - Movement - (15.61 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1002 - Commonroom - (101.55 SQM)	○ Office (25)	
BOC1 - R1007 - Senior Seminar - (12.4 SQM)	○ Office (3)	
BOC1 - R1008 - Senior Seminar - (12.31 SQM)	○ Office (3)	
BOC1 - R1009 - Senior Study - (68.71 SQM)	○ Office (17)	
BOC1 - R1011 - General Learning Space - (39.7 SQM) - Teaching Space: 1	● Student Space (18)	
BOC1 - R1012 - General Learning Space - (46.29 SQM) - Teaching Space: 1	● Student Space (21)	
BOC1 - R1013 - Staff Study - (32.01 SQM)	○ Office (8)	
BOC1 - R1015 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
BOC1 - R1016 - Study Space - (15.69 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0001 - General Learning Space - (46.17 SQM) - Teaching Space: 1	● Student Space (21)	
BOC2 - R0002 - General Learning Space - (39.83 SQM) - Teaching Space: 1	● Student Space (18)	
BOC2 - R0003 - General Learning Space - (46.21 SQM) - Teaching Space: 1	● Student Space (21)	
BOC2 - R0004 - General Learning Space - (46.86 SQM) - Teaching Space: 1	● Student Space (21)	
BOC2 - R0005 - Study Space - (14.66 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0006 - Movement - (8.43 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R0008 - Darkroom Space - (15.39 SQM)	○ Office (3)	
BOC2 - R0011 - Darkroom Space - (13.7 SQM)	○ Office (3)	
BOC2 - R0013 - Interview/Office - Type 1 - (14.66 SQM)	○ Office (3)	
BOC2 - R0014 - Interview/Office - Type 1 - (14.76 SQM)	○ Office (3)	
BOC2 - R0017 - Staff Study - (39.78 SQM)	○ Office (9)	
BOC2 - R0018 - Interview/Office - Type 1 - (12.68 SQM)	○ Office (3)	
BOC2 - R0021 - Teachers Aides - (15.04 SQM)	○ Office (3)	
BOC2 - R0022 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
BOC2 - R1001 - General Learning Space - (46.46 SQM) - Teaching Space: 1	● Student Space (21)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0C2 - R1002 - General Learning Space - (39.95 SQM) - Teaching Space: 1	● Student Space (18)	
B0C2 - R1003 - General Learning Space - (46.24 SQM) - Teaching Space: 1	● Student Space (21)	
B0C2 - R1004 - General Learning Space - (46.98 SQM) - Teaching Space: 1	● Student Space (21)	
B0C2 - R1005 - Staff Study - (15.69 SQM)	● Office (3)	
B0C2 - R1006 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B0C2 - R1008 - Staff Study - (31.95 SQM)	● Office (7)	
B0C2 - R1009 - Computer Learning Space - (46.21 SQM) - Teaching Space: 1	● Student Space (21)	
B0C2 - R1010 - Computer Learning Space - (39.62 SQM) - Teaching Space: 1	● Student Space (18)	
B0C2 - R1011 - General Learning Space - (46.21 SQM) - Teaching Space: 1	● Student Space (21)	
B0C2 - R1013 - Study Space - (15.81 SQM)	Not Applicable	Circulation or storage space.
B0C2 - R1014 - Movement - (8.37 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0001 - Materials Technology L.S. - (70.87 SQM) - Teaching Space: 1	● Student Space (32)	
B0D1 - R0005 - Staff Study - (29.62 SQM)	● Office (7)	
B0D1 - R0006 - Clinic - Girls - (13.42 SQM)	● Office (3)	
B0D1 - R0007 - Computer Learning Space - (70.79 SQM) - Teaching Space: 1	● Student Space (32)	
B0D1 - R0008 - Movement - (6.01 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0010 - Food Technology L.S. - (104.23 SQM) - Teaching Space: 1	● Student Space (48)	
B0D1 - R0011 - Preparation - (17.11 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0012 - Food/Research Space - (11.24 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R0013 - Kitchen - Type 2 - (105.74 SQM)	● Student Space (49)	
B0D1 - R1001 - Music Learning Space - (78.64 SQM) - Teaching Space: 1	● Student Space (36)	
B0D1 - R1002 - Practice/Seminar - (25.71 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R1004 - Music Learning Space - (61.3 SQM) - Teaching Space: 1	● Student Space (28)	
B0D1 - R1005 - Movement - (5.79 SQM)	Not Applicable	Circulation or storage space.
B0D1 - R1007 - Staff Study - (16.83 SQM)	● Office (4)	
B0D1 - R1008 - Movement - (9.34 SQM)	Not Applicable	Circulation or storage space.
B0D2 - R0001 - Staff Study - (26.11 SQM)	● Office (6)	
B0D2 - R0002 - Staff Study - (18.18 SQM)	● Office (4)	
B0D2 - R0003 - Art Entry/Display - (8.36 SQM)	Not Applicable	Circulation or storage space.
B0D2 - R0006 - Art Learning Space - (59.12 SQM) - Teaching Space: 1	● Student Space (27)	
B0D2 - R0007 - Workshop - (56.4 SQM)	● Student Space (26)	
B0D2 - R0009 - Art Learning Space - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B0D2 - R0015 - Movement - (11.07 SQM)	Not Applicable	Circulation or storage space.
B0D2 - R0016 - Movement - (9.24 SQM)	Not Applicable	Circulation or storage space.
B0D2 - R0017 - Art Learning Space - (59.12 SQM) - Teaching Space: 1	● Student Space (27)	
B0D2 - R0018 - Design L.S. - (51.58 SQM) - Teaching Space: 1	● Student Space (23)	
B0D2 - R0019 - Design L.S. - (57.75 SQM) - Teaching Space: 1	● Student Space (26)	
B0D3 - R0001 - Movement - (8.58 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0002 - Welding Area - (15.09 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0006 - Workshop - (66.45 SQM)	● Student Space (30)	
B0D3 - R0007 - Welding Area - (11.58 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0010 - Materials Technology L.S. - (91.56 SQM) - Teaching Space: 1	● Student Space (42)	
B0D3 - R0011 - Wood Technology Bay - (34.43 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0014 - Materials Technology L.S. - (91.57 SQM) - Teaching Space: 1	● Student Space (42)	
B0D3 - R0015 - Movement - (7.78 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0016 - Movement - (7.99 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0017 - Design L.S. - (75.47 SQM) - Teaching Space: 1	● Student Space (35)	
B0D3 - R0018 - Metal Technology Bay - (40.22 SQM)	Not Applicable	Circulation or storage space.
B0D3 - R0020 - Materials Technology L.S. - (91.61 SQM) - Teaching Space: 1	● Student Space (42)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B0D3 - R0021 - Wood Technology Bay - (14.85 SQM)	Not Applicable	Circulation or storage space.
B0E1 - R0001 - Practical Activities - (33.34 SQM)	 Student Space (15)	
B0E1 - R0003 - Materials Technology L.S. - (43.5 SQM) - Teaching Space: 1	 Student Space (20)	
B0E1 - R0004 - Workshop - (127.23 SQM)	 Student Space (59)	
B0E1 - R0008 - T.A.S. Outdoor Area - (65.79 SQM)	Not Applicable	Circulation or storage space.
NS 220 15030 - NS 220 15030 - Science Learning/Preparation Space - (95 SQM)	Not Applicable	Circulation or storage space.
OS 521 11819 - OS 521 11819 - Staff Study - (76 SQM)	 Office (19)	
OS 601 10440 - OS 601 10440 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 627 11999 - OS 627 11999 - Learning Unit Double - PWD - (190 SQM)	 Student Space (88)	
OS 710 10923 - OS 710 10923 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	