

VENTILATION AUDIT REPORT

SCHOOL:	Mendooran Central School (2522)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Warrumbungle

2522 - Mendooran Central School
Site Plan (12996)



1:1,300

Printed: 13-Jul-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Home Base - (89.8 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R0004 - Movement - (7.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0007 - Movement - (5.85 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (30.61 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Home Base - (89.96 SQM) - Teaching Space: 1	● Student Space (41)	
B00A - R1005 - Movement - (44.59 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Movement - (12.22 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Canteen - (17.28 SQM)	Not Applicable	Circulation or storage space.
B00C - R0001 - Staff Room Annexe - (15.06 SQM)	● Office (3)	
B00C - R0002 - Home Base - (68.41 SQM) - Teaching Space: 1	● Student Space (31)	
B00C - R0003 - Practical Activities - 1hb - (19.14 SQM)	● Student Space (8)	
B00C - R0005 - Movement - (25.95 SQM)	Not Applicable	Circulation or storage space.
B00D - R0001 - Movement - (48.86 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Staff Study - (53.72 SQM)	● Office (13)	
B00D - R0004 - Withdrawal Space - 1hb - (13.04 SQM)	● Student Space (6)	
B00D - R0005 - Home Base - (67.03 SQM) - Teaching Space: 1	● Student Space (31)	
B00D - R0007 - Interview - (10.92 SQM)	● Office (2)	
B00E - R0002 - Staff Room - (46.45 SQM)	● Office (11)	
B00E - R0003 - Movement - (9.22 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (33.46 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - General Learning Space - (54.27 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0001 - Movement - (76.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Staff Room Annexe - (8.38 SQM)	● Office (2)	
B00H - R0008 - Staff Room Annexe - (11.13 SQM)	● Office (2)	
B00H - R0010 - Deputy Principal - (15.13 SQM)	● Office (3)	
B00H - R0014 - Computer Learning Space - (57.74 SQM) - Teaching Space: 1	● Student Space (26)	
B00H - R0015 - Preparation - (26.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R0016 - Science Laboratory - (91.41 SQM)	● Student Space (42)	
B00L - R0002 - Outdoor Workshop - (34.09 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Movement - (38.53 SQM)	Not Applicable	Circulation or storage space.
B00M - R0002 - Practical Activities - 1hb - (19.42 SQM)	● Student Space (9)	
B00M - R0004 - Home Base - (59.28 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0005 - Withdrawal Space - 2hb - (11.37 SQM)	● Student Space (5)	
B00M - R0006 - Home Base - (59.27 SQM) - Teaching Space: 1	● Student Space (27)	
B00M - R0008 - Practical Activities - 1hb - (19.43 SQM)	● Student Space (9)	
B00N - R0001 - Materials Technology L.S. - (109.41 SQM) - Teaching Space: 1	● Student Space (50)	
B00O - R0002 - Food Technology L.S. - (75.91 SQM) - Teaching Space: 1	● Student Space (35)	
B00O - R0003 - Food/Research Space - (20.5 SQM)	Not Applicable	Circulation or storage space.
B00O - R0004 - Preparation - Materials - (19.51 SQM)	Not Applicable	Circulation or storage space.
OS 502 10759 - OS 502 10759 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	● Office (38)	
OS 522 15759 - OS 522 15759 - Staff Study - (38 SQM)	● Office (9)	
OS 534 11034 - OS 534 11034 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 10441 - OS 601 10441 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	