

VENTILATION AUDIT REPORT

SCHOOL:	Menindee Central School (2523)
AMU REGION:	North Western NSW
STATE ELECTORATE:	Barwon
LOCAL GOVERNMENT AREA:	Central Darling



2523 - Menindee Central School
Site Plan (10593)



1:1,242

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - General Learning Space - (40.1 SQM) - Teaching Space: 1	● Student Space (18)	
B00A - R0006 - General Learning Space - (43.97 SQM) - Teaching Space: 1	● Student Space (20)	
B00B - R0002 - Entry Vestibule - (17.84 SQM)	Not Applicable	Circulation or storage space.
B00B - R0003 - Movement - (45.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - Clerical Office - (20.07 SQM)	● Office (5)	
B00B - R0005 - Duplicating Workroom - (23.72 SQM)	● Office (5)	
B00B - R0007 - Staff Room Annexe - (13.66 SQM)	● Office (3)	
B00B - R0012 - Clerical Office/Workroom - (12.67 SQM)	● Office (3)	
B00B - R0013 - Principal - (17.02 SQM)	● Office (4)	
B00B - R0014 - Dental Clinic - (11.63 SQM)	● Office (2)	
B00B - R0017 - Sick Bay - (11.56 SQM)	● Student Space (5)	
B00B - R0018 - Staff Room Annexe - (9.21 SQM)	● Office (2)	
B00B - R0019 - Staff Room Annexe - (14.01 SQM)	● Office (3)	
B00B - R0020 - Staff Room - (36.84 SQM)	● Office (9)	
B00C - R0006 - Home Base - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0008 - Practical Activities - 1hb - (18.94 SQM)	● Student Space (8)	
B00C - R0009 - Withdrawal Space - 1hb - (12.35 SQM)	● Student Space (5)	
B00C - R0010 - Practical Activities - 1hb - (18.9 SQM)	● Student Space (8)	
B00C - R0013 - Home Base - (58.99 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0017 - Practical Activities - 1hb - (18.9 SQM)	● Student Space (8)	
B00C - R0018 - Home Base - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0019 - Withdrawal Space - 1hb - (12.3 SQM)	● Student Space (5)	
B00C - R0020 - Practical Activities - 1hb - (18.9 SQM)	● Student Space (8)	
B00C - R0024 - Home Base - (59.08 SQM) - Teaching Space: 1	● Student Space (27)	
B00C - R0026 - Movement - (22.03 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Withdrawal Space - 1hb - (11.97 SQM)	● Student Space (5)	
B00D - R0005 - Special Programs Room - (41.67 SQM)	● Student Space (19)	
B00D - R0006 - Reading Area - (87.47 SQM)	● Student Space (40)	
B00D - R0009 - Special Programs Room - (29.9 SQM)	● Student Space (13)	
B00E - R0003 - Staff Room Annexe - (22.22 SQM)	● Office (5)	
B00E - R0004 - Seminar/Study - (14.79 SQM)	● Office (3)	
B00E - R0007 - Preparation - (16.89 SQM)	Not Applicable	Circulation or storage space.
B00E - R0008 - Food Technology L.S. - (54.38 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0011 - Laboratory L.S. - (55.9 SQM) - Teaching Space: 1	● Student Space (25)	
B00E - R0013 - Preparation - (19.25 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Communal Space - (161.84 SQM)	● Student Space (75)	
B00F - R0002 - Raised Platform - (44.64 SQM)	Not Applicable	Circulation or storage space.
B00F - R0009 - Canteen - (14.59 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Darkroom Space - (16.71 SQM)	● Office (4)	
B00G - R0009 - Materials Technology L.S. - (74 SQM) - Teaching Space: 1	● Student Space (34)	
B00G - R0011 - Workshop Area - (33.81 SQM)	● Student Space (15)	
B00G - R0013 - Computer Learning Space - (27.89 SQM) - Teaching Space: 1	● Student Space (12)	
B00H - R0001 - General Learning Space - (42.2 SQM) - Teaching Space: 1	● Student Space (19)	
B00K - R0004 - Music Learning Space - (62.78 SQM) - Teaching Space: 1	● Student Space (29)	
B00K - R0005 - Staff Study - (10.85 SQM)	● Office (2)	
B00K - R0006 - Art Learning Space - (62.8 SQM) - Teaching Space: 1	● Student Space (29)	
B00L - R0001 - Movement - (14.22 SQM)	Not Applicable	Circulation or storage space.
OS 601 13928 - OS 601 13928 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	

Entity Location	Audit Condition Classification (Capacity)	Comment
OS 700 11520 - OS 700 11520 - Art Learning Space/Workshop/Store - (114 SQM)	Not Applicable	Circulation or storage space.
OS 751 11965 - OS 751 11965 - Learning Unit - ESL - (76 SQM)	<input checked="" type="radio"/> Student Space (35)	