

VENTILATION AUDIT REPORT

SCHOOL:	Merrylands Public School (2531)
AMU REGION:	South Western Sydney
STATE ELECTORATE:	Granville
LOCAL GOVERNMENT AREA:	Cumberland

2531 - Merrylands Public School
Site Plan (10680)



1:766

Printed: 07-Aug-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Home Base - (46.98 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R0012 - Movement - (13.96 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Principal - (17.24 SQM)	● Office (4)	
B00A - R0016 - Home Base - (62.98 SQM) - Teaching Space: 1	● Student Space (29)	
B00A - R0018 - Practical Activities/Movement - 4hb - (10.21 SQM)	● Student Space (4)	
B00A - R0020 - Home Base - (43.93 SQM) - Teaching Space: 1	● Student Space (20)	
B00A - R0023 - Special Programs Room - (41.22 SQM)	● Student Space (19)	
B00A - R1003 - Home Base - (50.12 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1004 - Home Base - (49.74 SQM) - Teaching Space: 1	● Student Space (23)	
B00A - R1005 - Home Base - (49.07 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1006 - Movement - (58.27 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Home Base - (52.5 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0003 - Home Base - (52.64 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0004 - Movement - (27.45 SQM)	Not Applicable	Circulation or storage space.
B00D - R0002 - Home Base - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0003 - Home Base - (52.65 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0004 - Movement - (27.39 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Movement - (29.72 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Withdrawal Space - 1hb - (17.99 SQM)	● Student Space (8)	
B00G - R0007 - Movement - (5 SQM)	Not Applicable	Circulation or storage space.
B00G - R0008 - Home Base - (51.19 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0009 - Home Base - (51 SQM) - Teaching Space: 1	● Student Space (23)	
B00G - R0025 - Movement - (13.57 SQM)	Not Applicable	Circulation or storage space.
B00G - R0026 - Interview - (13.09 SQM)	● Office (3)	
B00G - R0028 - Clerical Office - (13.45 SQM)	● Office (3)	
B00G - R0030 - Staff Kitchen - (9.86 SQM)	● Office (2)	
B00G - R0031 - Staff Room - (66.73 SQM)	● Office (16)	
B00G - R0032 - Movement - (16.99 SQM)	Not Applicable	Circulation or storage space.
B00G - R0033 - Duplicating Workroom - (5.33 SQM)	● Office (1)	
B00G - R0034 - Sick Bay - (5.43 SQM)	● Student Space (2)	
B00G - R0035 - Movement - (52.05 SQM)	Not Applicable	Circulation or storage space.
B00G - R0036 - Clerical Office - (23.79 SQM)	● Office (5)	
B00G - R0037 - Entry Vestibule - (11.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Home Base - (53.52 SQM) - Teaching Space: 1	● Student Space (24)	
B00H - R0003 - Home Base - (54.04 SQM) - Teaching Space: 1	● Student Space (25)	
B00H - R0004 - Movement - (29.04 SQM)	Not Applicable	Circulation or storage space.
B00I - R0001 - Movement - (21.07 SQM)	Not Applicable	Circulation or storage space.
B00I - R0002 - Interview - (18.82 SQM)	● Office (4)	
B00I - R0004 - Special Programs Room - (53.68 SQM)	● Student Space (24)	
B00J - R0001 - Movement - (32.99 SQM)	Not Applicable	Circulation or storage space.
B00J - R0002 - Home Base - (105.66 SQM) - Teaching Space: 1	● Student Space (49)	
B00L - R0001 - Reading Area - (162.27 SQM)	● Student Space (75)	
B00M - R0001 - Communal Space - (145.32 SQM)	● Student Space (67)	
B00M - R0002 - Raised Platform - (59.42 SQM)	Not Applicable	Circulation or storage space.
B00M - R0016 - Movement - (6.17 SQM)	Not Applicable	Circulation or storage space.
B00M - R0017 - Movement - (13.66 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Canteen - (26.48 SQM)	Not Applicable	Circulation or storage space.
B00M - R0021 - Movement - (12.41 SQM)	Not Applicable	Circulation or storage space.
B00N - R0013 - Practical Activities - 2hb - (44.8 SQM)	● Student Space (20)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00N - R0018 - Home Base - (64.94 SQM) - Teaching Space: 1	● Student Space (30)	
B00N - R0019 - Home Base - (65.2 SQM) - Teaching Space: 1	● Student Space (30)	
B00N - R0020 - Withdrawal Space - 2hb - (11.45 SQM)	● Student Space (5)	
B00N - R0023 - Movement - (25.76 SQM)	Not Applicable	Circulation or storage space.
B00N - R1003 - Practical Activities - 2hb - (37.09 SQM)	● Student Space (17)	
B00N - R1012 - Practical Activities - 2hb - (45.7 SQM)	● Student Space (21)	
B00N - R1015 - Home Base - (64.99 SQM) - Teaching Space: 1	● Student Space (30)	
B00N - R1016 - Home Base - (64.87 SQM) - Teaching Space: 1	● Student Space (30)	
B00N - R1017 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B00N - R1019 - Tiered Learning Space - (12.98 SQM)	● Student Space (6)	
B00N - R1020 - Home Base - (63.77 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R1021 - Home Base - (64.2 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R1022 - Withdrawal Space - 2hb - (11.66 SQM)	● Student Space (5)	
B00N - R1024 - Movement - (93.48 SQM)	Not Applicable	Circulation or storage space.
B00N - R2003 - Practical Activities - 2hb - (37.09 SQM)	● Student Space (17)	
B00N - R2012 - Practical Activities - 2hb - (45.7 SQM)	● Student Space (21)	
B00N - R2015 - Home Base - (64.99 SQM) - Teaching Space: 1	● Student Space (30)	
B00N - R2016 - Home Base - (64.87 SQM) - Teaching Space: 1	● Student Space (30)	
B00N - R2017 - Withdrawal Space - 2hb - (11.6 SQM)	● Student Space (5)	
B00N - R2019 - Tiered Learning Space - (12.98 SQM)	● Student Space (6)	
B00N - R2020 - Home Base - (63.77 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R2021 - Home Base - (64.2 SQM) - Teaching Space: 1	● Student Space (29)	
B00N - R2022 - Withdrawal Space - 2hb - (11.66 SQM)	● Student Space (5)	
B00N - R2024 - Movement - (93.48 SQM)	Not Applicable	Circulation or storage space.
OS 600 11539 - OS 600 11539 - Learning Unit - Small - (57 SQM)	● Student Space (26)	
OS 601 15357 - OS 601 15357 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 12323 - OS 602 12323 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10579 - OS 603 10579 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 12588 - OS 603 12588 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 19092 - OS 606 19092 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	