

VENTILATION AUDIT REPORT

SCHOOL:	Metella Road Public School (4444)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Prospect
LOCAL GOVERNMENT AREA:	Blacktown

4444 - Metella Road Public School
Site Plan (10478)



1:1,059

Printed: 12-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Deputy Principal - (14.2 SQM)	Office (3)	
B00A - R0004 - Interview - (9.15 SQM)	Office (2)	
B00A - R0005 - Entry Vestibule - (19.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Interview - (9.49 SQM)	Office (2)	
B00A - R0007 - Principal - (20.99 SQM)	Office (5)	
B00A - R0011 - Clerical Office/Workroom - (13.96 SQM)	Office (3)	
B00A - R0012 - Movement - (15.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0013 - Duplicating Workroom - (10.47 SQM)	Office (2)	
B00A - R0020 - Canteen - (30.73 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Movement - (10.08 SQM)	Not Applicable	Circulation or storage space.
B00A - R0022 - Staff Room - (80.05 SQM)	Office (20)	
B00A - R0025 - Movement - (6.9 SQM)	Not Applicable	Circulation or storage space.
B00A - R0028 - Movement - (19.27 SQM)	Not Applicable	Circulation or storage space.
B00A - R0030 - Sick Bay - (9.73 SQM)	Student Space (4)	
B00A - R0032 - Clerical Office - (15.45 SQM)	Office (3)	
B00A - R0033 - Movement - (44.48 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (92.82 SQM) - Teaching Space: 1	Student Space (43)	
B00B - R0007 - Home Base - (96.01 SQM) - Teaching Space: 1	Student Space (44)	
B00B - R0015 - Home Base - (92.71 SQM) - Teaching Space: 1	Student Space (43)	
B00C - R0006 - Home Base - (63.48 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0008 - Home Base - (64.03 SQM) - Teaching Space: 1	Student Space (29)	
B00C - R0017 - Home Base - (83.22 SQM) - Teaching Space: 1	Student Space (38)	
B00D - R0002 - Home Base - (63.39 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0004 - Staff Room Annexe - (12.84 SQM)	Office (3)	
B00D - R0007 - Home Base - (64.05 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0009 - Home Base - (63.77 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0016 - Home Base - (63.47 SQM) - Teaching Space: 1	Student Space (29)	
B00E - R0013 - Home Base - (68.62 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0014 - Practical Activities - 1hb - (8.07 SQM)	Student Space (3)	
B00E - R0015 - Home Base - (68.02 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R0016 - Practical Activities - 1hb - (8.33 SQM)	Student Space (3)	
B00E - R0020 - Home Base - (69.94 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R0021 - Practical Activities - 1hb - (6.54 SQM)	Student Space (3)	
B00E - R0026 - Staff Kitchen - (10.02 SQM)	Office (2)	
B00E - R0028 - Communal Space - (241.65 SQM)	Student Space (112)	
B00E - R0031 - Movement - (76.81 SQM)	Not Applicable	Circulation or storage space.
B00E - R0032 - Special Programs Room - (77.37 SQM)	Student Space (35)	
B00E - R1001 - Home Base - (65.71 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1004 - Home Base - M - (67.41 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R1005 - Practical Activities - 1hb - (7.82 SQM)	Student Space (3)	
B00E - R1006 - Home Base - (67.77 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R1007 - Practical Activities - 1hb - (7.54 SQM)	Student Space (3)	
B00E - R1008 - Home Base - (69.64 SQM) - Teaching Space: 1	Student Space (32)	
B00E - R1009 - Practical Activities - 1hb - (5.52 SQM)	Student Space (2)	
B00E - R1011 - Home Base - (67.58 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R1012 - Practical Activities - 1hb - (7.73 SQM)	Student Space (3)	
B00E - R1013 - Home Base - M - (67.31 SQM) - Teaching Space: 1	Student Space (31)	
B00E - R1014 - Practical Activities - 1hb - (7.79 SQM)	Student Space (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00E - R1015 - Movement - (7.07 SQM)	Not Applicable	Circulation or storage space.
B00E - R1016 - Home Base - M - (75.19 SQM) - Teaching Space: 1	● Student Space (34)	
B00E - R1017 - Home Base - (75.27 SQM) - Teaching Space: 1	● Student Space (34)	
B00E - R1018 - Movement - (131.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Movement - (11.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0014 - Reading Area - (292.31 SQM)	● Student Space (135)	
B00G - R0001 - Communal Space - (202.01 SQM)	● Student Space (93)	
B00G - R0002 - Raised Platform - (56.87 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Movement - (6.26 SQM)	Not Applicable	Circulation or storage space.
B00G - R0004 - Movement - (16.77 SQM)	Not Applicable	Circulation or storage space.
B00G - R0005 - Movement - (11.25 SQM)	Not Applicable	Circulation or storage space.
NS 250 11490 - NS 250 11490 - Learning Unit - Single E.S.L./Store - (38 SQM)	● Student Space (17)	
OS 602 10960 - OS 602 10960 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11473 - OS 602 11473 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12847 - OS 602 12847 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12995 - OS 602 12995 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 19828 - OS 602 19828 - Learning Unit - Standard With P.A.A. - (SQM)	● Student Space ()	
OS 603 12114 - OS 603 12114 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 603 15384 - OS 603 15384 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 17692 - OS 606 17692 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	