


VENTILATION AUDIT REPORT

SCHOOL:	Michelago Public School (2540)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Snowy Monaro

2540 - Michelago Public School
Site Plan (10479)



1:634

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Movement - (14.2 SQM)	Not Applicable	Circulation or storage space.
B00A - R0002 - Duplicating Workroom - (13.11 SQM)	 Office (3)	
B00A - R0005 - Staff Room - (15.93 SQM)	 Office (3)	
B00A - R0006 - Sick Bay - (12 SQM)	 Student Space (5)	
B00A - R0007 - Entry Vestibule - (13.11 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (10.18 SQM)	Not Applicable	Circulation or storage space.
B00A - R0010 - Principal - (13.11 SQM)	 Office (3)	
B00A - R0011 - Movement - (20.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0016 - Clerical Office - (12.92 SQM)	 Office (3)	
B00B - R0001 - Movement - (16.87 SQM)	Not Applicable	Circulation or storage space.
B00B - R0002 - Practical Activities - (38.02 SQM)	 Student Space (17)	
B00B - R0003 - Withdrawal Space - 1hb - (19.73 SQM)	 Student Space (9)	
B00D - R0001 - Movement - (10.24 SQM)	Not Applicable	Circulation or storage space.
B00G - R0001 - Reading Area - (61.15 SQM)	 Student Space (28)	
OS 601 13605 - OS 601 13605 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 601 13852 - OS 601 13852 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	