

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Middle Harbour Public School (2543)</b>
<b>AMU REGION:</b>	<b>Northern Sydney</b>
<b>STATE ELECTORATE:</b>	<b>North Shore</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Mosman</b>

2543 - Middle Harbour Public School  
Site Plan (10627)



















1:773

Printed: 03-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Movement - (12.75 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Home Base - (47.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0005 - Home Base - (47.66 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0006 - Movement - (15.87 SQM)	Not Applicable	Circulation or storage space.
B00A - R0009 - Seminar/Study - (6.79 SQM)	● Office (1)	
B00A - R0010 - Staff Room Annexe - (12.88 SQM)	● Office (3)	
B00A - R0012 - Practical Activities - 1hb - (17.76 SQM)	● Student Space (8)	
B00A - R0013 - Home Base - (47.79 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0014 - Home Base - (47.67 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R0016 - Movement - (13.4 SQM)	Not Applicable	Circulation or storage space.
B00A - R1001 - Movement - (7.3 SQM)	Not Applicable	Circulation or storage space.
B00A - R1003 - Practical Activities - 1hb - (36.4 SQM)	● Student Space (16)	
B00A - R1004 - Home Base - (47.45 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1005 - Home Base - (47.33 SQM) - Teaching Space: 1	● Student Space (21)	
B00A - R1006 - Home Base - (47.58 SQM) - Teaching Space: 1	● Student Space (22)	
B00A - R1007 - Practical Activities - 1hb - (47.64 SQM)	● Student Space (22)	
B00A - R1008 - Practical Activities - 1hb - (36.61 SQM)	● Student Space (16)	
B00A - R1009 - Seminar/Study - (20.58 SQM)	● Office (5)	
B00A - R1012 - Movement - (5.25 SQM)	Not Applicable	Circulation or storage space.
B00B - R0001 - Home Base - (52.14 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0002 - Home Base - (52.21 SQM) - Teaching Space: 1	● Student Space (24)	
B00C - R0001 - Home Base - (51.06 SQM) - Teaching Space: 1	● Student Space (23)	
B00C - R0002 - Home Base - (51.14 SQM) - Teaching Space: 1	● Student Space (23)	
B00F - R0003 - Home Base - (53.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0005 - Special Programs Room - (13.37 SQM)	● Student Space (6)	
B00F - R0009 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0010 - Home Base - (53.46 SQM) - Teaching Space: 1	● Student Space (24)	
B00F - R0020 - Computer Room - (24.11 SQM)	● Student Space (11)	
B00H - R0003 - Communal Space - (247.96 SQM)	● Student Space (115)	
B00H - R0004 - Raised Platform - (56.04 SQM)	Not Applicable	Circulation or storage space.
B00J - R0004 - Special Programs Room - (44.6 SQM)	● Student Space (20)	
B00K - R0017 - Principal - (18.25 SQM)	● Office (4)	
B00K - R0018 - Entry Vestibule - (7.12 SQM)	Not Applicable	Circulation or storage space.
B00K - R0019 - Clerical Office - (21.82 SQM)	● Office (5)	
B00K - R0030 - Duplicating Workroom - (17.95 SQM)	● Office (4)	
B00K - R0031 - Movement - (15.45 SQM)	Not Applicable	Circulation or storage space.
B00K - R0033 - Staff Room - (50.55 SQM)	● Office (12)	
B00K - R0034 - Staff Kitchen - (14.61 SQM)	● Office (3)	
B00K - R0035 - Study Annexe - (9.85 SQM)	● Office (2)	
B00K - R0036 - Clerical Office - (12.17 SQM)	● Office (3)	
B00K - R0037 - Movement - (6.37 SQM)	Not Applicable	Circulation or storage space.
B00L - R0005 - Home Base - (55.1 SQM) - Teaching Space: 1	● Student Space (25)	
B00L - R0014 - Canteen - (38.3 SQM)	Not Applicable	Circulation or storage space.
B00M - R0004 - Reading Area - (169.75 SQM)	● Student Space (78)	
B00M - R0005 - Reading Area - (36.27 SQM)	● Student Space (16)	
B00O - R0001 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00O - R0002 - Home Base - (61.22 SQM) - Teaching Space: 1	● Student Space (28)	
B00O - R0003 - Home Base - (60.5 SQM) - Teaching Space: 1	● Student Space (28)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B000 - R0005 - Practical Activities - 1hb - (19.06 SQM)	 Student Space (8)	
B000 - R0006 - Withdrawal Space - 2hb - (11.61 SQM)	 Student Space (5)	
B000 - R0007 - Practical Activities - 1hb - (18.37 SQM)	 Student Space (8)	
B000 - R0009 - Withdrawal Space - 1hb - (8.75 SQM)	 Student Space (4)	
B000 - R0010 - Practical Activities - 1hb - (19.51 SQM)	 Student Space (9)	
B000 - R1001 - Home Base - (58.01 SQM) - Teaching Space: 1	 Student Space (26)	
B000 - R1002 - Home Base - (60.92 SQM) - Teaching Space: 1	 Student Space (28)	
B000 - R1003 - Home Base - (60.8 SQM) - Teaching Space: 1	 Student Space (28)	
B000 - R1005 - Practical Activities - 1hb - (18.78 SQM)	 Student Space (8)	
B000 - R1006 - Withdrawal Space - 2hb - (11.56 SQM)	 Student Space (5)	
B000 - R1007 - Practical Activities - 1hb - (18.12 SQM)	 Student Space (8)	
B000 - R1009 - Withdrawal Space - 1hb - (9.12 SQM)	 Student Space (4)	
B000 - R1010 - Practical Activities - 1hb - (20.56 SQM)	 Student Space (9)	
OS 602 10191 - OS 602 10191 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 13875 - OS 602 13875 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 603 13378 - OS 603 13378 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	 Student Space (35)	