


# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Millthorpe Public School (2558)</b>
<b>AMU REGION:</b>	<b>North Western NSW</b>
<b>STATE ELECTORATE:</b>	<b>Bathurst</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Blayney</b>

2558 - Millthorpe Public School  
Site Plan (10651)



1:694

Printed: 11-Mar-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Special Programs Room - (75.47 SQM)	● Student Space (35)	
B00B - R0001 - Withdrawal Space - 1hb - (8.17 SQM)	● Student Space (3)	
B00B - R0005 - Canteen - (15.63 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Home Base - (49.75 SQM) - Teaching Space: 1	● Student Space (23)	
B00B - R0007 - Home Base - (48.94 SQM) - Teaching Space: 1	● Student Space (22)	
B00B - R0008 - Home Base - (53.1 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0009 - Home Base - (53.83 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0012 - Movement - (70.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0013 - Movement - (6.25 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Special Programs Room - (53.17 SQM)	● Student Space (24)	
B00D - R0018 - Principal - (12.41 SQM)	● Office (3)	
B00D - R0019 - Clerical Office - (18.97 SQM)	● Office (4)	
B00D - R0020 - Entry Vestibule - (8.92 SQM)	Not Applicable	Circulation or storage space.
B00D - R0021 - Staff Room - (54.58 SQM)	● Office (13)	
B00D - R0022 - Sick Bay - (15.55 SQM)	● Student Space (7)	
B00G - R0002 - Reading Area - (92.77 SQM)	● Student Space (43)	
B00G - R0003 - Principal - (20.36 SQM)	● Office (5)	
B00J - R0001 - Communal Space - (237.55 SQM)	● Student Space (110)	
B00K - R0004 - Canteen - (26.23 SQM)	Not Applicable	Circulation or storage space.
OS 601 10183 - OS 601 10183 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11065 - OS 601 11065 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 11963 - OS 601 11963 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 13792 - OS 601 13792 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 601 14253 - OS 601 14253 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 14546 - OS 602 14546 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 11514 - OS 603 11514 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 10855 - OS 606 10855 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	