

VENTILATION AUDIT REPORT

SCHOOL:	Minchinbury Public School (4577)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Mount Druitt
LOCAL GOVERNMENT AREA:	Blacktown

4577 - Minchinbury Public School
Site Plan (10567)
























1:1,093

Printed: 11-Jun-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0019 - Communal Space - (140.74 SQM)	● Student Space (65)	
B00A - R0020 - Raised Platform - (42.74 SQM)	Not Applicable	Circulation or storage space.
B00B - R0006 - Canteen - (31.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0002 - Staff Room - (48.43 SQM)	● Office (12)	
B00C - R0003 - Staff Room Annexe - (19.12 SQM)	● Office (4)	
B00C - R0004 - Movement - (39.79 SQM)	Not Applicable	Circulation or storage space.
B00C - R0009 - Principal - (17.15 SQM)	● Office (4)	
B00C - R0012 - Sick Bay - (9.54 SQM)	● Student Space (4)	
B00C - R0013 - Clerical Office/Workroom - (13.22 SQM)	● Office (3)	
B00C - R0014 - Entry Vestibule - (13.59 SQM)	Not Applicable	Circulation or storage space.
B00C - R0015 - Clerical Office - (13.24 SQM)	● Office (3)	
B00C - R0017 - Duplicating Workroom - (20.58 SQM)	● Office (5)	
B00C - R0019 - Deputy Principal - (13.69 SQM)	● Office (3)	
B00C - R0020 - Interview - (13.15 SQM)	● Office (3)	
B00D - R0001 - Special Programs Room - (34.81 SQM)	● Student Space (16)	
B00D - R0008 - Movement - (15.04 SQM)	Not Applicable	Circulation or storage space.
B00D - R0010 - Reading Area - (168.96 SQM)	● Student Space (78)	
B00E - R0005 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0006 - Withdrawal Space - 1hb - (12.33 SQM)	● Student Space (5)	
B00E - R0007 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0012 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0013 - Withdrawal Space - 1hb - (12.29 SQM)	● Student Space (5)	
B00E - R0014 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0019 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0020 - Withdrawal Space - 1hb - (12.36 SQM)	● Student Space (5)	
B00E - R0021 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00E - R0026 - Movement - (6.53 SQM)	Not Applicable	Circulation or storage space.
B00E - R0028 - Practical Activities - 1hb - (36.19 SQM)	● Student Space (16)	
B00E - R0030 - Practical Activities - 1hb - (36.02 SQM)	● Student Space (16)	
B00E - R0031 - Movement - (6.47 SQM)	Not Applicable	Circulation or storage space.
B00E - R0035 - Practical Activities - 1hb - (34.28 SQM)	● Student Space (15)	
B00E - R0036 - Movement - (6.48 SQM)	Not Applicable	Circulation or storage space.
B00F - R0005 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0006 - Withdrawal Space - 1hb - (12.36 SQM)	● Student Space (5)	
B00F - R0007 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0012 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0013 - Withdrawal Space - 1hb - (12.36 SQM)	● Student Space (5)	
B00F - R0014 - Home Base - (59.8 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0019 - Movement - (6.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0021 - Practical Activities - 1hb - (36.31 SQM)	● Student Space (16)	
B00F - R0023 - Movement - (6.45 SQM)	Not Applicable	Circulation or storage space.
B00F - R0025 - Practical Activities - 1hb - (36.31 SQM)	● Student Space (16)	
B00G - R0002 - Practical Activities - 1hb - (19.68 SQM)	● Student Space (9)	
B00G - R0003 - Home Base - (62.02 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0004 - Withdrawal Space - 2hb - (11.67 SQM)	● Student Space (5)	
B00G - R0005 - Home Base - (61.91 SQM) - Teaching Space: 1	● Student Space (28)	
B00G - R0006 - Practical Activities - 1hb - (19.66 SQM)	● Student Space (9)	
B00H - R0001 - Movement - (38.5 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00H - R0002 - Practical Activities - 1hb - (19.41 SQM)	 Student Space (9)	
B00H - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	 Student Space (5)	
B00H - R0006 - Home Base - (59.22 SQM) - Teaching Space: 1	 Student Space (27)	
B00H - R0008 - Practical Activities - 1hb - (19.42 SQM)	 Student Space (9)	
B00J - R0003 - Home Base/Practical Activities - (59.34 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0004 - Withdrawal Space - 2hb - (11.3 SQM)	 Student Space (5)	
B00J - R0005 - Home Base/Practical Activities - (59.46 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0008 - Home Base/Practical Activities - (59.55 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0009 - Withdrawal Space - 2hb - (11.3 SQM)	 Student Space (5)	
B00J - R0010 - Home Base/Practical Activities - (59.44 SQM) - Teaching Space: 1	 Student Space (27)	
B00J - R0012 - Home Base/Practical Activities - (58.18 SQM) - Teaching Space: 1	 Student Space (26)	
B00J - R0013 - Withdrawal Space - 1hb - (9.07 SQM)	 Student Space (4)	
B00J - R0015 - Practical Activities - 1hb - (18.48 SQM)	 Student Space (8)	
B00J - R0017 - Practical Activities - 1hb - (18.63 SQM)	 Student Space (8)	
B00J - R0019 - Practical Activities - 1hb - (18.63 SQM)	 Student Space (8)	
B00J - R0020 - Practical Activities - 1hb - (18.58 SQM)	 Student Space (8)	
B00J - R0021 - Practical Activities - 1hb - (18.59 SQM)	 Student Space (8)	
OS 522 16306 - OS 522 16306 - Staff Study - (38 SQM)	 Office (9)	
OS 602 12545 - OS 602 12545 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 12819 - OS 602 12819 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	