

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Minto Public School (2572)</b>
<b>AMU REGION:</b>	<b>South Western Sydney</b>
<b>STATE ELECTORATE:</b>	<b>Macquarie Fields</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Campbelltown</b>

2572 - Minto Public School  
Site Plan (12920)



1:761

Printed: 21-Mar-2020

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0007 - Home Base - (53.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0008 - Home Base - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B00A - R0010 - Entry Vestibule - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R0011 - Principal - (12.02 SQM)	● Office (3)	
B00A - R0013 - Staff Room - (21.6 SQM)	● Office (5)	
B00A - R0014 - Staff Kitchen - (18.34 SQM)	● Office (4)	
B00A - R0015 - Deputy Principal - (12.85 SQM)	● Office (3)	
B00A - R0016 - Sick Bay - (9.28 SQM)	● Student Space (4)	
B00A - R0017 - Interview - (10.29 SQM)	● Office (2)	
B00A - R0018 - Principal - (14.9 SQM)	● Office (3)	
B00A - R0019 - Clerical Office - (24.08 SQM)	● Office (6)	
B00A - R0020 - Entry Vestibule - (21.05 SQM)	Not Applicable	Circulation or storage space.
B00A - R0024 - Movement - (21.15 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Movement - (8.55 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Practical Activities - 1hb - (9.81 SQM)	● Student Space (4)	
B00A - R0030 - Practical Activities - 1hb - (11.76 SQM)	● Student Space (5)	
B00B - R0003 - Home Base - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0004 - Special Programs Room - (53.74 SQM)	● Student Space (24)	
B00B - R0005 - Practical Activities - 1hb - (10.49 SQM)	● Student Space (4)	
B00B - R0006 - Practical Activities - 1hb - (10.46 SQM)	● Student Space (4)	
B00D - R0006 - Movement - (13.14 SQM)	Not Applicable	Circulation or storage space.
B00D - R1001 - Home Base - (86.45 SQM) - Teaching Space: 1	● Student Space (40)	
B00D - R1002 - Movement - (23.67 SQM)	Not Applicable	Circulation or storage space.
B00D - R1003 - Movement - (6.87 SQM)	Not Applicable	Circulation or storage space.
B00K - R0004 - Movement - (19.59 SQM)	Not Applicable	Circulation or storage space.
B00L - R0001 - Movement - (38.49 SQM)	Not Applicable	Circulation or storage space.
B00L - R0002 - Practical Activities - 1hb - (19.4 SQM)	● Student Space (9)	
B00L - R0004 - Home Base - (59.22 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0005 - Withdrawal Space - 2hb - (11.36 SQM)	● Student Space (5)	
B00L - R0006 - Home Base - (59.21 SQM) - Teaching Space: 1	● Student Space (27)	
B00L - R0008 - Practical Activities - 1hb - (19.41 SQM)	● Student Space (9)	
B00M - R0001 - Communal Space - (145.97 SQM)	● Student Space (67)	
B00M - R0002 - Raised Platform - (57.45 SQM)	Not Applicable	Circulation or storage space.
B00M - R0015 - Movement - (13.86 SQM)	Not Applicable	Circulation or storage space.
B00M - R0018 - Movement - (7.48 SQM)	Not Applicable	Circulation or storage space.
B00M - R0020 - Canteen - (26.59 SQM)	Not Applicable	Circulation or storage space.
OS 534 11341 - OS 534 11341 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 601 11343 - OS 601 11343 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	
OS 602 12867 - OS 602 12867 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 14961 - OS 602 14961 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	