

VENTILATION AUDIT REPORT

SCHOOL:	Mitchell High School (8403)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Blacktown
LOCAL GOVERNMENT AREA:	Blacktown

8403 - Mitchell High School
Site Plan (10485)



































1:1,451

Printed: 12-Jun-2021

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0005 - Laboratory L.S. - (86.57 SQM) - Teaching Space: 1	 Student Space (40)	
B00A - R0008 - Laboratory L.S. - (86.42 SQM) - Teaching Space: 1	 Student Space (40)	
B00A - R0012 - Food Technology L.S. - (65.88 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R0020 - Staff Study - (26.01 SQM)	 Office (6)	
B00A - R0021 - Movement - (113.84 SQM)	Not Applicable	Circulation or storage space.
B00A - R0026 - Staff Lounge - (11.47 SQM)	 Office (2)	
B00A - R0028 - Preparation - Science - (38.63 SQM)	Not Applicable	Circulation or storage space.
B00A - R0029 - Preparation - Science - (16.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R0031 - Preparation - (23.7 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Food Technology L.S. - (92.26 SQM) - Teaching Space: 1	 Student Space (42)	
B00A - R1004 - Laboratory L.S. - (79.17 SQM) - Teaching Space: 1	 Student Space (36)	
B00A - R1005 - General Learning Space - (65.73 SQM) - Teaching Space: 1	 Student Space (30)	
B00A - R1008 - General Learning Space - (52.74 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R1010 - General Learning Space - (52.74 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R1011 - General Learning Space - (52.73 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R1012 - General Learning Space - (52.81 SQM) - Teaching Space: 1	 Student Space (24)	
B00A - R1013 - Staff Study - (25.85 SQM)	 Office (6)	
B00A - R1015 - Preparation - (12.71 SQM)	Not Applicable	Circulation or storage space.
B00A - R1018 - Interview/Office - Type 1 - (25.64 SQM)	 Office (6)	
B00A - R1019 - Movement - (112.52 SQM)	Not Applicable	Circulation or storage space.
B00B - R0004 - General Assistants - (6.4 SQM)	 Office (1)	
B00B - R0008 - Movement - (17.98 SQM)	Not Applicable	Circulation or storage space.
B00B - R0009 - Movement - (320.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Student Canteen - (43.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0016 - Movement - (17.78 SQM)	Not Applicable	Circulation or storage space.
B00B - R0024 - Movement - (157.69 SQM)	Not Applicable	Circulation or storage space.
B00B - R0026 - Movement - (6.67 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Movement - (7.24 SQM)	Not Applicable	Circulation or storage space.
B00C - R0004 - Materials Technology L.S. - (79.09 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0005 - Materials Technology L.S. - (65.91 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R0009 - Design L.S. - (65.91 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R0011 - Movement - (112.56 SQM)	Not Applicable	Circulation or storage space.
B00C - R0014 - Staff Study - (24.84 SQM)	 Office (6)	
B00C - R0016 - Materials Technology L.S. - (79.03 SQM) - Teaching Space: 1	 Student Space (36)	
B00C - R0020 - Materials Technology L.S. - (81.63 SQM) - Teaching Space: 1	 Student Space (37)	
B00C - R0021 - Welding Area - (10.11 SQM)	Not Applicable	Circulation or storage space.
B00C - R1004 - Art Learning Space - (68.04 SQM) - Teaching Space: 1	 Student Space (31)	
B00C - R1005 - Art Learning Space - (65.91 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R1010 - Staff Study - (24.94 SQM)	 Office (6)	
B00C - R1012 - Music Learning Space - (65.73 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R1014 - Music Learning Space - (65.72 SQM) - Teaching Space: 1	 Student Space (30)	
B00C - R1015 - General Learning Space - (39.21 SQM) - Teaching Space: 1	 Student Space (18)	
B00C - R1016 - Computer Learning Space - (52.8 SQM) - Teaching Space: 1	 Student Space (24)	
B00C - R1017 - Movement - (106.72 SQM)	Not Applicable	Circulation or storage space.
B00C - R1023 - Dark Room - (30.79 SQM)	 Office (7)	
B00C - R1024 - Movement - (5.82 SQM)	Not Applicable	Circulation or storage space.
B00D - R0004 - Staff Study - (25.93 SQM)	 Office (6)	
B00D - R0008 - General Learning Space - (49.98 SQM) - Teaching Space: 1	 Student Space (23)	
B00D - R0009 - Audio Visual Workroom - (25.99 SQM)	 Student Space (12)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00D - R0010 - Workroom - (38.9 SQM)	Office (9)	
B00D - R0013 - Seminar - (12.93 SQM)	Office (3)	
B00D - R0014 - Seminar - (12.61 SQM)	Office (3)	
B00D - R0017 - Movement - (32.21 SQM)	Not Applicable	Circulation or storage space.
B00D - R0019 - Commonroom - (78.25 SQM)	Office (19)	
B00D - R0020 - Movement - (23.55 SQM)	Not Applicable	Circulation or storage space.
B00D - R0024 - Movement - (40.29 SQM)	Not Applicable	Circulation or storage space.
B00D - R0025 - Staff Study - (39 SQM)	Office (9)	
B00D - R0032 - Movement - (19.66 SQM)	Not Applicable	Circulation or storage space.
B00D - R0033 - Seminar Space - (17.56 SQM)	Office (4)	
B00D - R0034 - Seminar Space - (21.31 SQM)	Office (5)	
B00D - R0035 - Seminar Space - (25.75 SQM)	Office (6)	
B00D - R1001 - Computer Learning Space - (52.07 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1002 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1003 - General Learning Space - (52.15 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1004 - General Learning Space - (66.06 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1007 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1009 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00D - R1012 - General Learning Space - (65.91 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1013 - General Learning Space - (65.91 SQM) - Teaching Space: 1	Student Space (30)	
B00D - R1015 - Movement - (120.11 SQM)	Not Applicable	Circulation or storage space.
B00D - R1017 - Staff Study - (34.78 SQM)	Office (8)	
B00E - R0002 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0004 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0005 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R0006 - General Learning Space - (39.25 SQM) - Teaching Space: 1	Student Space (18)	
B00E - R0007 - Staff Study - (38.65 SQM)	Office (9)	
B00E - R0012 - Laboratory L.S. - (93.22 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0013 - Preparation - (29.17 SQM)	Not Applicable	Circulation or storage space.
B00E - R0015 - Laboratory L.S. - (92.86 SQM) - Teaching Space: 1	Student Space (43)	
B00E - R0016 - Computer Learning Space - (65.98 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R0017 - Movement - (122.46 SQM)	Not Applicable	Circulation or storage space.
B00E - R1001 - General Learning Space - (52.58 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1002 - Staff Study - (26.01 SQM)	Office (6)	
B00E - R1003 - General Learning Space - (65.91 SQM) - Teaching Space: 1	Student Space (30)	
B00E - R1005 - General Learning Space - (53.83 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1009 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1012 - Staff Study - (25.16 SQM)	Office (6)	
B00E - R1013 - General Learning Space - (52.73 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1014 - General Learning Space - (52.72 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1015 - General Learning Space - (52.43 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1016 - General Learning Space - (52.35 SQM) - Teaching Space: 1	Student Space (24)	
B00E - R1019 - Movement - (121.09 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Student Canteen - (17.56 SQM)	Not Applicable	Circulation or storage space.
B00F - R0003 - Movement - (70.69 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Stage - (109.46 SQM)	Not Applicable	Circulation or storage space.
B00F - R0015 - Movement - (16.38 SQM)	Not Applicable	Circulation or storage space.
B00F - R0017 - Multi-Purpose Space - (455.19 SQM)	Student Space (211)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00G - R0001 - Leading Teacher - (14.85 SQM)	Office (3)	
B00G - R0002 - Principal Office - (19.56 SQM)	Office (4)	
B00G - R0003 - Deputy Principal Office - (17.01 SQM)	Office (4)	
B00G - R0005 - Administration - Clerical - (36.08 SQM)	Office (9)	
B00G - R0006 - Clinic - Girls - (13.2 SQM)	Office (3)	
B00G - R0009 - Clinic - Boys - (12.81 SQM)	Office (3)	
B00G - R0010 - Administration - Clerical - (12.81 SQM)	Office (3)	
B00G - R0011 - Teachers Aides - (12.82 SQM)	Office (3)	
B00G - R0012 - Interview/Office - Type 1 - (12.81 SQM)	Office (3)	
B00G - R0014 - Ancillary Staff - (22.58 SQM)	Office (5)	
B00G - R0016 - Duplicating Workroom - (27.37 SQM)	Office (6)	
B00G - R0017 - Movement - (81.62 SQM)	Not Applicable	Circulation or storage space.
B00G - R1001 - Commonroom - (96.77 SQM)	Office (24)	
B00G - R1004 - Movement - (8.73 SQM)	Not Applicable	Circulation or storage space.
NS 200 14763 - NS 200 14763 - Art Learning Space/Workshop/Bulk Store - (95 SQM)	Not Applicable	Circulation or storage space.
OS 600 14016 - OS 600 14016 - Learning Unit - Small - (57 SQM)	Student Space (26)	
OS 601 10154 - OS 601 10154 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 11444 - OS 601 11444 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14115 - OS 601 14115 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 601 14511 - OS 601 14511 - Learning Unit - Standard/Withdrawal - (76 SQM)	Student Space (35)	
OS 621 14353 - OS 621 14353 - Learning Unit Single - PWD - (95 SQM)	Student Space (44)	
OS 720 14762 - OS 720 14762 - Science Laboratory/Prep Room - (114 SQM)	Not Applicable	Circulation or storage space.