

# VENTILATION AUDIT REPORT

<b>SCHOOL:</b>	<b>Mittagong Public School (2581)</b>
<b>AMU REGION:</b>	<b>Southern NSW</b>
<b>STATE ELECTORATE:</b>	<b>Wollondilly</b>
<b>LOCAL GOVERNMENT AREA:</b>	<b>Wingecarribee</b>

2581 - Mittagong Public School  
Site Plan (10557)



1:1,034

Printed: 03-Sep-2021

## Ventilation Audit Key

Category	Description
	Category A Operate this space in line with <a href="#">COVID safe school operations</a> . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m <sup>2</sup> to comply with <a href="#">COVID safe school operations and the guided use of spaces</a> . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0001 - Clerical Office - (19.71 SQM)	Office (4)	
B00A - R0002 - Entry Vestibule - (11.92 SQM)	Not Applicable	Circulation or storage space.
B00A - R0003 - Duplicating Workroom - (27.02 SQM)	Office (6)	
B00A - R0004 - Deputy Principal - (14.2 SQM)	Office (3)	
B00A - R0005 - Interview - (14.24 SQM)	Office (3)	
B00A - R0006 - Staff Room Annexe - (13.06 SQM)	Office (3)	
B00A - R0007 - Sick Bay - (9.32 SQM)	Student Space (4)	
B00A - R0008 - Principal - (15.39 SQM)	Office (3)	
B00A - R0016 - Movement - (27.28 SQM)	Not Applicable	Circulation or storage space.
B00A - R0017 - Movement - (27.49 SQM)	Not Applicable	Circulation or storage space.
B00A - R0018 - Movement - (12.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0019 - Movement - (28.6 SQM)	Not Applicable	Circulation or storage space.
B00A - R0020 - Movement - (20.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0021 - Staff Room - (47.82 SQM)	Office (11)	
B00A - R0022 - Staff Kitchen - (10.37 SQM)	Office (2)	
B00B - R0002 - Special Programs Room - (31.86 SQM)	Student Space (14)	
B00B - R0006 - Movement - (8.33 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Duplicating Workroom - (6.24 SQM)	Office (1)	
B00B - R0011 - Movement - (9.35 SQM)	Not Applicable	Circulation or storage space.
B00B - R0012 - Movement - (42.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R0004 - Movement - (40.91 SQM)	Not Applicable	Circulation or storage space.
B00E - R0009 - Withdrawal Space - 1hb - (16.2 SQM)	Student Space (7)	
B00E - R0010 - Home Base - (47.34 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0011 - Home Base - (47.26 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R0012 - Home Base - (47.4 SQM) - Teaching Space: 1	Student Space (21)	
B00E - R1002 - Home Base - (48.86 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1003 - Home Base - (48.2 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1004 - Home Base - (49 SQM) - Teaching Space: 1	Student Space (22)	
B00E - R1005 - Movement - (48.64 SQM)	Not Applicable	Circulation or storage space.
B00E - R1006 - Withdrawal Space - 1hb - (17.26 SQM)	Student Space (8)	
B00F - R0004 - Home Base - (52.79 SQM) - Teaching Space: 1	Student Space (24)	
B00F - R0005 - Movement - (19.19 SQM)	Not Applicable	Circulation or storage space.
B00G - R0002 - Movement - (31.81 SQM)	Not Applicable	Circulation or storage space.
B00G - R0003 - Home Base - (53.44 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0004 - Home Base - (53.74 SQM) - Teaching Space: 1	Student Space (24)	
B00G - R0005 - Staff Room Annexe - (13.29 SQM)	Office (3)	
B00J - R0001 - Staff Room - (33.43 SQM)	Office (8)	
B00J - R0007 - Home Base - (57.2 SQM) - Teaching Space: 1	Student Space (26)	
B00J - R0008 - Home Base - (86.15 SQM) - Teaching Space: 1	Student Space (39)	
B00J - R0014 - Movement - (78.08 SQM)	Not Applicable	Circulation or storage space.
B00K - R0001 - Movement - (83.88 SQM)	Not Applicable	Circulation or storage space.
B00K - R0002 - Special Programs Room - (42.14 SQM)	Student Space (19)	
B00K - R0007 - Reading Area - (226.65 SQM)	Student Space (105)	
B00L - R0004 - Movement - (23.7 SQM)	Not Applicable	Circulation or storage space.
B00M - R0006 - Communal Space - (183.19 SQM)	Student Space (84)	
B00M - R0009 - Raised Platform - (54.55 SQM)	Not Applicable	Circulation or storage space.
B00M - R0011 - Movement - (31.64 SQM)	Not Applicable	Circulation or storage space.
B00M - R0013 - Movement - (6.74 SQM)	Not Applicable	Circulation or storage space.
B00M - R0019 - Movement - (6.96 SQM)	Not Applicable	Circulation or storage space.
B00M - R0025 - Communal Space - (362.35 SQM)	Student Space (168)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00M - R0026 - Movement - (120 SQM)	Not Applicable	Circulation or storage space.
B00N - R0001 - Home Base - (60.11 SQM) - Teaching Space: 1	● Student Space (27)	
B00N - R0003 - Practical Activities - 1hb - (19.09 SQM)	● Student Space (8)	
B00N - R0004 - Movement - (39.37 SQM)	Not Applicable	Circulation or storage space.
B00N - R0005 - Withdrawal Space - 2hb - (11.48 SQM)	● Student Space (5)	
B00N - R0006 - Practical Activities - 1hb - (18.8 SQM)	● Student Space (8)	
B00N - R0008 - Home Base - (59.3 SQM) - Teaching Space: 1	● Student Space (27)	
B00S - R0002 - Special Programs Room - (33.75 SQM)	● Student Space (15)	
B00S - R0009 - Special Programs Room - (15.46 SQM)	● Student Space (7)	
B00U - R0009 - Movement - (12.27 SQM)	Not Applicable	Circulation or storage space.
B00U - R0010 - Home Base - (45.12 SQM) - Teaching Space: 1	● Student Space (20)	
B00V - R0001 - Home Base - (60.56 SQM) - Teaching Space: 1	● Student Space (28)	
B00V - R0003 - Practical Activities - 1hb - (19.79 SQM)	● Student Space (9)	
B00V - R0004 - Withdrawal Space - 2hb - (11.78 SQM)	● Student Space (5)	
B00V - R0005 - Home Base - (60.47 SQM) - Teaching Space: 1	● Student Space (28)	
B00V - R0007 - Practical Activities - 1hb - (19.74 SQM)	● Student Space (9)	
B00V - R0008 - Home Base - (58.7 SQM) - Teaching Space: 1	● Student Space (27)	
B00V - R0010 - Withdrawal Space - 1hb - (8.95 SQM)	● Student Space (4)	
B00V - R0011 - Practical Activities - 1hb - (20.61 SQM)	● Student Space (9)	
B00W - R0004 - Home Base - (60.27 SQM) - Teaching Space: 1	● Student Space (27)	
OS 602 10835 - OS 602 10835 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 11610 - OS 602 11610 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 12635 - OS 602 12635 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 602 13139 - OS 602 13139 - Learning Unit - Standard With P.A.A. - (76 SQM)	● Student Space (35)	
OS 603 10497 - OS 603 10497 - Learning Unit - Standard With P.A.A. A/C - (76 SQM)	● Student Space (35)	
OS 606 16305 - OS 606 16305 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19068 - OS 606 19068 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19133 - OS 606 19133 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19591 - OS 606 19591 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	
OS 606 19599 - OS 606 19599 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	● Student Space (35)	