

VENTILATION AUDIT REPORT

SCHOOL:	Moama Public School (2584)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Murray
LOCAL GOVERNMENT AREA:	Murray River

2584 - Moama Public School
Site Plan (12925)



1:883

Printed: 21-Mar-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0006 - Movement - (67.68 SQM)	Not Applicable	Circulation or storage space.
B00A - R0014 - Home Base - (86.02 SQM) - Teaching Space: 1	● Student Space (39)	
B00A - R0015 - Home Base - (86.35 SQM) - Teaching Space: 1	● Student Space (40)	
B00A - R0021 - Clerical Office/Workroom - (16.09 SQM)	○ Office (4)	
B00A - R0022 - Staff Room - (42.32 SQM)	○ Office (10)	
B00A - R0027 - Staff Kitchen - (8.67 SQM)	○ Office (2)	
B00A - R0028 - Movement - (5.03 SQM)	Not Applicable	Circulation or storage space.
B00B - R0008 - Home Base - (53.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0012 - Home Base - (53.62 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0013 - Special Programs Room - (26.7 SQM)	● Student Space (12)	
B00B - R0014 - Home Base - (52.67 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0020 - Movement - (69.91 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - Entry Vestibule - (17.29 SQM)	Not Applicable	Circulation or storage space.
B00B - R0022 - Clerical Office/Workroom - (35.96 SQM)	○ Office (8)	
B00B - R0023 - Interview - (11.84 SQM)	○ Office (2)	
B00B - R0024 - Sick Bay - (14.3 SQM)	● Student Space (6)	
B00B - R0027 - Movement - (5.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R0028 - Principal - (18.67 SQM)	○ Office (4)	
B00C - R0001 - Movement - (42.53 SQM)	Not Applicable	Circulation or storage space.
B00C - R0003 - Withdrawal Space - 2hb - (17.71 SQM)	● Student Space (8)	
B00C - R0005 - Home Base - (53.47 SQM) - Teaching Space: 1	● Student Space (24)	
B00D - R0002 - Home Base - (58.52 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0003 - Practical Activities - 1hb - (20.96 SQM)	● Student Space (9)	
B00D - R0004 - Withdrawal Space - 1hb - (11.65 SQM)	● Student Space (5)	
B00D - R0005 - Movement - (41.36 SQM)	Not Applicable	Circulation or storage space.
B00D - R0006 - Home Base - (58.53 SQM) - Teaching Space: 1	● Student Space (27)	
B00D - R0007 - Practical Activities - 1hb - (20.91 SQM)	● Student Space (9)	
B00D - R0010 - Movement - (5.41 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Movement - (32.54 SQM)	Not Applicable	Circulation or storage space.
B00U - R0002 - Movement - (14.45 SQM)	Not Applicable	Circulation or storage space.
B00U - R0004 - Home Base - Pre - (87.95 SQM) - Teaching Space: 1	● Student Space (40)	
B00U - R0005 - Practical Activities - Pre - (9.33 SQM)	● Student Space (4)	
B00U - R0011 - Staff Kitchen - (15.35 SQM)	○ Office (3)	
B00W - R0002 - Communal Space - (147.59 SQM)	● Student Space (68)	
B00W - R0003 - Movement - (6.02 SQM)	Not Applicable	Circulation or storage space.
B00W - R0004 - Raised Platform - (59.9 SQM)	Not Applicable	Circulation or storage space.
B00W - R0006 - Movement - (10.77 SQM)	Not Applicable	Circulation or storage space.
B00X - R0001 - Special Programs Room - (52.33 SQM)	● Student Space (24)	
B00X - R0003 - Staff Kitchen - (10.66 SQM)	○ Office (2)	
OS 534 12450 - OS 534 12450 - Library/Group Study/Office/A V Store - (152 SQM)	● Student Space (70)	
OS 801 16621 - OS 801 16621 - FSU - (57 SQM)	Not Applicable	Circulation or storage space.