


VENTILATION AUDIT REPORT

SCHOOL:	Modanville Public School (2585)
AMU REGION:	North Coast
STATE ELECTORATE:	Lismore
LOCAL GOVERNMENT AREA:	Lismore

2585 - Modanville Public School
Site Plan (11997)



1:791

Printed: 07-Oct-2020

Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0002 - Withdrawal Space - 1hb - (7.99 SQM)	● Student Space (3)	
B00A - R0005 - Practical Activities - 1hb - (14.63 SQM)	● Student Space (6)	
B00A - R0006 - Home Base - (35.1 SQM) - Teaching Space: 1	● Student Space (16)	
B00D - R0001 - Practical Activities - 1hb - (14.95 SQM)	● Student Space (6)	
B00D - R0002 - Home Base - (38.18 SQM) - Teaching Space: 1	● Student Space (17)	
B00D - R0004 - Movement - (26.35 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Special Programs Room - (33.08 SQM)	● Student Space (15)	
B00F - R0001 - Practical Activities - 1hb - (13.52 SQM)	● Student Space (6)	
B00F - R0002 - Home Base - (59.77 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0003 - Withdrawal Space - 1hb - (11.55 SQM)	● Student Space (5)	
B00F - R0005 - Movement - (14.76 SQM)	Not Applicable	Circulation or storage space.
B00F - R0006 - Movement - (14.75 SQM)	Not Applicable	Circulation or storage space.
B00F - R0007 - Home Base - (59.76 SQM) - Teaching Space: 1	● Student Space (27)	
B00F - R0008 - Practical Activities - 1hb - (13.52 SQM)	● Student Space (6)	
B00J - R0001 - Canteen - (21.39 SQM)	Not Applicable	Circulation or storage space.
B00M - R0001 - Clerical Office - (17.66 SQM)	● Office (4)	
B00M - R0003 - Sick Bay - (7.45 SQM)	● Student Space (3)	
B00M - R0006 - Movement - (21.39 SQM)	Not Applicable	Circulation or storage space.
B00M - R0007 - Principal - (15.48 SQM)	● Office (3)	
B00M - R0009 - Staff Room - (20.57 SQM)	● Office (5)	
B00M - R0010 - Reading Area - (70.82 SQM)	● Student Space (32)	
B00M - R0013 - Withdrawal Space - 1hb - (12.8 SQM)	● Student Space (5)	
B00M - R0016 - Staff Kitchen - (5.69 SQM)	● Office (1)	