

VENTILATION AUDIT REPORT

SCHOOL:	Model Farms High School (8499)
AMU REGION:	Western Sydney
STATE ELECTORATE:	Baulkham Hills
LOCAL GOVERNMENT AREA:	The Hills

8499 - Model Farms High School
Site Plan (10568)



Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B001 - R0001 - Materials Technology L.S. - (78.47 SQM) - Teaching Space: 1	● Student Space (36)	
B001 - R0003 - Metal Technology Bay - (10.4 SQM)	Not Applicable	Circulation or storage space.
B001 - R0005 - Materials Technology L.S. - (79.46 SQM) - Teaching Space: 1	● Student Space (36)	
B001 - R0008 - Art Learning Space - (63.28 SQM) - Teaching Space: 1	● Student Space (29)	
B001 - R0014 - Movement - (36.86 SQM)	Not Applicable	Circulation or storage space.
B001 - R1001 - Materials Technology L.S. - (83.12 SQM) - Teaching Space: 1	● Student Space (38)	
B001 - R1005 - Materials Technology L.S. - (83.03 SQM) - Teaching Space: 1	● Student Space (38)	
B001 - R1008 - General Learning Space - (52.87 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R1009 - Staff Study - (25.79 SQM)	● Office (6)	
B001 - R1010 - Design L.S. - (53.02 SQM) - Teaching Space: 1	● Student Space (24)	
B001 - R1013 - Movement - (52.2 SQM)	Not Applicable	Circulation or storage space.
B002 - R0008 - Student Canteen - (54.16 SQM)	Not Applicable	Circulation or storage space.
B002 - R0023 - Movement - (35.64 SQM)	Not Applicable	Circulation or storage space.
B002 - R0025 - Movement - (144.45 SQM)	Not Applicable	Circulation or storage space.
B002 - R0030 - Multi-Purpose Space - (186.5 SQM)	● Student Space (86)	
B002 - R0031 - Multi-Purpose Space - (119.61 SQM)	● Student Space (55)	
B002 - R0033 - Movement - (49.15 SQM)	Not Applicable	Circulation or storage space.
B002 - R0035 - Movement - (77.83 SQM)	Not Applicable	Circulation or storage space.
B002 - R1009 - Movement - (66.14 SQM)	Not Applicable	Circulation or storage space.
B002 - R1010 - Movement - (20.65 SQM)	Not Applicable	Circulation or storage space.
B002 - R1012 - Movement - (58.89 SQM)	Not Applicable	Circulation or storage space.
B002 - R1014 - Workshop - (20.99 SQM)	● Student Space (9)	
B003 - R0003 - Food Technology L.S. - (82.21 SQM) - Teaching Space: 1	● Student Space (38)	
B003 - R0006 - Food Technology L.S. - (82.65 SQM) - Teaching Space: 1	● Student Space (38)	
B003 - R0009 - Staff Study - (20.91 SQM)	● Office (5)	
B003 - R0010 - General Learning Space - (65.76 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R0013 - Staff Study - (32.25 SQM)	● Office (8)	
B003 - R0018 - Movement - (75.2 SQM)	Not Applicable	Circulation or storage space.
B003 - R1001 - Performance Workspace - (64.87 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1004 - Design L.S. - (65.66 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1005 - Music Learning Space - (65.11 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1007 - Music Learning Space - (65.56 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1009 - Art Learning Space - (65.43 SQM) - Teaching Space: 1	● Student Space (30)	
B003 - R1010 - Art Learning Space - (69.48 SQM) - Teaching Space: 1	● Student Space (32)	
B003 - R1013 - Movement - (62.18 SQM)	Not Applicable	Circulation or storage space.
B004 - M1001 - Main Area - (148.01 SQM)	Not Applicable	Circulation or storage space.
B004 - M1003 - Seminar - (23.92 SQM)	● Office (5)	
B004 - R0001 - Laboratory L.S. - (91.23 SQM) - Teaching Space: 1	● Student Space (42)	
B004 - R0002 - Preparation - (49.27 SQM)	Not Applicable	Circulation or storage space.
B004 - R0003 - Laboratory L.S. - (91.23 SQM) - Teaching Space: 1	● Student Space (42)	
B004 - R0007 - Laboratory L.S. - (91.34 SQM) - Teaching Space: 1	● Student Space (42)	
B004 - R0008 - Preparation - (49.32 SQM)	Not Applicable	Circulation or storage space.
B004 - R0009 - Laboratory L.S. - (91.34 SQM) - Teaching Space: 1	● Student Space (42)	
B004 - R0010 - Movement - (58.72 SQM)	Not Applicable	Circulation or storage space.
B004 - R0012 - Movement - (124.96 SQM)	Not Applicable	Circulation or storage space.
B004 - R0016 - Movement - (15.11 SQM)	Not Applicable	Circulation or storage space.
B004 - R0018 - Movement - (82.45 SQM)	Not Applicable	Circulation or storage space.
B004 - R0019 - Movement - (42.49 SQM)	Not Applicable	Circulation or storage space.
B004 - R1002 - Workroom - (34.51 SQM)	● Office (8)	
B004 - R1004 - Workroom - (13.32 SQM)	● Office (3)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B004 - R1006 - Entry - (6.38 SQM)	Not Applicable	Circulation or storage space.
B004 - R1009 - Main Area - (368.1 SQM)	Not Applicable	Circulation or storage space.
B004 - R1010 - Seminar - (13.03 SQM)	Office (3)	
B004 - R1011 - Seminar - (14.51 SQM)	Office (3)	
B004 - R1016 - Seminar - (14.26 SQM)	Office (3)	
B004 - R1017 - Seminar - (13.1 SQM)	Office (3)	
B004 - R1018 - Movement - (8.44 SQM)	Not Applicable	Circulation or storage space.
B004 - R1021 - Movement - (134.88 SQM)	Not Applicable	Circulation or storage space.
B005 - R0005 - Clinic - Boys - (14.08 SQM)	Office (3)	
B005 - R0006 - Interview/Office - Type 1 - (9.62 SQM)	Office (2)	
B005 - R0007 - Interview/Office - Type 1 - (9.73 SQM)	Office (2)	
B005 - R0009 - Principal Office - (23.14 SQM)	Office (5)	
B005 - R0010 - Deputy Principal Office - (19.79 SQM)	Office (4)	
B005 - R0014 - Leading Teacher - (16.2 SQM)	Office (4)	
B005 - R0024 - General Learning Space - (61.78 SQM) - Teaching Space: 1	Student Space (28)	
B005 - R0025 - Staff Study - (44.17 SQM)	Office (11)	
B005 - R0027 - Staff Lounge - (76.78 SQM)	Office (19)	
B005 - R0028 - Staff Study - (14.15 SQM)	Office (3)	
B005 - R0029 - Entry - (18.15 SQM)	Not Applicable	Circulation or storage space.
B005 - R0030 - Movement - (102.32 SQM)	Not Applicable	Circulation or storage space.
B005 - R0031 - Administration - Clerical - (9.61 SQM)	Office (2)	
B005 - R0032 - Administration - Clerical - (39.24 SQM)	Office (9)	
B005 - R1001 - General Learning Space - (53.74 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R1002 - General Learning Space - (53.6 SQM) - Teaching Space: 1	Student Space (24)	
B005 - R1006 - General Learning Space - (60.23 SQM) - Teaching Space: 1	Student Space (27)	
B005 - R1007 - General Learning Space - (60.24 SQM) - Teaching Space: 1	Student Space (27)	
B005 - R1008 - General Learning Space - (53.89 SQM) - Teaching Space: 1	Student Space (25)	
B005 - R1011 - General Learning Space - (40.54 SQM) - Teaching Space: 1	Student Space (18)	
B005 - R1013 - Staff Study - (17.98 SQM)	Office (4)	
B005 - R1014 - General Learning Space - (40.53 SQM) - Teaching Space: 1	Student Space (18)	
B005 - R1015 - Movement - (57.75 SQM)	Not Applicable	Circulation or storage space.
B006 - R0001 - Laboratory L.S. - (90.54 SQM) - Teaching Space: 1	Student Space (42)	
B006 - R0002 - Preparation - (47.49 SQM)	Not Applicable	Circulation or storage space.
B006 - R0004 - Laboratory L.S. - (90.54 SQM) - Teaching Space: 1	Student Space (42)	
B006 - R0005 - General Assistants - (10.76 SQM)	Office (2)	
B006 - R1001 - Laboratory L.S. - (90.54 SQM) - Teaching Space: 1	Student Space (42)	
B006 - R1002 - Preparation - (47.48 SQM)	Not Applicable	Circulation or storage space.
B006 - R1004 - Laboratory L.S. - (90.53 SQM) - Teaching Space: 1	Student Space (42)	
B006 - R1009 - Movement - (60.5 SQM)	Not Applicable	Circulation or storage space.
B007 - R0001 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0002 - General Learning Space - (53.16 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0005 - Darkroom Space - (13.37 SQM)	Office (3)	
B007 - R0006 - Duplicating Workroom - (37.25 SQM)	Office (9)	
B007 - R0008 - Administration - Clerical - (10.82 SQM)	Office (2)	
B007 - R0015 - General Learning Space - (53.23 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0016 - General Learning Space - (53.75 SQM) - Teaching Space: 1	Student Space (24)	
B007 - R0017 - General Learning Space - (37.93 SQM) - Teaching Space: 1	Student Space (17)	
B007 - R0018 - General Learning Space - (52.36 SQM) - Teaching Space: 1	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B007 - R0020 - Movement - (86.34 SQM)	Not Applicable	Circulation or storage space.
B007 - R0022 - Movement - (58.64 SQM)	Not Applicable	Circulation or storage space.
B007 - R0025 - Movement - (15.84 SQM)	Not Applicable	Circulation or storage space.
B007 - R1001 - General Learning Space - (53.16 SQM) - Teaching Space: 1	● Student Space (24)	
B007 - R1002 - General Learning Space - (54.04 SQM) - Teaching Space: 1	● Student Space (25)	
B007 - R1003 - Movement - (18.82 SQM)	Not Applicable	Circulation or storage space.
B007 - R1004 - General Learning Space - (54.33 SQM) - Teaching Space: 1	● Student Space (25)	
B007 - R1005 - General Learning Space - (54.7 SQM) - Teaching Space: 1	● Student Space (25)	
B007 - R1006 - Staff Study - (11.09 SQM)	● Office (2)	
B007 - R1009 - Staff Study - (40.9 SQM)	● Office (10)	
B007 - R1011 - General Learning Space - (53.17 SQM) - Teaching Space: 1	● Student Space (24)	
B007 - R1013 - Movement - (26.4 SQM)	Not Applicable	Circulation or storage space.
B007 - R1014 - General Learning Space - (53.97 SQM) - Teaching Space: 1	● Student Space (25)	
B007 - R1015 - General Learning Space - (53.6 SQM) - Teaching Space: 1	● Student Space (24)	
B007 - R1016 - Staff Study - (18.37 SQM)	● Office (4)	
B007 - R1019 - Movement - (57.35 SQM)	Not Applicable	Circulation or storage space.
B008 - R0001 - General Learning Space - (51.55 SQM) - Teaching Space: 1	● Student Space (23)	
B008 - R0002 - General Learning Space - (51.55 SQM) - Teaching Space: 1	● Student Space (23)	
B008 - R0003 - Staff Study - (25.11 SQM)	● Office (6)	
B008 - R0004 - General Learning Space - (53.75 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R0006 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R0007 - General Learning Space - (53.23 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R0012 - Staff Study - (32.02 SQM)	● Office (8)	
B008 - R0014 - Staff Study - (11.04 SQM)	● Office (2)	
B008 - R0016 - Computer Learning Space - (50.77 SQM) - Teaching Space: 1	● Student Space (23)	
B008 - R0019 - Movement - (82.43 SQM)	Not Applicable	Circulation or storage space.
B008 - R0023 - Movement - (92.84 SQM)	Not Applicable	Circulation or storage space.
B008 - R1001 - Computer Learning Space - (54.18 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R1002 - General Learning Space - (53.01 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R1003 - Staff Study - (18.21 SQM)	● Office (4)	
B008 - R1004 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R1005 - General Learning Space - (53.68 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R1007 - General Learning Space - (53.1 SQM) - Teaching Space: 1	● Student Space (24)	
B008 - R1009 - Staff Study - (39.89 SQM)	● Office (9)	
B008 - R1010 - Staff Study - (10.77 SQM)	● Office (2)	
B008 - R1013 - Movement - (27.04 SQM)	Not Applicable	Circulation or storage space.
B008 - R1014 - General Learning Space - (54.55 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R1015 - General Learning Space - (54.71 SQM) - Teaching Space: 1	● Student Space (25)	
B008 - R1016 - Movement - (18.13 SQM)	Not Applicable	Circulation or storage space.
B008 - R1018 - Movement - (77.13 SQM)	Not Applicable	Circulation or storage space.
B012 - R0001 - Gymnasium - (480.71 SQM)	● Student Space (223)	
B012 - R0014 - Stage - (113.3 SQM)	Not Applicable	Circulation or storage space.
B012 - R0015 - Movement - (21.91 SQM)	Not Applicable	Circulation or storage space.
OS 601 19451 - OS 601 19451 - Learning Unit - Standard/Withdrawal - (76 SQM)	● Student Space (35)	