


VENTILATION AUDIT REPORT

SCHOOL:	Monaro High School (8196)
AMU REGION:	Southern NSW
STATE ELECTORATE:	Monaro
LOCAL GOVERNMENT AREA:	Snowy Monaro

8196 - Monaro High School
Site Plan (11946)





















Ventilation Audit Key

Category	Description
	Category A Operate this space in line with COVID safe school operations . It has the required level of natural ventilation. NB. Circulation and storage areas should not be used for groups or gatherings.
	Category B This space should be occupied at 1 person per 4m ² to comply with COVID safe school operations and the guided use of spaces . The report details the number of people who can be accommodated safely in each of the identified spaces.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00A - R0003 - Metal Technology Bay - (18.21 SQM)	Not Applicable	Circulation or storage space.
B00A - R0004 - Materials Technology L.S. - (88.86 SQM)	● Student Space (41)	
B00A - R0005 - Movement - (20.98 SQM)	Not Applicable	Circulation or storage space.
B00A - R0006 - Staff Study - (20.74 SQM)	● Office (5)	
B00A - R0007 - Movement - (31.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R0008 - Movement - (15.69 SQM)	Not Applicable	Circulation or storage space.
B00A - R0032 - Design L.S. - (53.6 SQM)	● Student Space (24)	
B00A - R0033 - Computer Learning Space - (53.47 SQM)	● Student Space (24)	
B00A - R0034 - Materials Technology L.S. - (89.28 SQM)	● Student Space (41)	
B00A - R1010 - Movement - (42.01 SQM)	Not Applicable	Circulation or storage space.
B00A - R1011 - Movement - (58.12 SQM)	Not Applicable	Circulation or storage space.
B00A - R1025 - General Learning Space - (53.53 SQM)	● Student Space (24)	
B00A - R1026 - General Learning Space - (76.23 SQM)	● Student Space (35)	
B00A - R1028 - General Learning Space - (52.08 SQM)	● Student Space (24)	
B00A - R1029 - General Learning Space - (53.25 SQM)	● Student Space (24)	
B00A - R1032 - Staff Kitchen - (22.22 SQM)	● Office (5)	
B00A - R2013 - Movement - (72.62 SQM)	Not Applicable	Circulation or storage space.
B00A - R2014 - Practice/Seminar - (9.5 SQM)	Not Applicable	Circulation or storage space.
B00A - R2016 - Staff Study - (53.33 SQM)	● Office (13)	
B00A - R2017 - General Learning Space - (53.18 SQM)	● Student Space (24)	
B00A - R2019 - General Learning Space - (53.18 SQM)	● Student Space (24)	
B00A - R2020 - General Learning Space - (53.32 SQM)	● Student Space (24)	
B00B - R0001 - Leading Teacher - (8 SQM)	● Office (2)	
B00B - R0003 - Materials Technology L.S. - (79.21 SQM) - Teaching Space: 1	● Student Space (36)	
B00B - R0004 - Staff Study - (9.61 SQM)	● Office (2)	
B00B - R0012 - Staff Study - (23.89 SQM)	● Office (5)	
B00B - R0017 - General Learning Space - (69.12 SQM) - Teaching Space: 1	● Student Space (32)	
B00B - R0018 - General Learning Space - (92.6 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0019 - Growing/Breeding - (9.72 SQM)	Not Applicable	Circulation or storage space.
B00B - R0020 - Preparation - (28.6 SQM)	Not Applicable	Circulation or storage space.
B00B - R0021 - General Learning Space - (92.59 SQM) - Teaching Space: 1	● Student Space (42)	
B00B - R0024 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R0025 - Movement - (115.32 SQM)	Not Applicable	Circulation or storage space.
B00B - R0036 - Movement - (5.15 SQM)	Not Applicable	Circulation or storage space.
B00B - R0041 - Movement - (21.7 SQM)	Not Applicable	Circulation or storage space.
B00B - R0046 - Movement - (12.89 SQM)	Not Applicable	Circulation or storage space.
B00B - R0047 - Materials Technology L.S. - (118.05 SQM) - Teaching Space: 1	● Student Space (54)	
B00B - R0048 - Metal Technology Bay - (14.36 SQM)	Not Applicable	Circulation or storage space.
B00B - R0049 - Wood Technology Bay - (17.37 SQM)	Not Applicable	Circulation or storage space.
B00B - R1001 - General Learning Space - (52.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1002 - General Learning Space - (52.01 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1003 - General Learning Space - (52.08 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1004 - General Learning Space - (52.45 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1006 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1007 - Staff Study - (25.57 SQM)	● Office (6)	
B00B - R1010 - General Learning Space - (53.76 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1013 - General Learning Space - (52.09 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1014 - General Learning Space - (52.16 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1016 - General Learning Space - (52.23 SQM) - Teaching Space: 1	● Student Space (24)	
B00B - R1017 - Movement - (9.65 SQM)	Not Applicable	Circulation or storage space.

Entity Location	Audit Condition Classification (Capacity)	Comment
B00B - R1018 - Leading Teacher - (6 SQM)	Office (1)	
B00B - R1019 - Staff Study - (25.39 SQM)	Office (6)	
B00B - R1021 - Computer Learning Space - (50.79 SQM) - Teaching Space: 1	Student Space (23)	
B00B - R1023 - Movement - (102 SQM)	Not Applicable	Circulation or storage space.
B00B - R1025 - General Learning Space - (52.45 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1027 - General Learning Space - (39.35 SQM) - Teaching Space: 1	Student Space (18)	
B00B - R1028 - Movement - (64.34 SQM)	Not Applicable	Circulation or storage space.
B00B - R1029 - General Learning Space - (53.02 SQM) - Teaching Space: 1	Student Space (24)	
B00B - R1030 - Movement - (85.62 SQM)	Not Applicable	Circulation or storage space.
B00B - R1035 - Performance Workspace - (79.6 SQM) - Teaching Space: 1	Student Space (36)	
B00C - M1001 - Senior Study - (119.65 SQM)	Office (29)	
B00C - M1003 - Study Space - (18.45 SQM)	Not Applicable	Circulation or storage space.
B00C - R0019 - Staff Study - (91.39 SQM)	Office (22)	
B00C - R0020 - Interview/Meeting - (15.41 SQM)	Office (3)	
B00C - R0022 - Movement - (10.01 SQM)	Not Applicable	Circulation or storage space.
B00C - R0023 - Staff Lounge - (46.45 SQM)	Office (11)	
B00C - R0024 - Staff Kitchen - (39.87 SQM)	Office (9)	
B00C - R0025 - Staff Study - (122.33 SQM)	Office (30)	
B00C - R0026 - Interview/Meeting - (16.23 SQM)	Office (4)	
B00C - R0027 - Staff Study - (47.78 SQM)	Office (11)	
B00C - R0028 - Movement - (73.23 SQM)	Not Applicable	Circulation or storage space.
B00C - R1001 - Audio Visual Workroom - (47.93 SQM)	Student Space (22)	
B00C - R1003 - Movement - (46.06 SQM)	Not Applicable	Circulation or storage space.
B00C - R1005 - Main Area - (364.47 SQM)	Not Applicable	Circulation or storage space.
B00C - R1006 - Seminar - (12.02 SQM)	Office (3)	
B00C - R1007 - Seminar - (12.61 SQM)	Office (3)	
B00C - R1010 - Seminar - (12.6 SQM)	Office (3)	
B00C - R1011 - Seminar - (12.09 SQM)	Office (3)	
B00C - R1013 - Computer Learning Space - (37.16 SQM) - Teaching Space: 1	Student Space (17)	
B00D - R0008 - Movement - (15.53 SQM)	Not Applicable	Circulation or storage space.
B00D - R0009 - General Learning Space - (63.17 SQM) - Teaching Space: 1	Student Space (29)	
B00D - R0010 - Kitchen - Type 1 - (37.54 SQM)	Student Space (17)	
B00D - R0011 - Movement - (12.4 SQM)	Not Applicable	Circulation or storage space.
B00D - R0012 - Interview/Office - Type 1 - (12.95 SQM)	Office (3)	
B00D - R0014 - Commonroom - (9.17 SQM)	Office (2)	
B00D - R0015 - General Learning Space - (55.58 SQM) - Teaching Space: 1	Student Space (25)	
B00D - R0017 - Movement - (5.97 SQM)	Not Applicable	Circulation or storage space.
B00E - R0001 - Design L.S. - (67.46 SQM)	Student Space (31)	
B00E - R0002 - Food Technology L.S. - (100.32 SQM)	Student Space (46)	
B00E - R0004 - Food/Research Space - (21.09 SQM)	Not Applicable	Circulation or storage space.
B00E - R0007 - Seminar/Technology Space - (14.86 SQM)	Office (3)	
B00E - R0009 - Food Technology L.S. - (105.48 SQM)	Student Space (48)	
B00E - R0011 - Movement - (12.68 SQM)	Not Applicable	Circulation or storage space.
B00E - R0013 - Staff Study - (20.47 SQM)	Office (5)	
B00E - R0016 - Movement - (38.52 SQM)	Not Applicable	Circulation or storage space.
B00F - R0001 - Senior Study - (64.38 SQM)	Office (16)	
B00F - R0003 - Senior Seminar - (53.47 SQM)	Office (13)	
B00F - R0004 - Computer Learning Space - (53.62 SQM)	Student Space (24)	

Entity Location	Audit Condition Classification (Capacity)	Comment
B00F - R0005 - Art Learning Space - (75.74 SQM)	● Student Space (35)	
B00F - R0009 - Movement - (24.1 SQM)	Not Applicable	Circulation or storage space.
B00F - R0010 - Staff Study - (17.66 SQM)	● Office (4)	
B00F - R0011 - Movement - (5.27 SQM)	Not Applicable	Circulation or storage space.
B00F - R0012 - Staff Study - (10.57 SQM)	● Office (2)	
B00F - R0013 - Deputy Principal Office - (16.43 SQM)	● Office (4)	
B00F - R0014 - Leading Teacher - (12.24 SQM)	● Office (3)	
B00F - R0015 - Movement - (18.16 SQM)	Not Applicable	Circulation or storage space.
B00G - R0012 - Clinic - Boys - (14.37 SQM)	● Office (3)	
B00G - R0013 - Duplicating Workroom - (22.36 SQM)	● Office (5)	
B00G - R0014 - Ancillary Staff - (15.03 SQM)	● Office (3)	
B00G - R0015 - General Assistants - (18.05 SQM)	● Office (4)	
B00G - R0030 - Pupil Entry - (58.29 SQM)	Not Applicable	Circulation or storage space.
B00G - R0031 - Public Reception - (10.78 SQM)	Not Applicable	Circulation or storage space.
B00G - R0032 - Administration - Executive - (10.75 SQM)	● Office (2)	
B00G - R0033 - Staff Kitchen - (16.13 SQM)	● Office (4)	
B00G - R0035 - Interview/Meeting - (33.66 SQM)	● Office (8)	
B00G - R0036 - Deputy Principal Office - (16.73 SQM)	● Office (4)	
B00G - R0038 - Movement - (19.41 SQM)	Not Applicable	Circulation or storage space.
B00G - R0039 - Movement - (7.3 SQM)	Not Applicable	Circulation or storage space.
B00G - R0041 - Principal Office - (14.44 SQM)	● Office (3)	
B00G - R0042 - Administration - Clerical - (29.21 SQM)	● Office (7)	
B00G - R0046 - Movement - (6.94 SQM)	Not Applicable	Circulation or storage space.
B00H - R0002 - Multi-Purpose Space - (328.35 SQM)	● Student Space (152)	
B00H - R0003 - Movement - (18.6 SQM)	Not Applicable	Circulation or storage space.
B00H - R0004 - Stage - (78.27 SQM)	Not Applicable	Circulation or storage space.
B00H - R0007 - Staff Kitchen - (18.27 SQM)	● Office (4)	
B00H - R0012 - Movement - (23.17 SQM)	Not Applicable	Circulation or storage space.
B00H - R9006 - Student Canteen - (42.36 SQM)	Not Applicable	Circulation or storage space.
B00H - R9007 - Staff Kitchen - (26.71 SQM)	● Office (6)	
B00H - R9009 - Movement - (5.69 SQM)	Not Applicable	Circulation or storage space.
B00H - R9013 - Movement - (6.03 SQM)	Not Applicable	Circulation or storage space.
B00H - R9015 - General Assistants - (11.21 SQM)	● Office (2)	
B00K - R0001 - Laboratory L.S. - (65.39 SQM) - Teaching Space: 1	● Student Space (30)	
B00K - R0002 - Movement - (104.25 SQM)	Not Applicable	Circulation or storage space.
B00K - R0005 - Laboratory L.S. - (82.44 SQM) - Teaching Space: 1	● Student Space (38)	
B00K - R0009 - Laboratory L.S. - (82.47 SQM) - Teaching Space: 1	● Student Space (38)	
B00K - R0014 - Preparation - Science - (18.27 SQM)	Not Applicable	Circulation or storage space.
B00K - R0016 - Preparation - Science - (37.32 SQM)	Not Applicable	Circulation or storage space.
B00K - R1001 - Music Learning Space - (67.12 SQM) - Teaching Space: 1	● Student Space (31)	
B00K - R1002 - Movement - (15.21 SQM)	Not Applicable	Circulation or storage space.
B00K - R1006 - Staff Study - (25.01 SQM)	● Office (6)	
B00K - R1007 - Music Learning Space - (52.8 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1010 - Art Learning Space - (58.49 SQM) - Teaching Space: 1	● Student Space (27)	
B00K - R1011 - Art Learning Space - (53.18 SQM) - Teaching Space: 1	● Student Space (24)	
B00K - R1018 - Movement - (54.51 SQM)	Not Applicable	Circulation or storage space.
B00K - R1019 - Movement - (26.94 SQM)	Not Applicable	Circulation or storage space.
B00K - R9001 - Performance Workspace - (67.64 SQM) - Teaching Space: 1	● Student Space (31)	
B00K - R9003 - Movement - (13.19 SQM)	Not Applicable	Circulation or storage space.
B00K - R9006 - Movement - (6.88 SQM)	Not Applicable	Circulation or storage space.
B00K - R9007 - Darkroom Space - (36.61 SQM)	● Office (9)	

Entity Location	Audit Condition Classification (Capacity)	Comment
BOD1 - R0002 - Multi Media Studio - (11.43 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0003 - Multi Media Studio - (17.54 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0004 - Multi Media Studio - (16.45 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0006 - General Learning Space - Type 1 - (67.99 SQM) - Teaching Space: 1	 Student Space (31)	
BOD1 - R0007 - Seminar - Type 1 - (33.26 SQM)	 Office (8)	
BOD1 - R0013 - Movement - (12.26 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0014 - General Learning Space - (60.26 SQM) - Teaching Space: 1	 Student Space (27)	
BOD1 - R0015 - Shared Study Space - (42.45 SQM)	 Office (10)	
BOD1 - R0016 - Practical Activities - (11.78 SQM)	 Student Space (5)	
BOD1 - R0017 - General Learning Space - (60.29 SQM) - Teaching Space: 1	 Student Space (27)	
BOD1 - R0018 - Multi-Purpose Space - (78.92 SQM)	 Student Space (36)	
BOD1 - R0019 - Multi Media Workshop - (99.8 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0020 - Kitchen - Type 1 - (14.46 SQM)	 Student Space (6)	
BOD1 - R0021 - Movement - (11.72 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0022 - Movement - (24.17 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0023 - Movement - (24.22 SQM)	Not Applicable	Circulation or storage space.
BOD1 - R0024 - Movement - (11.4 SQM)	Not Applicable	Circulation or storage space.
OS 502 13510 - OS 502 13510 - Admin Staff/Principal/Clerk/Dup/Clinic - (152 SQM)	 Office (38)	
OS 601 19833 - OS 601 19833 - Learning Unit - Standard/Withdrawal - (76 SQM)	 Student Space (35)	
OS 602 11500 - OS 602 11500 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 19343 - OS 602 19343 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 602 19518 - OS 602 19518 - Learning Unit - Standard With P.A.A. - (76 SQM)	 Student Space (35)	
OS 606 10956 - OS 606 10956 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 11712 - OS 606 11712 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 16325 - OS 606 16325 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 606 70041 - OS 606 70041 - Learning Unit - Standard With P.A.A A/C - (76 SQM)	 Student Space (35)	
OS 710 15024 - OS 710 15024 - Home Science/Pantry/Laundry - (95 SQM)	 Office (23)	